

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 12/6/2024 9:59:04 AM

JOB DESCRIPTION

RED-HILL
Weekly
RUSH Weekly Red Hill

JOB NUMBER

380-123125-1

Eurofins Eaton Analytical Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

Authorization



Generated
12/6/2024 9:59:04 AM

Authorized for release by
Rachelle Arada, Project Manager
Rachelle.Arada@et.eurofinsus.com
(626)386-1106



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
QC Sample Results	15
QC Association Summary	32
Lab Chronicle	34
Certification Summary	35
Method Summary	37
Sample Summary	38
Chain of Custody	39
Receipt Checklists	41

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Qualifiers

GC/MS Semi VOA

Qualifier	Qualifier Description
B	Analyte was found in the associated method blank.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

GC Semi VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-123125-1

Job ID: 380-123125-1

Eurofins Eaton Analytical Pomona

Job Narrative 380-123125-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 11/20/2024 9:31 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperatures of the 3 coolers at receipt time were 0.3°C, 0.9°C and 2.3°C.

GC/MS Semi VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Gasoline Range Organics

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Diesel Range Organics

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260) P2
(331-203-TP400)**
PWSID Number: HI0000331

Lab Sample ID: 380-123125-1

No Detections.

**Client Sample ID: TB: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Lab Sample ID: 380-123125-2

No Detections.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260) P2
(331-203-TP400)**

Lab Sample ID: 380-123125-1

Date Collected: 11/18/24 10:26

Matrix: Drinking Water

Date Received: 11/20/24 09:31

PWSID Number: HI0000331

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
2,4'-DDD	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
2,4'-DDE	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
2,4'-DDT	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
2,4-Dinitrotoluene	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
2,6-Dinitrotoluene	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
2-Methylnaphthalene	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
4,4'-DDD	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
4,4'-DDE	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
4,4'-DDT	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Acenaphthene	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Acenaphthylene	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Acetochlor	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Alachlor	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
alpha-BHC	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
alpha-Chlordane	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Anthracene	<0.020		0.020	ug/L		11/21/24 16:40	11/22/24 16:57	1
Atrazine	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Benz(a)anthracene	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Benzo[a]pyrene	<0.020		0.020	ug/L		11/21/24 16:40	11/22/24 16:57	1
Benzo[b]fluoranthene	<0.020		0.020	ug/L		11/21/24 16:40	11/22/24 16:57	1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Benzo[k]fluoranthene	<0.020		0.020	ug/L		11/21/24 16:40	11/22/24 16:57	1
beta-BHC	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Bis(2-ethylhexyl) phthalate	<0.59		0.59	ug/L		11/21/24 16:40	11/22/24 16:57	1
Bromacil	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Butachlor	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Butylbenzylphthalate	<0.49		0.49	ug/L		11/21/24 16:40	11/22/24 16:57	1
Chlorobenzilate	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Chloroneb	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Chlorothalonil (Draconil, Bravo)	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Chlorpyrifos	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Chrysene	<0.020		0.020	ug/L		11/21/24 16:40	11/22/24 16:57	1
delta-BHC	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Di(2-ethylhexyl)adipate	<0.59	B	0.59	ug/L		11/21/24 16:40	11/22/24 16:57	1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Diclorvos (DDVP)	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Dieldrin	<0.0099		0.0099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Diethylphthalate	<0.49		0.49	ug/L		11/21/24 16:40	11/22/24 16:57	1
Dimethylphthalate	<0.49		0.49	ug/L		11/21/24 16:40	11/22/24 16:57	1
Di-n-butyl phthalate	<0.99		0.99	ug/L		11/21/24 16:40	11/22/24 16:57	1
Di-n-octyl phthalate	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Endosulfan I (Alpha)	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Endosulfan II (Beta)	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Endosulfan sulfate	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Endrin	<0.0099		0.0099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Endrin aldehyde	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
EPTC	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1

Eurofins Eaton Analytical Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260) P2
(331-203-TP400)**

Lab Sample ID: 380-123125-1

Date Collected: 11/18/24 10:26

Matrix: Drinking Water

Date Received: 11/20/24 09:31

PWSID Number: HI0000331

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Fluorene	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
gamma-Chlordane	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Heptachlor	<0.0099		0.0099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Heptachlor epoxide (isomer B)	<0.0099		0.0099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Hexachlorobenzene	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Hexachlorocyclopentadiene	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Isophorone	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Lindane	<0.0099		0.0099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Malathion	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Methoxychlor	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Metolachlor	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Molinate	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Naphthalene	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Parathion	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Pendimethalin (Penoxaline)	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Phenanthrene	<0.039		0.039	ug/L		11/21/24 16:40	11/22/24 16:57	1
Propachlor	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Pyrene	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Simazine	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Terbacil	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Terbutylazine	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Thiobencarb	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1
Total Permethrin (mixed isomers)	<0.20		0.20	ug/L		11/21/24 16:40	11/22/24 16:57	1
trans-Nonachlor	<0.049		0.049	ug/L		11/21/24 16:40	11/22/24 16:57	1
Trifluralin	<0.099		0.099	ug/L		11/21/24 16:40	11/22/24 16:57	1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	11/21/24 16:40	11/22/24 16:57	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	97		70 - 130	11/21/24 16:40	11/22/24 16:57	1
Perylene-d12	91		70 - 130	11/21/24 16:40	11/22/24 16:57	1
Triphenylphosphate	99		70 - 130	11/21/24 16:40	11/22/24 16:57	1

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
2-Methylnaphthalene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Acenaphthene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Acenaphthylene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Anthracene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Benzo[a]anthracene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Benzo[a]pyrene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Benzo[b]fluoranthene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Benzo[g,h,i]perylene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Benzo[k]fluoranthene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Chrysene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1

Eurofins Eaton Analytical Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260) P2
(331-203-TP400)**

Lab Sample ID: 380-123125-1

Date Collected: 11/18/24 10:26

Matrix: Drinking Water

Date Received: 11/20/24 09:31

PWSID Number: HI0000331

Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Dibenz(a,h)anthracene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Fluoranthene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Fluorene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Indeno[1,2,3-cd]pyrene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Naphthalene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Phenanthrene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1
Pyrene	<0.19		0.19	ug/L		11/22/24 13:13	12/04/24 17:10	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	74		28 - 127	11/22/24 13:13	12/04/24 17:10	1
2-Fluorobiphenyl (Surr)	66		31 - 120	11/22/24 13:13	12/04/24 17:10	1
2-Fluorophenol (Surr)	42		17 - 120	11/22/24 13:13	12/04/24 17:10	1
Nitrobenzene-d5 (Surr)	72		27 - 120	11/22/24 13:13	12/04/24 17:10	1
Phenol-d6 (Surr)	25		10 - 120	11/22/24 13:13	12/04/24 17:10	1
p-Terphenyl-d14 (Surr)	76		45 - 120	11/22/24 13:13	12/04/24 17:10	1

Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	11/22/24 13:13	12/05/24 20:35	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	78		33 - 139	11/22/24 13:13	12/05/24 20:35	1
2-Fluorobiphenyl (Surr)	67		33 - 126	11/22/24 13:13	12/05/24 20:35	1
2-Fluorophenol (Surr)	39		12 - 120	11/22/24 13:13	12/05/24 20:35	1
Nitrobenzene-d5 (Surr)	71		36 - 120	11/22/24 13:13	12/05/24 20:35	1
Phenol-d6 (Surr)	22		10 - 120	11/22/24 13:13	12/05/24 20:35	1
p-Terphenyl-d14 (Surr)	81		47 - 131	11/22/24 13:13	12/05/24 20:35	1

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			11/29/24 12:53	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	84		38 - 134		11/29/24 12:53	1

Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<26		26	ug/L		11/23/24 11:38	11/27/24 23:14	1
Motor Oil Range Organics [C24-C36]	<26		26	ug/L		11/23/24 11:38	11/27/24 23:14	1
C8-C18	<26		26	ug/L		11/23/24 11:38	11/27/24 23:14	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)	86		60 - 130	11/23/24 11:38	11/27/24 23:14	1

Client Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-123125-1
 SDG: Weekly

**Client Sample ID: TB: AIEA WELLS PUMPS 1&2 (260)
 (331-203-TP400)**

Lab Sample ID: 380-123125-2

Date Collected: 11/18/24 10:26

Matrix: Water

Date Received: 11/20/24 09:31

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			11/29/24 12:27	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	81		38 - 134				11/29/24 12:27	1

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260) P2
(331-203-TP400)**
PWSID Number: HI0000331

Lab Sample ID: 380-123125-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Alachlor	<0.049		ug/L	2	0.049	525.2	Total/NA
Atrazine	<0.049		ug/L	3	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.020		ug/L	0.2	0.020	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.59		ug/L	6	0.59	525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.59	B	ug/L	400	0.59	525.2	Total/NA
Endrin	<0.0099		ug/L	2	0.0099	525.2	Total/NA
Heptachlor	<0.0099		ug/L	0.4	0.0099	525.2	Total/NA
Heptachlor epoxide (isomer B)	<0.0099		ug/L	0.2	0.0099	525.2	Total/NA
Hexachlorobenzene	<0.049		ug/L	1	0.049	525.2	Total/NA
Hexachlorocyclopentadiene	<0.049		ug/L	50	0.049	525.2	Total/NA
Lindane	<0.0099		ug/L	0.2	0.0099	525.2	Total/NA
Methoxychlor	<0.049		ug/L	40	0.049	525.2	Total/NA
Simazine	<0.049		ug/L	4	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.19		ug/L	0.2	0.19	625.1 SIM	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-123125-1	AIEA WELLS PUMPS 1&2 (260)	97	91	99

Surrogate Legend
 2NMX = 2-Nitro-m-xylene
 PRY = Perylene-d12
 TPP = Triphenylphosphate

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-121607-M-1-A DU	Duplicate	97	80	95
380-122758-Q-1-A MS	Matrix Spike	97	91	105
LCS 380-120047/23-A	Lab Control Sample	97	91	101
LCS 380-120047/24-A	Lab Control Sample Dup	96	90	106
MB 380-120047/21-A	Method Blank	97	83	103
MRL 380-120047/22-A	Lab Control Sample	96	79	106

Surrogate Legend
 2NMX = 2-Nitro-m-xylene
 PRY = Perylene-d12
 TPP = Triphenylphosphate

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)
380-123125-1	AIEA WELLS PUMPS 1&2 (260)	78	67	39	71	22	81

Surrogate Legend
 TBP = 2,4,6-Tribromophenol (Surr)
 FBP = 2-Fluorobiphenyl (Surr)
 2FP = 2-Fluorophenol (Surr)
 NBZ = Nitrobenzene-d5 (Surr)
 PHL6 = Phenol-d6 (Surr)
 TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)
MB 570-506497/1-A	Method Blank	67	59	42	64	24	79

Surrogate Legend
 TBP = 2,4,6-Tribromophenol (Surr)
 FBP = 2-Fluorobiphenyl (Surr)
 2FP = 2-Fluorophenol (Surr)

Surrogate Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-123125-1
 SDG: Weekly

NBZ = Nitrobenzene-d5 (Surr)
 PHL6 = Phenol-d6 (Surr)
 TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-123125-1	AIEA WELLS PUMPS 1&2 (260)	74	66	42	72	25	76

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
 FBP = 2-Fluorobiphenyl (Surr)
 2FP = 2-Fluorophenol (Surr)
 NBZ = Nitrobenzene-d5 (Surr)
 PHL6 = Phenol-d6 (Surr)
 TPHd14 = p-Terphenyl-d14 (Surr)

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-123126-A-3-A MS	Matrix Spike	75	75	50	69	30	75
380-123126-A-3-B MSD	Matrix Spike Duplicate	79	79	54	72	32	73
LCS 570-506497/2-A	Lab Control Sample	81	80	60	74	36	79
LCS 570-506497/3-A	Lab Control Sample Dup	76	70	48	64	30	74
MB 570-506497/1-A	Method Blank	70	66	49	75	27	79

Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)
 FBP = 2-Fluorobiphenyl (Surr)
 2FP = 2-Fluorophenol (Surr)
 NBZ = Nitrobenzene-d5 (Surr)
 PHL6 = Phenol-d6 (Surr)
 TPHd14 = p-Terphenyl-d14 (Surr)

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)
		BFB1 (38-134)
380-123125-1	AIEA WELLS PUMPS 1&2 (260)	84

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)
		BFB1 (38-134)
380-123125-2	TB: AIEA WELLS PUMPS 1&2 (81
380-123126-C-3 MS	Matrix Spike	94

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB1 (38-134)
380-123126-C-3 MSD	Matrix Spike Duplicate	93
LCS 570-508548/4	Lab Control Sample	93
LCSD 570-508548/5	Lab Control Sample Dup	93
MB 570-508548/6	Method Blank	85
MRL 570-508548/3	Lab Control Sample	89

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Drinking Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-123125-1	AIEA WELLS PUMPS 1&2 (260)	86

Surrogate Legend

OTCSN = n-Octacosane (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-123126-B-3-A MS	Matrix Spike	88
380-123126-B-3-B MSD	Matrix Spike Duplicate	89
LCS 570-506858/2-A	Lab Control Sample	90
LCSD 570-506858/3-A	Lab Control Sample Dup	87
MB 570-506858/1-A	Method Blank	87
MRL 570-506858/4-A	Lab Control Sample	84

Surrogate Legend

OTCSN = n-Octacosane (Surr)

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-123125-1
 SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-120047/21-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 120047

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
2,4'-DDD	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
2,4'-DDE	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
2,4'-DDT	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
2,4-Dinitrotoluene	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
2,6-Dinitrotoluene	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
2-Methylnaphthalene	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
4,4'-DDD	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
4,4'-DDE	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
4,4'-DDT	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Acenaphthene	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Acenaphthylene	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Acetochlor	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Alachlor	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
alpha-BHC	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
alpha-Chlordane	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Anthracene	<0.020		0.020	ug/L		11/21/24 10:09	11/22/24 15:57	1
Atrazine	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Benz(a)anthracene	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Benzo[a]pyrene	<0.020		0.020	ug/L		11/21/24 10:09	11/22/24 15:57	1
Benzo[b]fluoranthene	<0.020		0.020	ug/L		11/21/24 10:09	11/22/24 15:57	1
Benzo[g,h,i]perylene	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Benzo[k]fluoranthene	<0.020		0.020	ug/L		11/21/24 10:09	11/22/24 15:57	1
beta-BHC	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Bis(2-ethylhexyl) phthalate	<0.60		0.60	ug/L		11/21/24 10:09	11/22/24 15:57	1
Bromacil	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Butachlor	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Butylbenzylphthalate	<0.50		0.50	ug/L		11/21/24 10:09	11/22/24 15:57	1
Chlorobenzilate	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Chloroneb	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Chlorothalonil (Draconil, Bravo)	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Chlorpyrifos	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Chrysene	<0.020		0.020	ug/L		11/21/24 10:09	11/22/24 15:57	1
delta-BHC	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Di(2-ethylhexyl)adipate	1.56	B	0.60	ug/L		11/21/24 10:09	11/22/24 15:57	1
Dibenz(a,h)anthracene	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Diclorvos (DDVP)	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Dieldrin	<0.0099		0.0099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Diethylphthalate	<0.50		0.50	ug/L		11/21/24 10:09	11/22/24 15:57	1
Dimethylphthalate	<0.50		0.50	ug/L		11/21/24 10:09	11/22/24 15:57	1
Di-n-butyl phthalate	<0.99		0.99	ug/L		11/21/24 10:09	11/22/24 15:57	1
Di-n-octyl phthalate	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Endosulfan I (Alpha)	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Endosulfan II (Beta)	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Endosulfan sulfate	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Endrin	<0.0099		0.0099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Endrin aldehyde	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
EPTC	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-120047/21-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 120047

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Fluorene	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
gamma-Chlordane	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Heptachlor	<0.0099		0.0099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Heptachlor epoxide (isomer B)	<0.0099		0.0099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Hexachlorobenzene	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Hexachlorocyclopentadiene	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Indeno[1,2,3-cd]pyrene	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Isophorone	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Lindane	<0.0099		0.0099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Malathion	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Methoxychlor	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Metolachlor	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Molinate	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Naphthalene	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Parathion	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Pendimethalin (Penoxaline)	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Phenanthrene	<0.040		0.040	ug/L		11/21/24 10:09	11/22/24 15:57	1
Propachlor	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Pyrene	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Simazine	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Terbacil	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Terbutylazine	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Thiobencarb	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1
Total Permethrin (mixed isomers)	<0.20		0.20	ug/L		11/21/24 10:09	11/22/24 15:57	1
trans-Nonachlor	<0.050		0.050	ug/L		11/21/24 10:09	11/22/24 15:57	1
Trifluralin	<0.099		0.099	ug/L		11/21/24 10:09	11/22/24 15:57	1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Unknown	0.592	T J	ug/L		3.20	N/A	11/21/24 10:09	11/22/24 15:57	1
9-Octadecenamamide, (Z)-	3.74	T J N	ug/L		7.98	301-02-0	11/21/24 10:09	11/22/24 15:57	1
Unknown	0.773	T J	ug/L		11.22	N/A	11/21/24 10:09	11/22/24 15:57	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	97		70 - 130	11/21/24 10:09	11/22/24 15:57	1
Perylene-d12	83		70 - 130	11/21/24 10:09	11/22/24 15:57	1
Triphenylphosphate	103		70 - 130	11/21/24 10:09	11/22/24 15:57	1

Lab Sample ID: LCS 380-120047/23-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	1.99	1.95		ug/L		98	70 - 130
2,4'-DDD	1.99	2.05		ug/L		103	70 - 130
2,4'-DDE	1.99	2.06		ug/L		103	70 - 130
2,4'-DDT	1.99	1.99		ug/L		100	70 - 130
2,4-Dinitrotoluene	1.99	1.63		ug/L		82	70 - 130

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-120047/23-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
2,6-Dinitrotoluene	1.99	1.71		ug/L		86	70 - 130
2-Methylnaphthalene	1.99	1.95		ug/L		98	70 - 130
4,4'-DDD	1.99	2.09		ug/L		105	70 - 130
4,4'-DDE	1.99	1.99		ug/L		100	70 - 130
4,4'-DDT	1.99	1.98		ug/L		100	70 - 130
Acenaphthene	1.99	1.96		ug/L		99	70 - 130
Acenaphthylene	1.99	1.99		ug/L		100	70 - 130
Acetochlor	1.99	2.10		ug/L		106	70 - 130
Alachlor	1.99	2.12		ug/L		107	70 - 130
alpha-BHC	1.99	2.00		ug/L		100	70 - 130
alpha-Chlordane	1.99	2.06		ug/L		104	70 - 130
Anthracene	1.99	1.89		ug/L		95	70 - 130
Atrazine	1.99	2.18		ug/L		110	70 - 130
Benz(a)anthracene	1.99	1.84		ug/L		93	70 - 130
Benzo[a]pyrene	1.99	1.82		ug/L		91	70 - 130
Benzo[b]fluoranthene	1.99	2.14		ug/L		108	70 - 130
Benzo[g,h,i]perylene	1.99	2.04		ug/L		103	70 - 130
Benzo[k]fluoranthene	1.99	2.10		ug/L		106	70 - 130
beta-BHC	1.99	2.01		ug/L		101	70 - 130
Bis(2-ethylhexyl) phthalate	1.99	2.04		ug/L		103	70 - 130
Bromacil	1.99	1.92		ug/L		97	70 - 130
Butachlor	1.99	2.17		ug/L		109	70 - 130
Butylbenzylphthalate	1.99	2.22		ug/L		112	70 - 130
Chlorobenzilate	1.99	1.78		ug/L		89	70 - 130
Chloroneb	1.99	1.96		ug/L		99	70 - 130
Chlorothalonil (Draconil, Bravo)	1.99	2.04		ug/L		103	70 - 130
Chlorpyrifos	1.99	2.17		ug/L		109	70 - 130
Chrysene	1.99	2.06		ug/L		104	70 - 130
delta-BHC	1.99	2.12		ug/L		107	70 - 130
Di(2-ethylhexyl)adipate	1.99	1.89		ug/L		95	70 - 130
Dibenz(a,h)anthracene	1.99	1.82		ug/L		92	70 - 130
Diclorvos (DDVP)	1.99	1.96		ug/L		99	70 - 130
Dieldrin	1.99	1.98		ug/L		100	70 - 130
Diethylphthalate	1.99	2.10		ug/L		106	70 - 130
Dimethylphthalate	1.99	2.08		ug/L		105	70 - 130
Di-n-butyl phthalate	3.97	4.24		ug/L		107	70 - 130
Di-n-octyl phthalate	1.99	1.68		ug/L		85	70 - 130
Endosulfan I (Alpha)	1.99	1.98		ug/L		100	70 - 130
Endosulfan II (Beta)	1.99	2.00		ug/L		101	70 - 130
Endosulfan sulfate	1.99	2.02		ug/L		102	70 - 130
Endrin	1.99	1.94		ug/L		98	70 - 130
Endrin aldehyde	1.99	2.00		ug/L		101	60 - 130
EPTC	1.99	2.01		ug/L		101	70 - 130
Fluoranthene	1.99	2.12		ug/L		107	70 - 130
Fluorene	1.99	2.08		ug/L		105	70 - 130
gamma-Chlordane	1.99	2.00		ug/L		101	70 - 130
Heptachlor	1.99	1.93		ug/L		97	70 - 130
Heptachlor epoxide (isomer B)	1.99	1.99		ug/L		100	70 - 130
Hexachlorobenzene	1.99	1.89		ug/L		95	70 - 130

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-120047/23-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec	
							Limits	
Hexachlorocyclopentadiene	1.99	1.89		ug/L		95	70 - 130	
Indeno[1,2,3-cd]pyrene	1.99	1.96		ug/L		99	70 - 130	
Isophorone	1.99	1.92		ug/L		96	70 - 130	
Lindane	1.99	1.88		ug/L		95	70 - 130	
Malathion	1.99	2.13		ug/L		107	70 - 130	
Methoxychlor	1.99	1.98		ug/L		99	70 - 130	
Metolachlor	1.99	2.11		ug/L		106	70 - 130	
Molinate	1.99	2.06		ug/L		104	70 - 130	
Naphthalene	1.99	1.96		ug/L		99	70 - 130	
Parathion	1.99	1.94		ug/L		98	70 - 130	
Pendimethalin (Penoxaline)	1.99	1.80		ug/L		91	70 - 130	
Phenanthrene	1.99	1.92		ug/L		97	70 - 130	
Propachlor	1.99	2.06		ug/L		104	70 - 130	
Pyrene	1.99	2.11		ug/L		106	70 - 130	
Simazine	1.99	2.14		ug/L		108	70 - 130	
Terbacil	1.99	2.01		ug/L		101	70 - 130	
Terbutylazine	1.99	2.18		ug/L		110	70 - 130	
Thiobencarb	1.99	2.17		ug/L		109	70 - 130	
trans-Nonachlor	1.99	1.98		ug/L		100	70 - 130	
Trifluralin	1.99	1.73		ug/L		87	70 - 130	
		LCS	LCS					
Surrogate		%Recovery	Qualifier				Limits	
2-Nitro-m-xylene		97					70 - 130	
Perylene-d12		91					70 - 130	
Triphenylphosphate		101					70 - 130	

Lab Sample ID: LCSD 380-120047/24-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec		RPD	Limit
							Limits			
1-Methylnaphthalene	1.98	1.95		ug/L		98	70 - 130	0	20	
2,4'-DDD	1.98	2.12		ug/L		107	70 - 130	3	20	
2,4'-DDE	1.98	2.12		ug/L		107	70 - 130	3	20	
2,4'-DDT	1.98	2.07		ug/L		105	70 - 130	4	20	
2,4-Dinitrotoluene	1.98	1.75		ug/L		88	70 - 130	7	20	
2,6-Dinitrotoluene	1.98	1.80		ug/L		91	70 - 130	5	20	
2-Methylnaphthalene	1.98	1.95		ug/L		99	70 - 130	0	20	
4,4'-DDD	1.98	2.17		ug/L		110	70 - 130	4	20	
4,4'-DDE	1.98	2.09		ug/L		106	70 - 130	5	20	
4,4'-DDT	1.98	2.08		ug/L		105	70 - 130	5	20	
Acenaphthene	1.98	1.95		ug/L		99	70 - 130	0	20	
Acenaphthylene	1.98	2.01		ug/L		102	70 - 130	1	20	
Acetochlor	1.98	2.15		ug/L		109	70 - 130	3	20	
Alachlor	1.98	2.17		ug/L		110	70 - 130	3	20	
alpha-BHC	1.98	2.03		ug/L		103	70 - 130	2	20	
alpha-Chlordane	1.98	2.12		ug/L		107	70 - 130	3	20	
Anthracene	1.98	1.90		ug/L		96	70 - 130	0	20	

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 380-120047/24-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec		RPD	Limit
							Limits	RPD		
Atrazine	1.98	2.30		ug/L		116	70 - 130	5	20	
Benz(a)anthracene	1.98	1.91		ug/L		97	70 - 130	4	20	
Benzo[a]pyrene	1.98	1.77		ug/L		90	70 - 130	3	20	
Benzo[b]fluoranthene	1.98	2.01		ug/L		101	70 - 130	6	20	
Benzo[g,h,i]perylene	1.98	1.90		ug/L		96	70 - 130	7	20	
Benzo[k]fluoranthene	1.98	2.09		ug/L		105	70 - 130	1	20	
beta-BHC	1.98	2.11		ug/L		107	70 - 130	5	20	
Bis(2-ethylhexyl) phthalate	1.98	2.11		ug/L		106	70 - 130	3	20	
Bromacil	1.98	1.88		ug/L		95	70 - 130	2	20	
Butachlor	1.98	2.30		ug/L		116	70 - 130	6	20	
Butylbenzylphthalate	1.98	2.34		ug/L		118	70 - 130	5	20	
Chlorobenzilate	1.98	1.85		ug/L		93	70 - 130	4	20	
Chloroneb	1.98	1.95		ug/L		99	70 - 130	1	20	
Chlorothalonil (Draconil, Bravo)	1.98	2.03		ug/L		103	70 - 130	1	20	
Chlorpyrifos	1.98	2.23		ug/L		113	70 - 130	3	20	
Chrysene	1.98	1.94		ug/L		98	70 - 130	6	20	
delta-BHC	1.98	2.17		ug/L		110	70 - 130	2	20	
Di(2-ethylhexyl)adipate	1.98	2.10		ug/L		106	70 - 130	11	20	
Dibenz(a,h)anthracene	1.98	1.78		ug/L		90	70 - 130	3	20	
Diclorvos (DDVP)	1.98	2.07		ug/L		105	70 - 130	5	20	
Dieldrin	1.98	2.05		ug/L		104	70 - 130	4	20	
Diethylphthalate	1.98	2.14		ug/L		108	70 - 130	2	20	
Dimethylphthalate	1.98	2.13		ug/L		107	70 - 130	2	20	
Di-n-butyl phthalate	3.96	4.45		ug/L		113	70 - 130	5	20	
Di-n-octyl phthalate	1.98	1.76		ug/L		89	70 - 130	4	20	
Endosulfan I (Alpha)	1.98	2.03		ug/L		103	70 - 130	3	20	
Endosulfan II (Beta)	1.98	2.06		ug/L		104	70 - 130	3	20	
Endosulfan sulfate	1.98	2.07		ug/L		105	70 - 130	2	20	
Endrin	1.98	1.99		ug/L		101	70 - 130	3	20	
Endrin aldehyde	1.98	2.07		ug/L		105	60 - 130	4	20	
EPTC	1.98	2.04		ug/L		103	70 - 130	1	20	
Fluoranthene	1.98	2.18		ug/L		110	70 - 130	3	20	
Fluorene	1.98	2.10		ug/L		106	70 - 130	1	20	
gamma-Chlordane	1.98	2.08		ug/L		105	70 - 130	4	20	
Heptachlor	1.98	1.96		ug/L		99	70 - 130	1	20	
Heptachlor epoxide (isomer B)	1.98	2.05		ug/L		103	70 - 130	3	20	
Hexachlorobenzene	1.98	1.93		ug/L		98	70 - 130	2	20	
Hexachlorocyclopentadiene	1.98	1.89		ug/L		96	70 - 130	0	20	
Indeno[1,2,3-cd]pyrene	1.98	1.97		ug/L		99	70 - 130	0	20	
Isophorone	1.98	1.96		ug/L		99	70 - 130	2	20	
Lindane	1.98	1.92		ug/L		97	70 - 130	2	20	
Malathion	1.98	2.21		ug/L		112	70 - 130	4	20	
Methoxychlor	1.98	1.87		ug/L		95	70 - 130	5	20	
Metolachlor	1.98	2.19		ug/L		111	70 - 130	4	20	
Molinate	1.98	2.12		ug/L		107	70 - 130	3	20	
Naphthalene	1.98	1.95		ug/L		98	70 - 130	1	20	
Parathion	1.98	2.00		ug/L		101	70 - 130	3	20	
Pendimethalin (Penoxaline)	1.98	1.93		ug/L		98	70 - 130	7	20	
Phenanthrene	1.98	1.92		ug/L		97	70 - 130	0	20	

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 380-120047/24-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Propachlor	1.98	2.14		ug/L		108	70 - 130	4	20
Pyrene	1.98	2.14		ug/L		108	70 - 130	2	20
Simazine	1.98	2.30		ug/L		116	70 - 130	7	20
Terbacil	1.98	2.10		ug/L		106	70 - 130	4	20
Terbutylazine	1.98	2.30		ug/L		116	70 - 130	6	20
Thiobencarb	1.98	2.20		ug/L		111	70 - 130	1	20
trans-Nonachlor	1.98	2.04		ug/L		103	70 - 130	3	20
Trifluralin	1.98	1.88		ug/L		95	70 - 130	8	20

Surrogate	LCSD %Recovery	LCSD Qualifier	LCSD Limits
2-Nitro-m-xylene	96		70 - 130
Perylene-d12	90		70 - 130
Triphenylphosphate	106		70 - 130

Lab Sample ID: MRL 380-120047/22-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	0.0993	0.114		ug/L		115	50 - 150
2,4'-DDD	0.0993	0.101		ug/L		102	50 - 150
2,4'-DDE	0.0993	0.114		ug/L		114	50 - 150
2,4'-DDT	0.0993	0.0974	J	ug/L		98	50 - 150
2,4-Dinitrotoluene	0.0993	0.0928	J	ug/L		93	50 - 150
2,6-Dinitrotoluene	0.0993	0.0947	J	ug/L		95	50 - 150
2-Methylnaphthalene	0.0993	0.111		ug/L		112	50 - 150
4,4'-DDD	0.0993	0.117		ug/L		118	50 - 150
4,4'-DDE	0.0993	0.107		ug/L		108	50 - 150
4,4'-DDT	0.0993	0.0948	J	ug/L		95	50 - 150
Acenaphthene	0.0993	0.103		ug/L		103	50 - 150
Acenaphthylene	0.0993	0.0960	J	ug/L		97	50 - 150
Acetochlor	0.0993	0.130		ug/L		131	50 - 150
Alachlor	0.0497	0.0572		ug/L		115	50 - 150
alpha-BHC	0.0993	0.114		ug/L		115	50 - 150
alpha-Chlordane	0.0248	<0.029		ug/L		107	50 - 150
Anthracene	0.0199	0.0239		ug/L		120	50 - 150
Atrazine	0.0497	0.0553		ug/L		111	50 - 150
Benz(a)anthracene	0.0497	0.0508		ug/L		102	50 - 150
Benzo[a]pyrene	0.0199	0.0199	J	ug/L		100	50 - 150
Benzo[b]fluoranthene	0.0199	0.0185	J	ug/L		93	50 - 150
Benzo[g,h,i]perylene	0.0497	0.0411	J	ug/L		83	50 - 150
Benzo[k]fluoranthene	0.0199	0.0185	J	ug/L		93	50 - 150
beta-BHC	0.0993	0.121		ug/L		122	50 - 150
Bis(2-ethylhexyl) phthalate	0.596	0.577	J	ug/L		97	50 - 150
Bromacil	0.0993	0.105		ug/L		106	50 - 150
Butachlor	0.0497	0.0595		ug/L		120	50 - 150
Butylbenzylphthalate	0.497	0.606		ug/L		122	50 - 150
Chlorobenzilate	0.0993	0.101		ug/L		102	50 - 150

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-120047/22-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Chloroneb	0.0993	0.0857	J	ug/L		86	50 - 150
Chlorothalonil (Draconil, Bravo)	0.0993	0.0935	J	ug/L		94	50 - 150
Chlorpyrifos	0.0497	0.0529		ug/L		107	50 - 150
Chrysene	0.0199	0.0227		ug/L		114	50 - 150
delta-BHC	0.0993	0.124		ug/L		125	50 - 150
Di(2-ethylhexyl)adipate	0.596	0.770		ug/L		129	50 - 150
Dibenz(a,h)anthracene	0.0497	0.0456	J	ug/L		92	50 - 150
Diclorvos (DDVP)	0.0497	0.0577		ug/L		116	50 - 150
Dieldrin	0.00993	0.0119		ug/L		120	50 - 150
Diethylphthalate	0.497	0.552		ug/L		111	50 - 150
Dimethylphthalate	0.497	0.545		ug/L		110	50 - 150
Di-n-butyl phthalate	0.497	0.616	J	ug/L		124	49 - 243
Di-n-octyl phthalate	0.0993	0.0931	J	ug/L		94	50 - 150
Endosulfan I (Alpha)	0.0993	0.0953	J	ug/L		96	50 - 150
Endosulfan II (Beta)	0.0993	0.101		ug/L		101	50 - 150
Endosulfan sulfate	0.0993	0.105		ug/L		106	50 - 150
Endrin	0.00993	0.0120		ug/L		121	50 - 150
Endrin aldehyde	0.0993	0.107		ug/L		107	50 - 150
EPTC	0.0993	0.100		ug/L		101	50 - 150
Fluoranthene	0.0993	0.108		ug/L		109	50 - 150
Fluorene	0.0497	0.0522		ug/L		105	50 - 150
gamma-Chlordane	0.0248	0.0241	J	ug/L		97	50 - 150
Heptachlor	0.00993	0.0121		ug/L		122	50 - 150
Heptachlor epoxide (isomer B)	0.00993	0.0112		ug/L		113	50 - 150
Hexachlorobenzene	0.0497	0.0494	J	ug/L		100	50 - 150
Hexachlorocyclopentadiene	0.0497	0.0475	J	ug/L		96	50 - 150
Indeno[1,2,3-cd]pyrene	0.0497	0.0351	J	ug/L		71	50 - 150
Isophorone	0.0993	0.119		ug/L		120	50 - 150
Lindane	0.00993	0.0108		ug/L		109	50 - 150
Malathion	0.0993	0.102		ug/L		103	50 - 150
Methoxychlor	0.0497	0.0504		ug/L		101	50 - 150
Metolachlor	0.0497	0.0617		ug/L		124	50 - 150
Molinate	0.0993	0.107		ug/L		108	50 - 150
Naphthalene	0.0993	0.124		ug/L		125	50 - 150
Parathion	0.0993	0.0840	J	ug/L		85	50 - 150
Pendimethalin (Penoxaline)	0.0993	0.0856	J	ug/L		86	50 - 150
Phenanthrene	0.0397	0.0476		ug/L		120	50 - 150
Propachlor	0.0497	0.0580		ug/L		117	50 - 150
Pyrene	0.0497	0.0545		ug/L		110	50 - 150
Simazine	0.0497	0.0580		ug/L		117	50 - 150
Terbacil	0.0993	0.102		ug/L		103	50 - 150
Terbutylazine	0.0993	0.115		ug/L		116	50 - 150
Thiobencarb	0.0993	0.110		ug/L		111	50 - 150
trans-Nonachlor	0.0248	0.0262	J	ug/L		106	50 - 150
Trifluralin	0.0993	0.0893	J	ug/L		90	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
2-Nitro-m-xylene	96		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-120047/22-A
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 120047

Surrogate	MRL %Recovery	MRL Qualifier	Limits
Perylene-d12	79		70 - 130
Triphenylphosphate	106		70 - 130

Lab Sample ID: 380-122758-Q-1-A MS
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	<0.096		1.93	1.93		ug/L		100	70 - 130
2,4'-DDD	<0.096		1.93	2.01		ug/L		104	70 - 130
2,4'-DDE	<0.096		1.93	1.93		ug/L		100	70 - 130
2,4'-DDT	<0.096		1.93	1.89		ug/L		98	70 - 130
2,4-Dinitrotoluene	<0.096		1.93	1.95		ug/L		101	70 - 130
2,6-Dinitrotoluene	<0.096		1.93	1.96		ug/L		101	70 - 130
2-Methylnaphthalene	<0.096		1.93	1.93		ug/L		100	70 - 130
4,4'-DDD	<0.096		1.93	2.05		ug/L		106	70 - 130
4,4'-DDE	<0.096		1.93	1.85		ug/L		96	70 - 130
4,4'-DDT	<0.096		1.93	1.89		ug/L		98	70 - 130
Acenaphthene	<0.096		1.93	1.91		ug/L		99	70 - 130
Acenaphthylene	<0.096		1.93	2.03		ug/L		105	70 - 130
Acetochlor	<0.096		1.93	2.07		ug/L		107	70 - 130
Alachlor	<0.048		1.93	2.07		ug/L		107	70 - 130
alpha-BHC	<0.096		1.93	2.01		ug/L		104	70 - 130
alpha-Chlordane	<0.048		1.93	2.04		ug/L		106	70 - 130
Anthracene	<0.019		1.93	1.83		ug/L		95	70 - 130
Atrazine	<0.048		1.93	1.99		ug/L		103	70 - 130
Benz(a)anthracene	<0.048		1.93	1.82		ug/L		94	70 - 130
Benzo[a]pyrene	<0.019		1.93	1.83		ug/L		95	70 - 130
Benzo[b]fluoranthene	<0.019		1.93	2.11		ug/L		109	70 - 130
Benzo[g,h,i]perylene	<0.048		1.93	1.83		ug/L		95	70 - 130
Benzo[k]fluoranthene	<0.019		1.93	2.08		ug/L		108	70 - 130
beta-BHC	<0.096		1.93	2.04		ug/L		106	70 - 130
Bis(2-ethylhexyl) phthalate	<0.58		1.93	1.76		ug/L		91	70 - 130
Bromacil	<0.096		1.93	1.93		ug/L		100	70 - 130
Butachlor	<0.048		1.93	2.23		ug/L		115	70 - 130
Butylbenzylphthalate	<0.48		1.93	2.30		ug/L		119	70 - 130
Chlorobenzilate	<0.096		1.93	2.44		ug/L		126	70 - 130
Chloroneb	<0.096		1.93	2.08		ug/L		108	70 - 130
Chlorothalonil (Draconil, Bravo)	<0.096		1.93	2.01		ug/L		104	70 - 130
Chlorpyrifos	<0.048		1.93	2.12		ug/L		110	70 - 130
Chrysene	<0.019		1.93	2.04		ug/L		106	70 - 130
delta-BHC	<0.096		1.93	2.00		ug/L		104	70 - 130
Di(2-ethylhexyl)adipate	<0.58	B	1.93	1.71		ug/L		75	70 - 130
Dibenz(a,h)anthracene	<0.048		1.93	1.57		ug/L		81	70 - 130
Diclorvos (DDVP)	<0.048		1.93	2.10		ug/L		109	70 - 130
Dieldrin	<0.0096		1.93	1.96		ug/L		101	70 - 130
Diethylphthalate	<0.48		1.93	2.21		ug/L		114	70 - 130
Dimethylphthalate	<0.48		1.93	2.19		ug/L		114	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-122758-Q-1-A MS
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec	Limits
	Result	Qualifier	Added	Result	Qualifier					
Di-n-butyl phthalate	<0.96		3.86	4.45		ug/L		107		70 - 130
Di-n-octyl phthalate	<0.096		1.93	1.44		ug/L		74		70 - 130
Endosulfan I (Alpha)	<0.096		1.93	1.96		ug/L		101		70 - 130
Endosulfan II (Beta)	<0.096		1.93	2.02		ug/L		105		70 - 130
Endosulfan sulfate	<0.096		1.93	2.00		ug/L		103		70 - 130
Endrin	<0.0096		1.93	1.74		ug/L		90		70 - 130
Endrin aldehyde	<0.096		1.93	1.46		ug/L		76		60 - 130
EPTC	<0.096		1.93	2.06		ug/L		106		70 - 130
Fluoranthene	<0.096		1.93	2.12		ug/L		110		70 - 130
Fluorene	<0.048		1.93	2.09		ug/L		108		70 - 130
gamma-Chlordane	<0.048		1.93	1.98		ug/L		103		70 - 130
Heptachlor	<0.0096		1.93	1.93		ug/L		100		70 - 130
Heptachlor epoxide (isomer B)	<0.0096		1.93	1.99		ug/L		103		70 - 130
Hexachlorobenzene	<0.048		1.93	1.91		ug/L		99		70 - 130
Hexachlorocyclopentadiene	<0.048		1.93	1.96		ug/L		101		70 - 130
Indeno[1,2,3-cd]pyrene	<0.048		1.93	1.84		ug/L		95		70 - 130
Isophorone	<0.096		1.93	1.95		ug/L		100		70 - 130
Lindane	<0.0096		1.93	1.88		ug/L		97		70 - 130
Malathion	<0.096		1.93	2.23		ug/L		116		70 - 130
Methoxychlor	<0.048		1.93	2.27		ug/L		118		70 - 130
Metolachlor	<0.048		1.93	2.11		ug/L		109		70 - 130
Molinate	<0.096		1.93	2.14		ug/L		110		70 - 130
Naphthalene	<0.096		1.93	1.91		ug/L		99		70 - 130
Parathion	<0.096		1.93	2.16		ug/L		112		70 - 130
Pendimethalin (Penoxaline)	<0.096		1.93	2.06		ug/L		106		70 - 130
Phenanthrene	<0.038		1.93	1.91		ug/L		99		70 - 130
Propachlor	<0.048		1.93	2.20		ug/L		114		70 - 130
Pyrene	<0.048		1.93	2.07		ug/L		107		70 - 130
Simazine	<0.048		1.93	1.92		ug/L		100		70 - 130
Terbacil	<0.096		1.93	1.88		ug/L		97		70 - 130
Terbutylazine	<0.096		1.93	2.00		ug/L		104		70 - 130
Thiobencarb	<0.096		1.93	2.15		ug/L		111		70 - 130
trans-Nonachlor	<0.048		1.93	1.91		ug/L		99		70 - 130
Trifluralin	<0.096		1.93	1.98		ug/L		102		70 - 130
				MS	MS					
Surrogate				%Recovery	Qualifier					Limits
2-Nitro-m-xylene				97						70 - 130
Perylene-d12				91						70 - 130
Triphenylphosphate				105						70 - 130

Lab Sample ID: 380-121607-M-1-A DU
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Duplicate
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Sample	Sample	DU	DU	Unit	D	RPD	RPD	Limit
	Result	Qualifier	Result	Qualifier					
1-Methylnaphthalene	<0.097		<0.097		ug/L			NC	20
2,4'-DDD	<0.097		<0.097		ug/L			NC	20
2,4'-DDE	<0.097		<0.097		ug/L			NC	20

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-123125-1
 SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-121607-M-1-A DU
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Duplicate
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
2,4'-DDT	<0.097		<0.097		ug/L		NC	20
2,4-Dinitrotoluene	<0.097		<0.097		ug/L		NC	20
2,6-Dinitrotoluene	<0.097		<0.097		ug/L		NC	20
2-Methylnaphthalene	<0.097		<0.097		ug/L		NC	20
4,4'-DDD	<0.097		<0.097		ug/L		NC	20
4,4'-DDE	<0.097		<0.097		ug/L		NC	20
4,4'-DDT	<0.097		<0.097		ug/L		NC	20
Acenaphthene	<0.097		<0.097		ug/L		NC	20
Acenaphthylene	<0.097		<0.097		ug/L		NC	20
Acetochlor	<0.097		<0.097		ug/L		NC	20
Alachlor	<0.048		<0.049		ug/L		NC	20
alpha-BHC	<0.097		<0.097		ug/L		NC	20
alpha-Chlordane	<0.048		<0.049		ug/L		NC	20
Anthracene	<0.019		<0.019		ug/L		NC	20
Atrazine	<0.048		<0.049		ug/L		NC	20
Benz(a)anthracene	<0.048		<0.049		ug/L		NC	20
Benzo[a]pyrene	<0.019		<0.019		ug/L		NC	20
Benzo[b]fluoranthene	<0.019		<0.019		ug/L		NC	20
Benzo[g,h,i]perylene	<0.048		<0.049		ug/L		NC	20
Benzo[k]fluoranthene	<0.019		<0.019		ug/L		NC	20
beta-BHC	<0.097		<0.097		ug/L		NC	20
Bis(2-ethylhexyl) phthalate	<0.58		<0.58		ug/L		NC	20
Bromacil	<0.097		<0.097		ug/L		NC	20
Butachlor	<0.048		<0.049		ug/L		NC	20
Butylbenzylphthalate	<0.48		<0.49		ug/L		NC	20
Chlorobenzilate	<0.097		<0.097		ug/L		NC	20
Chloroneb	<0.097		<0.097		ug/L		NC	20
Chlorothalonil (Draconil, Bravo)	<0.097		<0.097		ug/L		NC	20
Chlorpyrifos	<0.048		<0.049		ug/L		NC	20
Chrysene	<0.019		<0.019		ug/L		NC	20
delta-BHC	<0.097		<0.097		ug/L		NC	20
Di(2-ethylhexyl)adipate	<0.58	B	<0.58	B	ug/L		NC	20
Dibenz(a,h)anthracene	<0.048		<0.049		ug/L		NC	20
Diclorvos (DDVP)	<0.048		<0.049		ug/L		NC	20
Dieldrin	<0.0097		<0.0097		ug/L		NC	20
Diethylphthalate	<0.48		<0.49		ug/L		NC	20
Dimethylphthalate	<0.48		<0.49		ug/L		NC	20
Di-n-butyl phthalate	<0.97		<0.97		ug/L		NC	20
Di-n-octyl phthalate	<0.097		<0.097		ug/L		NC	20
Endosulfan I (Alpha)	<0.097		<0.097		ug/L		NC	20
Endosulfan II (Beta)	<0.097		<0.097		ug/L		NC	20
Endosulfan sulfate	<0.097		<0.097		ug/L		NC	20
Endrin	<0.0097		<0.0097		ug/L		NC	20
Endrin aldehyde	<0.097		<0.097		ug/L		NC	20
EPTC	<0.097		<0.097		ug/L		NC	20
Fluoranthene	<0.097		<0.097		ug/L		NC	20
Fluorene	<0.048		<0.049		ug/L		NC	20
gamma-Chlordane	<0.048		<0.049		ug/L		NC	20
Heptachlor	<0.0097		<0.0097		ug/L		NC	20

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-121607-M-1-A DU
Matrix: Water
Analysis Batch: 120317

Client Sample ID: Duplicate
Prep Type: Total/NA
Prep Batch: 120047

Analyte	Sample	Sample	DU	DU	Unit	D	RPD	Limit
	Result	Qualifier	Result	Qualifier				
Heptachlor epoxide (isomer B)	<0.0097		<0.0097		ug/L		NC	20
Hexachlorobenzene	<0.048		<0.049		ug/L		NC	20
Hexachlorocyclopentadiene	<0.048		<0.049		ug/L		NC	20
Indeno[1,2,3-cd]pyrene	<0.048		<0.049		ug/L		NC	20
Isophorone	<0.097		<0.097		ug/L		NC	20
Lindane	<0.0097		<0.0097		ug/L		NC	20
Malathion	<0.097		<0.097		ug/L		NC	20
Methoxychlor	<0.048		<0.049		ug/L		NC	20
Metolachlor	<0.048		<0.049		ug/L		NC	20
Molinate	<0.097		<0.097		ug/L		NC	20
Naphthalene	<0.097		<0.097		ug/L		NC	20
Parathion	<0.097		<0.097		ug/L		NC	20
Pendimethalin (Penoxaline)	<0.097		<0.097		ug/L		NC	20
Phenanthrene	<0.039		<0.039		ug/L		NC	20
Propachlor	<0.048		<0.049		ug/L		NC	20
Pyrene	<0.048		<0.049		ug/L		NC	20
Simazine	<0.048		<0.049		ug/L		NC	20
Terbacil	<0.097		<0.097		ug/L		NC	20
Terbutylazine	<0.097		<0.097		ug/L		NC	20
Thiobencarb	<0.097		<0.097		ug/L		NC	20
Total Permethrin (mixed isomers)	<0.19		<0.19		ug/L		NC	20
trans-Nonachlor	<0.048		<0.049		ug/L		NC	20
Trifluralin	<0.097		<0.097		ug/L		NC	20

Surrogate	DU	DU	Limits
	%Recovery	Qualifier	
2-Nitro-m-xylene	97		70 - 130
Perylene-d12	80		70 - 130
Triphenylphosphate	95		70 - 130

Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 570-506497/1-A
Matrix: Water
Analysis Batch: 510403

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 506497

Tentatively Identified Compound	MB	MB	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
	Est. Result	Qualifier							
Tentatively Identified Compound	None		ug/L			N/A	11/22/24 13:13	12/05/24 20:13	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
2,4,6-Tribromophenol (Surr)	67		33 - 139	11/22/24 13:13	12/05/24 20:13	1
2-Fluorobiphenyl (Surr)	59		33 - 126	11/22/24 13:13	12/05/24 20:13	1
2-Fluorophenol (Surr)	42		12 - 120	11/22/24 13:13	12/05/24 20:13	1
Nitrobenzene-d5 (Surr)	64		36 - 120	11/22/24 13:13	12/05/24 20:13	1
Phenol-d6 (Surr)	24		10 - 120	11/22/24 13:13	12/05/24 20:13	1
p-Terphenyl-d14 (Surr)	79		47 - 131	11/22/24 13:13	12/05/24 20:13	1

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Lab Sample ID: MB 570-506497/1-A
Matrix: Water
Analysis Batch: 507989

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 506497

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
1-Methylnaphthalene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
2-Methylnaphthalene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Acenaphthene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Acenaphthylene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Anthracene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Benzo[a]anthracene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Benzo[a]pyrene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Benzo[b]fluoranthene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Benzo[g,h,i]perylene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Benzo[k]fluoranthene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Chrysene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Dibenz(a,h)anthracene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Fluoranthene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Fluorene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Naphthalene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Phenanthrene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1
Pyrene	<0.20		0.20	ug/L		11/22/24 13:13	11/27/24 03:09	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
2,4,6-Tribromophenol (Surr)	70		28 - 127	11/22/24 13:13	11/27/24 03:09	1
2-Fluorobiphenyl (Surr)	66		31 - 120	11/22/24 13:13	11/27/24 03:09	1
2-Fluorophenol (Surr)	49		17 - 120	11/22/24 13:13	11/27/24 03:09	1
Nitrobenzene-d5 (Surr)	75		27 - 120	11/22/24 13:13	11/27/24 03:09	1
Phenol-d6 (Surr)	27		10 - 120	11/22/24 13:13	11/27/24 03:09	1
p-Terphenyl-d14 (Surr)	79		45 - 120	11/22/24 13:13	11/27/24 03:09	1

Lab Sample ID: LCS 570-506497/2-A
Matrix: Water
Analysis Batch: 507989

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 506497

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec Limits
		Result	Qualifier				
1-Methylnaphthalene	20.0	15.3		ug/L		77	47 - 120
2-Methylnaphthalene	20.0	17.5		ug/L		87	43 - 120
Acenaphthene	20.0	16.7		ug/L		83	60 - 132
Acenaphthylene	20.0	16.4		ug/L		82	54 - 126
Anthracene	20.0	17.5		ug/L		88	43 - 120
Benzo[a]anthracene	20.0	17.2		ug/L		86	42 - 133
Benzo[a]pyrene	20.0	19.3		ug/L		96	32 - 148
Benzo[b]fluoranthene	20.0	18.7		ug/L		94	42 - 140
Benzo[g,h,i]perylene	20.0	16.0		ug/L		80	1 - 195
Benzo[k]fluoranthene	20.0	19.2		ug/L		96	25 - 146
Chrysene	20.0	16.1		ug/L		81	44 - 140
Dibenz(a,h)anthracene	20.0	17.1		ug/L		85	1 - 200
Fluoranthene	20.0	18.8		ug/L		94	43 - 121
Fluorene	20.0	16.8		ug/L		84	70 - 120
Indeno[1,2,3-cd]pyrene	20.0	17.2		ug/L		86	1 - 151
Naphthalene	20.0	14.9		ug/L		74	36 - 120

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: LCS 570-506497/2-A
Matrix: Water
Analysis Batch: 507989

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 506497

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Phenanthrene	20.0	16.3		ug/L		81	65 - 120
Pyrene	20.0	14.8		ug/L		74	70 - 120

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2,4,6-Tribromophenol (Surr)	81		28 - 127
2-Fluorobiphenyl (Surr)	80		31 - 120
2-Fluorophenol (Surr)	60		17 - 120
Nitrobenzene-d5 (Surr)	74		27 - 120
Phenol-d6 (Surr)	36		10 - 120
p-Terphenyl-d14 (Surr)	79		45 - 120

Lab Sample ID: LCSD 570-506497/3-A
Matrix: Water
Analysis Batch: 507989

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 506497

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene	20.0	13.8		ug/L		69	47 - 120	11	20
2-Methylnaphthalene	20.0	15.8		ug/L		79	43 - 120	10	20
Acenaphthene	20.0	15.1		ug/L		75	60 - 132	10	29
Acenaphthylene	20.0	14.7		ug/L		73	54 - 126	11	45
Anthracene	20.0	16.6		ug/L		83	43 - 120	5	40
Benzo[a]anthracene	20.0	16.9		ug/L		84	42 - 133	2	32
Benzo[a]pyrene	20.0	18.4		ug/L		92	32 - 148	5	43
Benzo[b]fluoranthene	20.0	18.2		ug/L		91	42 - 140	3	43
Benzo[g,h,i]perylene	20.0	15.3		ug/L		76	1 - 195	5	61
Benzo[k]fluoranthene	20.0	18.5		ug/L		92	25 - 146	4	38
Chrysene	20.0	15.9		ug/L		79	44 - 140	2	53
Dibenz(a,h)anthracene	20.0	16.2		ug/L		81	1 - 200	5	75
Fluoranthene	20.0	18.2		ug/L		91	43 - 121	4	40
Fluorene	20.0	16.2		ug/L		81	70 - 120	4	23
Indeno[1,2,3-cd]pyrene	20.0	17.0		ug/L		85	1 - 151	1	60
Naphthalene	20.0	12.8		ug/L		64	36 - 120	15	39
Phenanthrene	20.0	15.6		ug/L		78	65 - 120	4	24
Pyrene	20.0	14.8		ug/L		74	70 - 120	0	30

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
2,4,6-Tribromophenol (Surr)	76		28 - 127
2-Fluorobiphenyl (Surr)	70		31 - 120
2-Fluorophenol (Surr)	48		17 - 120
Nitrobenzene-d5 (Surr)	64		27 - 120
Phenol-d6 (Surr)	30		10 - 120
p-Terphenyl-d14 (Surr)	74		45 - 120

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: 380-123126-A-3-A MS

Matrix: Water

Analysis Batch: 507989

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 506497

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec	Limits
	Result	Qualifier	Added	Result	Qualifier					
1-Methylnaphthalene	<0.19		19.2	14.3		ug/L		74		36 - 120
2-Methylnaphthalene	<0.19		19.2	16.4		ug/L		85		32 - 124
Acenaphthene	<0.19		19.2	15.2		ug/L		79		47 - 145
Acenaphthylene	<0.19		19.2	14.7		ug/L		77		33 - 145
Anthracene	<0.19		19.2	16.3		ug/L		85		27 - 133
Benzo[a]anthracene	<0.19		19.2	16.0		ug/L		83		33 - 143
Benzo[a]pyrene	<0.19		19.2	17.3		ug/L		90		17 - 163
Benzo[b]fluoranthene	<0.19		19.2	17.3		ug/L		90		24 - 159
Benzo[g,h,i]perylene	<0.19		19.2	14.8		ug/L		77		1 - 219
Benzo[k]fluoranthene	<0.19		19.2	17.5		ug/L		91		11 - 162
Chrysene	<0.19		19.2	15.3		ug/L		80		17 - 168
Dibenz(a,h)anthracene	<0.19		19.2	15.9		ug/L		83		1 - 227
Fluoranthene	<0.19		19.2	17.4		ug/L		90		26 - 137
Fluorene	<0.19		19.2	15.8		ug/L		82		59 - 121
Indeno[1,2,3-cd]pyrene	<0.19		19.2	15.7		ug/L		82		1 - 171
Naphthalene	<0.19		19.2	13.3		ug/L		69		21 - 133
Phenanthrene	<0.19		19.2	15.1		ug/L		79		54 - 120
Pyrene	<0.19		19.2	14.2		ug/L		74		52 - 120

Surrogate	MS	MS	Limits
	%Recovery	Qualifier	
2,4,6-Tribromophenol (Surr)	75		28 - 127
2-Fluorobiphenyl (Surr)	75		31 - 120
2-Fluorophenol (Surr)	50		17 - 120
Nitrobenzene-d5 (Surr)	69		27 - 120
Phenol-d6 (Surr)	30		10 - 120
p-Terphenyl-d14 (Surr)	75		45 - 120

Lab Sample ID: 380-123126-A-3-B MSD

Matrix: Water

Analysis Batch: 507989

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 506497

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec	Limits	RPD	Limit
	Result	Qualifier	Added	Result	Qualifier							
1-Methylnaphthalene	<0.19		19.1	15.2		ug/L		80		36 - 120	6	30
2-Methylnaphthalene	<0.19		19.1	16.8		ug/L		88		32 - 124	3	30
Acenaphthene	<0.19		19.1	15.8		ug/L		83		47 - 145	4	48
Acenaphthylene	<0.19		19.1	15.6		ug/L		82		33 - 145	6	74
Anthracene	<0.19		19.1	16.6		ug/L		87		27 - 133	2	66
Benzo[a]anthracene	<0.19		19.1	16.3		ug/L		85		33 - 143	2	53
Benzo[a]pyrene	<0.19		19.1	17.7		ug/L		93		17 - 163	2	72
Benzo[b]fluoranthene	<0.19		19.1	17.3		ug/L		91		24 - 159	0	71
Benzo[g,h,i]perylene	<0.19		19.1	14.7		ug/L		77		1 - 219	1	97
Benzo[k]fluoranthene	<0.19		19.1	17.6		ug/L		92		11 - 162	1	63
Chrysene	<0.19		19.1	15.5		ug/L		81		17 - 168	1	87
Dibenz(a,h)anthracene	<0.19		19.1	15.9		ug/L		83		1 - 227	0	126
Fluoranthene	<0.19		19.1	17.8		ug/L		94		26 - 137	3	66
Fluorene	<0.19		19.1	16.3		ug/L		86		59 - 121	3	38
Indeno[1,2,3-cd]pyrene	<0.19		19.1	15.9		ug/L		84		1 - 171	2	99
Naphthalene	<0.19		19.1	14.2		ug/L		75		21 - 133	7	65

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

Lab Sample ID: 380-123126-A-3-B MSD

Client Sample ID: Matrix Spike Duplicate

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 507989

Prep Batch: 506497

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Phenanthrene	<0.19		19.1	15.5		ug/L		81	54 - 120	3	39
Pyrene	<0.19		19.1	14.4		ug/L		76	52 - 120	2	49

Surrogate	MSD %Recovery	MSD Qualifier	Limits
2,4,6-Tribromophenol (Surr)	79		28 - 127
2-Fluorobiphenyl (Surr)	79		31 - 120
2-Fluorophenol (Surr)	54		17 - 120
Nitrobenzene-d5 (Surr)	72		27 - 120
Phenol-d6 (Surr)	32		10 - 120
p-Terphenyl-d14 (Surr)	73		45 - 120

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: MB 570-508548/6

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 508548

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			11/29/24 11:53	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	85		38 - 134		11/29/24 11:53	1

Lab Sample ID: LCS 570-508548/4

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 508548

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	400	332		ug/L		83	78 - 120

Surrogate	LCS %Recovery	LCS Qualifier	Limits
4-Bromofluorobenzene (Surr)	93		38 - 134

Lab Sample ID: LCSD 570-508548/5

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 508548

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	400	330		ug/L		82	78 - 120	1	10

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
4-Bromofluorobenzene (Surr)	93		38 - 134

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Lab Sample ID: MRL 570-508548/3
Matrix: Water
Analysis Batch: 508548

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	10.0	12.2		ug/L		122	50 - 150
Surrogate		MRL %Recovery	MRL Qualifier				Limits
4-Bromofluorobenzene (Surr)		89					38 - 134

Lab Sample ID: 380-123126-C-3 MS
Matrix: Water
Analysis Batch: 508548

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	<10		400	374		ug/L		93	68 - 122
Surrogate		MS %Recovery		MS Qualifier					Limits
4-Bromofluorobenzene (Surr)		94							38 - 134

Lab Sample ID: 380-123126-C-3 MSD
Matrix: Water
Analysis Batch: 508548

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	355		ug/L		89	68 - 122	5	18
Surrogate		MSD %Recovery		MSD Qualifier					Limits		
4-Bromofluorobenzene (Surr)		93							38 - 134		

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Lab Sample ID: MB 570-506858/1-A
Matrix: Water
Analysis Batch: 508451

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 506858

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25	ug/L		11/23/24 11:38	11/27/24 21:26	1
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		11/23/24 11:38	11/27/24 21:26	1
C8-C18	<25		25	ug/L		11/23/24 11:38	11/27/24 21:26	1
Surrogate		MB %Recovery	MB Qualifier			Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)		87				11/23/24 11:38	11/27/24 21:26	1

Lab Sample ID: LCS 570-506858/2-A
Matrix: Water
Analysis Batch: 508451

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 506858

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
C10-C28	1600	1340		ug/L		84	56 - 127

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

Lab Sample ID: LCS 570-506858/2-A
Matrix: Water
Analysis Batch: 508451

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 506858

	LCS %Recovery	LCS Qualifier	Limits
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>	90		60 - 130

Lab Sample ID: LCSD 570-506858/3-A
Matrix: Water
Analysis Batch: 508451

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA
Prep Batch: 506858

	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	Limit
Analyte C10-C28	1600	1290		ug/L		81	56 - 127	3	23
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>									

Lab Sample ID: MRL 570-506858/4-A
Matrix: Water
Analysis Batch: 508451

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 506858

	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits	
Analyte C10-C28	0.0200	0.0201	J	mg/L		100	50 - 150	
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>								

Lab Sample ID: 380-123126-B-3-A MS
Matrix: Water
Analysis Batch: 508451

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 506858

	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Analyte C10-C28	<26		1630	1400		ug/L		86	70 - 130
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>									

Lab Sample ID: 380-123126-B-3-B MSD
Matrix: Water
Analysis Batch: 508451

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 506858

	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	Limit
Analyte C10-C28	<26		1650	1390		ug/L		84	70 - 130	1	20
<i>Surrogate</i> <i>n-Octacosane (Surr)</i>											

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

GC/MS Semi VOA

Prep Batch: 120047

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-123125-1	AIEA WELLS PUMPS 1&2 (260) P2 (331-203-TP	Total/NA	Drinking Water	525.2	
MB 380-120047/21-A	Method Blank	Total/NA	Water	525.2	
LCS 380-120047/23-A	Lab Control Sample	Total/NA	Water	525.2	
LCSD 380-120047/24-A	Lab Control Sample Dup	Total/NA	Water	525.2	
MRL 380-120047/22-A	Lab Control Sample	Total/NA	Water	525.2	
380-122758-Q-1-A MS	Matrix Spike	Total/NA	Water	525.2	
380-121607-M-1-A DU	Duplicate	Total/NA	Water	525.2	

Analysis Batch: 120317

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-123125-1	AIEA WELLS PUMPS 1&2 (260) P2 (331-203-TP	Total/NA	Drinking Water	525.2	120047
MB 380-120047/21-A	Method Blank	Total/NA	Water	525.2	120047
LCS 380-120047/23-A	Lab Control Sample	Total/NA	Water	525.2	120047
LCSD 380-120047/24-A	Lab Control Sample Dup	Total/NA	Water	525.2	120047
MRL 380-120047/22-A	Lab Control Sample	Total/NA	Water	525.2	120047
380-122758-Q-1-A MS	Matrix Spike	Total/NA	Water	525.2	120047
380-121607-M-1-A DU	Duplicate	Total/NA	Water	525.2	120047

Prep Batch: 506497

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-123125-1	AIEA WELLS PUMPS 1&2 (260) P2 (331-203-TP	Total/NA	Drinking Water	625.1	
MB 570-506497/1-A	Method Blank	Total/NA	Water	625.1	
LCS 570-506497/2-A	Lab Control Sample	Total/NA	Water	625.1	
LCSD 570-506497/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	
380-123126-A-3-A MS	Matrix Spike	Total/NA	Water	625.1	
380-123126-A-3-B MSD	Matrix Spike Duplicate	Total/NA	Water	625.1	

Analysis Batch: 507989

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 570-506497/1-A	Method Blank	Total/NA	Water	625.1 SIM	506497
LCS 570-506497/2-A	Lab Control Sample	Total/NA	Water	625.1 SIM	506497
LCSD 570-506497/3-A	Lab Control Sample Dup	Total/NA	Water	625.1 SIM	506497
380-123126-A-3-A MS	Matrix Spike	Total/NA	Water	625.1 SIM	506497
380-123126-A-3-B MSD	Matrix Spike Duplicate	Total/NA	Water	625.1 SIM	506497

Analysis Batch: 509860

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-123125-1	AIEA WELLS PUMPS 1&2 (260) P2 (331-203-TP	Total/NA	Drinking Water	625.1 SIM	506497

Analysis Batch: 510403

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-123125-1	AIEA WELLS PUMPS 1&2 (260) P2 (331-203-TP	Total/NA	Drinking Water	625.1	506497
MB 570-506497/1-A	Method Blank	Total/NA	Water	625.1	506497

GC VOA

Analysis Batch: 508548

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-123125-1	AIEA WELLS PUMPS 1&2 (260) P2 (331-203-TP	Total/NA	Drinking Water	8015B GRO LL	
380-123125-2	TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TF	Total/NA	Water	8015B GRO LL	
MB 570-508548/6	Method Blank	Total/NA	Water	8015B GRO LL	

QC Association Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-123125-1
 SDG: Weekly

GC VOA (Continued)

Analysis Batch: 508548 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
LCS 570-508548/4	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-508548/5	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-508548/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-123126-C-3 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-123126-C-3 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

GC Semi VOA

Prep Batch: 506858

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-123125-1	AIEA WELLS PUMPS 1&2 (260) P2 (331-203-TP	Total/NA	Drinking Water	3510C	
MB 570-506858/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-506858/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-506858/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
MRL 570-506858/4-A	Lab Control Sample	Total/NA	Water	3510C	
380-123126-B-3-A MS	Matrix Spike	Total/NA	Water	3510C	
380-123126-B-3-B MSD	Matrix Spike Duplicate	Total/NA	Water	3510C	

Analysis Batch: 508451

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-123125-1	AIEA WELLS PUMPS 1&2 (260) P2 (331-203-TP	Total/NA	Drinking Water	8015B	506858
MB 570-506858/1-A	Method Blank	Total/NA	Water	8015B	506858
LCS 570-506858/2-A	Lab Control Sample	Total/NA	Water	8015B	506858
LCSD 570-506858/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	506858
MRL 570-506858/4-A	Lab Control Sample	Total/NA	Water	8015B	506858
380-123126-B-3-A MS	Matrix Spike	Total/NA	Water	8015B	506858
380-123126-B-3-B MSD	Matrix Spike Duplicate	Total/NA	Water	8015B	506858

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260) P2
(331-203-TP400)**

Lab Sample ID: 380-123125-1

Date Collected: 11/18/24 10:26

Matrix: Drinking Water

Date Received: 11/20/24 09:31

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			120047	OTM3	EA POM	11/21/24 16:40
Total/NA	Analysis	525.2		1	120317	UPAC	EA POM	11/22/24 16:57
Total/NA	Prep	625.1			506497	H1SH	EET CAL 4	11/22/24 13:13
Total/NA	Analysis	625.1		1	510403	CG	EET CAL 4	12/05/24 20:35
Total/NA	Prep	625.1			506497	H1SH	EET CAL 4	11/22/24 13:13
Total/NA	Analysis	625.1 SIM		1	509860	PQS1	EET CAL 4	12/04/24 17:10
Total/NA	Analysis	8015B GRO LL		1	508548	A9VE	EET CAL 4	11/29/24 12:53
Total/NA	Prep	3510C			506858	H6FE	EET CAL 4	11/23/24 11:38
Total/NA	Analysis	8015B		1	508451	E5RH	EET CAL 4	11/27/24 23:14

**Client Sample ID: TB: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Lab Sample ID: 380-123125-2

Date Collected: 11/18/24 10:26

Matrix: Water

Date Received: 11/20/24 09:31

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015B GRO LL		1	508548	A9VE	EET CAL 4	11/29/24 12:27

Laboratory References:

EA POM = Eurofins Eaton Analytical Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100
EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Accreditation/Certification Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-123125-1
 SDG: Weekly

Laboratory: Eurofins Eaton Analytical Pomona

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-25

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Drinking Water	1-Methylnaphthalene
525.2	525.2	Drinking Water	2,4'-DDD
525.2	525.2	Drinking Water	2,4'-DDE
525.2	525.2	Drinking Water	2,4'-DDT
525.2	525.2	Drinking Water	2,4-Dinitrotoluene
525.2	525.2	Drinking Water	2,6-Dinitrotoluene
525.2	525.2	Drinking Water	2-Methylnaphthalene
525.2	525.2	Drinking Water	4,4'-DDD
525.2	525.2	Drinking Water	4,4'-DDE
525.2	525.2	Drinking Water	4,4' DDT
525.2	525.2	Drinking Water	Acetochlor
525.2	525.2	Drinking Water	alpha-BHC
525.2	525.2	Drinking Water	alpha-Chlordane
525.2	525.2	Drinking Water	beta-BHC
525.2	525.2	Drinking Water	Chlorobenzilate
525.2	525.2	Drinking Water	Chloroneb
525.2	525.2	Drinking Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Drinking Water	Chlorpyrifos
525.2	525.2	Drinking Water	delta-BHC
525.2	525.2	Drinking Water	Diclorvos (DDVP)
525.2	525.2	Drinking Water	Endosulfan I (Alpha)
525.2	525.2	Drinking Water	Endosulfan II (Beta)
525.2	525.2	Drinking Water	Endosulfan sulfate
525.2	525.2	Drinking Water	Endrin aldehyde
525.2	525.2	Drinking Water	EPTC
525.2	525.2	Drinking Water	gamma-Chlordane
525.2	525.2	Drinking Water	Isophorone
525.2	525.2	Drinking Water	Malathion
525.2	525.2	Drinking Water	Parathion
525.2	525.2	Drinking Water	Pendimethalin (Penoxaline)
525.2	525.2	Drinking Water	Terbacil
525.2	525.2	Drinking Water	Terbutylazine
525.2	525.2	Drinking Water	Total Permethrin (mixed isomers)
525.2	525.2	Drinking Water	trans-Nonachlor

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Arizona	State	AZ0830	11-16-25
Arkansas DEQ	State	88-0161	07-02-25
California	Los Angeles County Sanitation Districts	9257304	07-31-26
California	State	3082	07-31-26
Kansas	NELAP	E-10420	07-31-25
Nevada	State	CA00111	07-31-25

Eurofins Eaton Analytical Pomona

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Laboratory: Eurofins Calscience (Continued)

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Oregon	NELAP	4175	02-02-25
USDA	US Federal Programs	P330-22-00059	06-08-26
Washington	State	C916-18	10-11-25

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Method	Method Description	Protocol	Laboratory
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA POM
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET CAL 4
625.1 SIM	Semivolatile Organic Compounds GC/MS (SIM)	EPA	EET CAL 4
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
525.2	Extraction of Semivolatile Compounds	EPA	EA POM
625.1	Liquid-Liquid Extraction	40CFR136A	EET CAL 4

Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EA POM = Eurofins Eaton Analytical Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-123125-1
SDG: Weekly

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
380-123125-1	AIEA WELLS PUMPS 1&2 (260) P2 (331-203-TP400)	Drinking Water	11/18/24 10:26	11/20/24 09:31	HI0000331
380-123125-2	TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400)	Water	11/18/24 10:26	11/20/24 09:31	

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-123125-1

SDG Number: Weekly

Login Number: 123125

List Number: 1

Creator: Ngo, Theodore

List Source: Eurofins Eaton Analytical Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	



Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-123125-1

SDG Number: Weekly

Login Number: 123125

List Number: 2

Creator: Khana, Piyush

List Source: Eurofins Calscience

List Creation: 11/21/24 05:24 PM

Question	Answer	Comment
Radioactivity wasn't checked or is \leq background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	1.7
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <math><6\text{mm}</math> (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	