

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

# ANALYTICAL REPORT

## PREPARED FOR

Attn: Mr. Erwin Kawata  
City & County of Honolulu  
630 South Beretania Street  
Public Service Bldg. Room 310  
Honolulu, Hawaii 96843

Generated 1/7/2025 9:51:10 AM

## JOB DESCRIPTION

RED-HILL  
Weekly PFAS

## JOB NUMBER

380-128380-1

# Eurofins Eaton Analytical Pomona

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

## Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

## Authorization



Generated  
1/7/2025 9:51:10 AM

Authorized for release by  
Rachelle Arada, Project Manager  
[Rachelle.Arada@et.eurofinsus.com](mailto:Rachelle.Arada@et.eurofinsus.com)  
(626)386-1106



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	5
Detection Summary . . . . .	6
Client Sample Results . . . . .	7
Action Limit Summary . . . . .	11
Surrogate Summary . . . . .	12
Isotope Dilution Summary . . . . .	13
QC Sample Results . . . . .	14
QC Association Summary . . . . .	25
Lab Chronicle . . . . .	26
Certification Summary . . . . .	27
Method Summary . . . . .	28
Sample Summary . . . . .	29
Chain of Custody . . . . .	30
Receipt Checklists . . . . .	32

# Definitions/Glossary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Qualifiers

### LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: City & County of Honolulu  
Project: RED-HILL

Job ID: 380-128380-1

**Job ID: 380-128380-1**

**Eurofins Eaton Analytical Pomona**

## Job Narrative 380-128380-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

### Receipt

The samples were received on 1/3/2025 8:55 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.8°C.

### PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

# Detection Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Client Sample ID: Halawa Shaft Viewing Pool

Lab Sample ID: 380-128380-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanesulfonic acid (PFHxS)	3.4		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	3.4		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	3.6		2.0	ng/L	1		537.1	Total/NA
Perfluorohexanoic acid (PFHxA)	2.6		2.0	ng/L	1		537.1	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.7		2.0	ng/L	1		537.1	Total/NA

## Client Sample ID: FB: Halawa Shaft Viewing Viewing Pool

Lab Sample ID: 380-128380-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

**Client Sample ID: Halawa Shaft Viewing Pool**

**Lab Sample ID: 380-128380-1**

Date Collected: 01/02/25 10:00

Matrix: Water

Date Received: 01/03/25 08:55

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
<b>Perfluorohexanesulfonic acid (PFHxS)</b>	<b>3.4</b>		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
<b>Perfluorooctanesulfonic acid (PFOS)</b>	<b>3.4</b>		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:39	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	97		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C6 PFDA	104		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C5 PFHxA	106		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C4 PFHpA	109		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C8 PFOA	110		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C9 PFNA	107		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C7 PFUnA	104		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C2 PFDoA	108		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C4 PFBA	107		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C5 PFPeA	118		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C3 PFBS	107		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C3 PFHxS	111		50 - 200	01/04/25 14:51	01/06/25 09:39	1

Eurofins Eaton Analytical Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

**Client Sample ID: Halawa Shaft Viewing Pool**

**Lab Sample ID: 380-128380-1**

Date Collected: 01/02/25 10:00

Matrix: Water

Date Received: 01/03/25 08:55

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	111		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C2-4:2-FTS	134		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C2-6:2-FTS	115		50 - 200	01/04/25 14:51	01/06/25 09:39	1
13C2-8:2-FTS	103		50 - 200	01/04/25 14:51	01/06/25 09:39	1

**Method: EPA 537.1 - Perfluorinated Alkyl Acids (LC/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
<b>Perfluorooctanesulfonic acid (PFOS)</b>	<b>3.6</b>		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
<b>Perfluorohexanoic acid (PFHxA)</b>	<b>2.6</b>		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
<b>Perfluorohexanesulfonic acid (PFHxS)</b>	<b>3.7</b>		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 17:29	1
Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac		
d5-NEtFOSAA	99		70 - 130	01/03/25 16:31	01/04/25 17:29	1		
13C2 PFHxA	101		70 - 130	01/03/25 16:31	01/04/25 17:29	1		
13C2 PFDA	100		70 - 130	01/03/25 16:31	01/04/25 17:29	1		
13C3-GenX	105		70 - 130	01/03/25 16:31	01/04/25 17:29	1		

**Client Sample ID: FB: Halawa Shaft Viewing Viewing Pool**

**Lab Sample ID: 380-128380-2**

Date Collected: 01/02/25 10:00

Matrix: Water

Date Received: 01/03/25 08:55

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1

Eurofins Eaton Analytical Pomona



# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

**Client Sample ID: FB: Halawa Shaft Viewing Viewing Pool**

**Lab Sample ID: 380-128380-2**

Date Collected: 01/02/25 10:00

Matrix: Water

Date Received: 01/03/25 08:55

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		01/04/25 14:51	01/06/25 09:49	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	99		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C6 PFDA	101		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C5 PFHxA	110		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C4 PFHpA	110		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C8 PFOA	111		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C9 PFNA	107		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C7 PFUnA	101		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C2 PFDoA	100		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C4 PFBA	108		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C5 PFPeA	119		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C3 PFBS	110		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C3 PFHxS	113		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C8 PFOS	111		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C2-4:2-FTS	119		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C2-6:2-FTS	119		50 - 200	01/04/25 14:51	01/06/25 09:49	1
13C2-8:2-FTS	101		50 - 200	01/04/25 14:51	01/06/25 09:49	1

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

**Client Sample ID: FB: Halawa Shaft Viewing Viewing Pool**

**Lab Sample ID: 380-128380-2**

Date Collected: 01/02/25 10:00

Matrix: Water

Date Received: 01/03/25 08:55

**Method: EPA 537.1 - Perfluorinated Alkyl Acids (LC/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
N-methylperfluorooctanesulfonamideacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
N-ethylperfluorooctanesulfonamideacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		01/03/25 16:31	01/04/25 18:55	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>			<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
d5-NEtFOSAA	98		70 - 130			01/03/25 16:31	01/04/25 18:55	1
13C2 PFHxA	102		70 - 130			01/03/25 16:31	01/04/25 18:55	1
13C2 PFDA	97		70 - 130			01/03/25 16:31	01/04/25 18:55	1
13C3-GenX	102		70 - 130			01/03/25 16:31	01/04/25 18:55	1

# Action Limit Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

**Client Sample ID: Halawa Shaft Viewing Pool**

**Lab Sample ID: 380-128380-1**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.4		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	3.4		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	537.1	Total/NA
Perfluorooctanesulfonic acid (PFOS)	3.6		ng/L	4	2.0	537.1	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	537.1	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.7		ng/L	10	2.0	537.1	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	537.1	Total/NA

**Client Sample ID: FB: Halawa Shaft Viewing Viewing Pool**

**Lab Sample ID: 380-128380-2**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	537.1	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	537.1	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	537.1	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	537.1	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	537.1	Total/NA

# Surrogate Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-128380-1  
 SDG: Weekly PFAS

**Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS)**

**Matrix: Water**

**Prep Type: Total/NA**

**Percent Surrogate Recovery (Acceptance Limits)**

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-128380-1	Halawa Shaft Viewing Pool	99	101	100	105
380-128380-1 MS	Halawa Shaft Viewing Pool	99	107	101	105
380-128380-1 MSD	Halawa Shaft Viewing Pool	95	106	97	107
380-128380-2	FB: Halawa Shaft Viewing Viewing Pool	98	102	97	102
LCS 380-126363/12-A	Lab Control Sample	98	101	105	103
MBL 380-126363/10-A	Method Blank	97	101	100	104
MRL 380-126363/11-A	Lab Control Sample	105	103	101	105

**Surrogate Legend**

d5NEFOS = d5-NEtFOSAA  
 PFHxA = 13C2 PFHxA  
 PFDA = 13C2 PFDA  
 GenX = 13C3-GenX



# Isotope Dilution Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-128325-E-5-A MS	Matrix Spike	77	72	74	70	68	70	74	84
380-128325-F-5-A MSD	Matrix Spike Duplicate	78	76	76	74	72	73	80	89
380-128380-1	Halawa Shaft Viewing Pool	97	104	106	109	110	107	104	108
380-128380-2	FB: Halawa Shaft Viewing Viewing Pool	99	101	110	110	111	107	101	100
LCS 380-126394/17-A	Lab Control Sample	117	114	120	112	115	115	111	114
MBL 380-126394/15-A	Method Blank	101	109	116	114	110	113	107	111
MRL 380-126394/16-A	Lab Control Sample	102	106	117	113	111	110	106	112

### Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-128325-E-5-A MS	Matrix Spike	79	78	111	112	112	117	109	101
380-128325-F-5-A MSD	Matrix Spike Duplicate	76	77	110	111	111	121	106	107
380-128380-1	Halawa Shaft Viewing Pool	107	118	107	111	111	134	115	103
380-128380-2	FB: Halawa Shaft Viewing Viewing Pool	108	119	110	113	111	119	119	101
LCS 380-126394/17-A	Lab Control Sample	118	118	116	115	117	115	108	104
MBL 380-126394/15-A	Method Blank	114	112	110	113	113	119	104	98
MRL 380-126394/16-A	Lab Control Sample	110	112	111	112	113	125	103	98

#### Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDaA = 13C2 PFDaA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

**Lab Sample ID: MBL 380-126394/15-A**  
**Matrix: Water**  
**Analysis Batch: 126452**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 126394**

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.48		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<0.25		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		01/04/25 14:51	01/06/25 06:47	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	101		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C6 PFDA	109		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C5 PFHxA	116		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C4 PFHpA	114		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C8 PFOA	110		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C9 PFNA	113		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C7 PFUnA	107		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C2 PFDoA	111		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C4 PFBA	114		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C5 PFPeA	112		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C3 PFBS	110		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C3 PFHxS	113		50 - 200	01/04/25 14:51	01/06/25 06:47	1

Eurofins Eaton Analytical Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MBL 380-126394/15-A**  
**Matrix: Water**  
**Analysis Batch: 126452**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 126394**

<i>Isotope Dilution</i>	<i>MBL %Recovery</i>	<i>MBL Qualifier</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C8 PFOS	113		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C2-4:2-FTS	119		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C2-6:2-FTS	104		50 - 200	01/04/25 14:51	01/06/25 06:47	1
13C2-8:2-FTS	98		50 - 200	01/04/25 14:51	01/06/25 06:47	1

**Lab Sample ID: LCS 380-126394/17-A**  
**Matrix: Water**  
**Analysis Batch: 126452**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 126394**

<i>Analyte</i>	<i>Spike Added</i>	<i>LCS Result</i>	<i>LCS Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec Limits</i>
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	121	103		ng/L		86	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	121	105		ng/L		87	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	121	111		ng/L		92	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	121	109		ng/L		90	70 - 130
Perfluorobutanesulfonic acid (PFBS)	121	110		ng/L		91	70 - 130
Perfluorodecanoic acid (PFDA)	121	109		ng/L		90	70 - 130
Perfluorododecanoic acid (PFDoA)	121	105		ng/L		87	70 - 130
Perfluoroheptanoic acid (PFHpA)	121	116		ng/L		96	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	121	112		ng/L		93	70 - 130
Perfluorohexanoic acid (PFHxA)	121	107		ng/L		89	70 - 130
Perfluorononanoic acid (PFNA)	121	112		ng/L		93	70 - 130
Perfluorooctanesulfonic acid (PFOS)	121	110		ng/L		91	70 - 130
Perfluorooctanoic acid (PFOA)	121	110		ng/L		91	70 - 130
Perfluoroundecanoic acid (PFUnA)	121	112		ng/L		93	70 - 130
Perfluorobutanoic acid (PFBA)	121	108		ng/L		89	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	121	114		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	121	114		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	121	108		ng/L		90	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	121	104		ng/L		86	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	121	104		ng/L		86	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	121	108		ng/L		89	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	121	112		ng/L		93	70 - 130
Perfluoropentanoic acid (PFPeA)	121	108		ng/L		90	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	121	108		ng/L		90	70 - 130

Eurofins Eaton Analytical Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: LCS 380-126394/17-A**  
**Matrix: Water**  
**Analysis Batch: 126452**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 126394**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	121	109		ng/L		90	70 - 130
<b>LCS LCS</b>							
<b>Isotope Dilution</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				
13C3 HFPO-DA	117		50 - 200				
13C6 PFDA	114		50 - 200				
13C5 PFHxA	120		50 - 200				
13C4 PFHpA	112		50 - 200				
13C8 PFOA	115		50 - 200				
13C9 PFNA	115		50 - 200				
13C7 PFUnA	111		50 - 200				
13C2 PFDoA	114		50 - 200				
13C4 PFBA	118		50 - 200				
13C5 PFPeA	118		50 - 200				
13C3 PFBS	116		50 - 200				
13C3 PFHxS	115		50 - 200				
13C8 PFOS	117		50 - 200				
13C2-4:2-FTS	115		50 - 200				
13C2-6:2-FTS	108		50 - 200				
13C2-8:2-FTS	104		50 - 200				

**Lab Sample ID: MRL 380-126394/16-A**  
**Matrix: Water**  
**Analysis Batch: 126452**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 126394**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.79	J	ng/L		89	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	1.96	J	ng/L		98	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	1.99	J	ng/L		99	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	2.08	J	ng/L		104	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	1.96	J	ng/L		97	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	2.01	J	ng/L		100	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	1.96	J	ng/L		98	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	2.12	J	ng/L		106	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	2.03	J	ng/L		101	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	1.90	J	ng/L		95	50 - 150
Perfluorononanoic acid (PFNA)	2.01	2.12	J	ng/L		106	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	2.07	J	ng/L		103	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	1.92	J	ng/L		96	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	2.03	J	ng/L		101	50 - 150
Perfluorobutanoic acid (PFBA)	2.01	1.99	J	ng/L		99	50 - 150

Eurofins Eaton Analytical Pomona



# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MRL 380-126394/16-A**  
**Matrix: Water**  
**Analysis Batch: 126452**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 126394**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.01	2.11	J	ng/L		105	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.01	2.05	J	ng/L		102	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.01	2.30	J	ng/L		114	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.01	2.15	J	ng/L		107	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.01	1.88	J	ng/L		93	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.01	1.97	J	ng/L		98	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.01	1.95	J	ng/L		97	50 - 150
Perfluoropentanoic acid (PFPeA)	2.01	2.05	J	ng/L		102	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.01	1.94	J	ng/L		97	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.01	1.88	J	ng/L		94	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	102		50 - 200
13C6 PFDA	106		50 - 200
13C5 PFHxA	117		50 - 200
13C4 PFHpA	113		50 - 200
13C8 PFOA	111		50 - 200
13C9 PFNA	110		50 - 200
13C7 PFUnA	106		50 - 200
13C2 PFDoA	112		50 - 200
13C4 PFBA	110		50 - 200
13C5 PFPeA	112		50 - 200
13C3 PFBS	111		50 - 200
13C3 PFHxS	112		50 - 200
13C8 PFOS	113		50 - 200
13C2-4:2-FTS	125		50 - 200
13C2-6:2-FTS	103		50 - 200
13C2-8:2-FTS	98		50 - 200

**Lab Sample ID: 380-128325-E-5-A MS**  
**Matrix: Water**  
**Analysis Batch: 126452**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 126394**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	105		ng/L		88	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	107		ng/L		89	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		120	110		ng/L		91	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: 380-128325-E-5-A MS**  
**Matrix: Water**  
**Analysis Batch: 126452**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 126394**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		120	103		ng/L		86	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	<2.0		120	111		ng/L		92	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		120	108		ng/L		90	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		120	117		ng/L		97	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		120	117		ng/L		97	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		120	113		ng/L		93	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		120	110		ng/L		90	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		120	112		ng/L		93	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		120	113		ng/L		94	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		120	116		ng/L		95	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		120	115		ng/L		95	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		120	110		ng/L		91	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	117		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	119		ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	108		ng/L		90	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		120	123		ng/L		102	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		120	109		ng/L		91	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		120	104		ng/L		86	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		120	106		ng/L		88	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		120	111		ng/L		91	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	108		ng/L		89	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	109		ng/L		90	70 - 130

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	77		50 - 200
13C6 PFDA	72		50 - 200
13C5 PFHxA	74		50 - 200
13C4 PFHpA	70		50 - 200
13C8 PFOA	68		50 - 200
13C9 PFNA	70		50 - 200
13C7 PFUnA	74		50 - 200
13C2 PFDoA	84		50 - 200
13C4 PFBA	79		50 - 200
13C5 PFPeA	78		50 - 200
13C3 PFBS	111		50 - 200
13C3 PFHxS	112		50 - 200
13C8 PFOS	112		50 - 200

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: 380-128325-E-5-A MS**  
**Matrix: Water**  
**Analysis Batch: 126452**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 126394**

<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>MS MS Qualifier</i>	<i>Limits</i>
13C2-4:2-FTS	117		50 - 200
13C2-6:2-FTS	109		50 - 200
13C2-8:2-FTS	101		50 - 200

**Lab Sample ID: 380-128325-F-5-A MSD**  
**Matrix: Water**  
**Analysis Batch: 126452**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 126394**

<b>Analyte</b>	<b>Sample Result</b>	<b>Sample Qualifier</b>	<b>Spike Added</b>	<b>MSD Result</b>	<b>MSD Qualifier</b>	<b>Unit</b>	<b>D</b>	<b>%Rec</b>	<b>%Rec Limits</b>	<b>RPD</b>	<b>RPD Limit</b>
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		121	101		ng/L		84	70 - 130	4	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		121	106		ng/L		88	70 - 130	1	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		121	106		ng/L		88	70 - 130	4	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		121	101		ng/L		84	70 - 130	2	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		121	110		ng/L		90	70 - 130	1	30
Perfluorodecanoic acid (PFDA)	<2.0		121	113		ng/L		93	70 - 130	4	30
Perfluorododecanoic acid (PFDoA)	<2.0		121	112		ng/L		93	70 - 130	4	30
Perfluoroheptanoic acid (PFHpA)	<2.0		121	115		ng/L		95	70 - 130	2	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		121	111		ng/L		91	70 - 130	1	30
Perfluorohexanoic acid (PFHxA)	<2.0		121	108		ng/L		89	70 - 130	1	30
Perfluorononanoic acid (PFNA)	<2.0		121	113		ng/L		93	70 - 130	1	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		121	110		ng/L		91	70 - 130	3	30
Perfluorooctanoic acid (PFOA)	<2.0		121	113		ng/L		93	70 - 130	2	30
Perfluoroundecanoic acid (PFUnA)	<2.0		121	115		ng/L		96	70 - 130	0	30
Perfluorobutanoic acid (PFBA)	<2.0		121	113		ng/L		94	70 - 130	3	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		121	107		ng/L		89	70 - 130	9	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		121	114		ng/L		94	70 - 130	4	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		121	116		ng/L		96	70 - 130	7	30
Nonfluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		121	112		ng/L		93	70 - 130	9	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		121	104		ng/L		86	70 - 130	5	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		121	109		ng/L		90	70 - 130	4	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		121	108		ng/L		89	70 - 130	2	30
Perfluoropentanoic acid (PFPeA)	<2.0		121	113		ng/L		93	70 - 130	2	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		121	108		ng/L		90	70 - 130	0	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		121	108		ng/L		89	70 - 130	1	30

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	78		50 - 200
13C6 PFDA	76		50 - 200
13C5 PFHxA	76		50 - 200
13C4 PFHpA	74		50 - 200
13C8 PFOA	72		50 - 200
13C9 PFNA	73		50 - 200
13C7 PFUnA	80		50 - 200
13C2 PFDoA	89		50 - 200
13C4 PFBA	76		50 - 200
13C5 PFPeA	77		50 - 200
13C3 PFBS	110		50 - 200
13C3 PFHxS	111		50 - 200
13C8 PFOS	111		50 - 200
13C2-4:2-FTS	121		50 - 200
13C2-6:2-FTS	106		50 - 200
13C2-8:2-FTS	107		50 - 200

## Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS)

**Lab Sample ID: MBL 380-126363/10-A**  
**Matrix: Water**  
**Analysis Batch: 126396**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 126363**

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Perfluorotridecanoic acid (PFTrDA)	<0.36		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		01/03/25 16:31	01/04/25 16:57	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	97		70 - 130			01/03/25 16:31	01/04/25 16:57	1
13C2 PFHxA	101		70 - 130			01/03/25 16:31	01/04/25 16:57	1
13C2 PFDA	100		70 - 130			01/03/25 16:31	01/04/25 16:57	1

Eurofins Eaton Analytical Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS) (Continued)

**Lab Sample ID: MBL 380-126363/10-A**  
**Matrix: Water**  
**Analysis Batch: 126396**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 126363**

<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3-GenX	104		70 - 130	01/03/25 16:31	01/04/25 16:57	1

**Lab Sample ID: LCS 380-126363/12-A**  
**Matrix: Water**  
**Analysis Batch: 126396**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 126363**

<i>Analyte</i>	<i>Spike Added</i>	<i>LCS Result</i>	<i>LCS Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>Limits</i>
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	25.1	24.5		ng/L		98	70 - 130
Perfluorooctanesulfonic acid (PFOS)	25.1	25.4		ng/L		101	70 - 130
Perfluoroundecanoic acid (PFUnA)	25.1	25.0		ng/L		100	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	25.1	24.7		ng/L		99	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	25.1	23.8		ng/L		95	70 - 130
Perfluorohexanoic acid (PFHxA)	25.1	24.2		ng/L		97	70 - 130
Perfluorododecanoic acid (PFDoA)	25.1	24.6		ng/L		98	70 - 130
Perfluorooctanoic acid (PFOA)	25.1	26.2		ng/L		104	70 - 130
Perfluorodecanoic acid (PFDA)	25.1	25.0		ng/L		100	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	25.1	25.4		ng/L		101	70 - 130
Perfluorobutanesulfonic acid (PFBS)	25.1	21.3		ng/L		85	70 - 130
Perfluoroheptanoic acid (PFHpA)	25.1	26.1		ng/L		104	70 - 130
Perfluorononanoic acid (PFNA)	25.1	25.2		ng/L		101	70 - 130
Perfluorotetradecanoic acid (PFTA)	25.1	23.2		ng/L		93	70 - 130
Perfluorotridecanoic acid (PFTrDA)	25.1	24.2		ng/L		97	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	25.1	25.5		ng/L		102	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	25.1	24.2		ng/L		97	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	25.1	25.6		ng/L		102	70 - 130

<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>
d5-NEtFOSAA	98		70 - 130
13C2 PFHxA	101		70 - 130
13C2 PFDA	105		70 - 130
13C3-GenX	103		70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS) (Continued)

**Lab Sample ID: MRL 380-126363/11-A**  
**Matrix: Water**  
**Analysis Batch: 126396**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 126363**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	2.02	J	ng/L		101	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	2.09	J	ng/L		104	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	1.96	J	ng/L		98	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.00	2.01	J	ng/L		100	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.00	2.10	J	ng/L		105	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	2.05	J	ng/L		102	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	1.91	J	ng/L		95	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	2.07	J	ng/L		103	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.03	J	ng/L		101	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	1.99	J	ng/L		99	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	1.92	J	ng/L		96	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	2.11	J	ng/L		105	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.04	J	ng/L		102	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.00	1.83	J	ng/L		92	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.00	1.83	J	ng/L		91	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	1.94	J	ng/L		97	50 - 150
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	1.78	J	ng/L		89	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	2.03	J	ng/L		101	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	105		70 - 130
13C2 PFHxA	103		70 - 130
13C2 PFDA	101		70 - 130
13C3-GenX	105		70 - 130

**Lab Sample ID: 380-128380-1 MS**  
**Matrix: Water**  
**Analysis Batch: 126396**

**Client Sample ID: Halawa Shaft Viewing Pool**  
**Prep Type: Total/NA**  
**Prep Batch: 126363**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		25.1	25.5		ng/L		101	70 - 130
Perfluorooctanesulfonic acid (PFOS)	3.6		25.1	28.4		ng/L		99	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		25.1	24.3		ng/L		97	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		25.1	24.3		ng/L		97	70 - 130

Eurofins Eaton Analytical Pomona



# QC Sample Results

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-128380-1  
 SDG: Weekly PFAS

## Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS) (Continued)

Lab Sample ID: 380-128380-1 MSD

Client Sample ID: Halawa Shaft Viewing Pool

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 126396

Prep Batch: 126363

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorohexanesulfonic acid (PFHxS)	3.7		25.1	28.9		ng/L		100	70 - 130	4	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		25.1	25.5		ng/L		100	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0		25.1	26.7		ng/L		103	70 - 130	2	30
Perfluorononanoic acid (PFNA)	<2.0		25.1	25.5		ng/L		102	70 - 130	3	30
Perfluorotetradecanoic acid (PFTA)	<2.0		25.1	23.8		ng/L		95	70 - 130	5	30
Perfluorotridecanoic acid (PFTTrDA)	<2.0		25.1	24.5		ng/L		98	70 - 130	4	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		25.1	25.8		ng/L		103	70 - 130	4	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		25.1	24.6		ng/L		98	70 - 130	6	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		25.1	26.0		ng/L		104	70 - 130	4	30
<b>Surrogate</b>											
	<b>MSD %Recovery</b>	<b>MSD Qualifier</b>									<b>Limits</b>
d5-NEtFOSAA	95										70 - 130
13C2 PFHxA	106										70 - 130
13C2 PFDA	97										70 - 130
13C3-GenX	107										70 - 130



# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## LCMS

### Prep Batch: 126363

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-128380-1	Halawa Shaft Viewing Pool	Total/NA	Water	537.1 DW	
380-128380-2	FB: Halawa Shaft Viewing Viewing Pool	Total/NA	Water	537.1 DW	
MBL 380-126363/10-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-126363/12-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-126363/11-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-128380-1 MS	Halawa Shaft Viewing Pool	Total/NA	Water	537.1 DW	
380-128380-1 MSD	Halawa Shaft Viewing Pool	Total/NA	Water	537.1 DW	

### Prep Batch: 126394

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-128380-1	Halawa Shaft Viewing Pool	Total/NA	Water	533	
380-128380-2	FB: Halawa Shaft Viewing Viewing Pool	Total/NA	Water	533	
MBL 380-126394/15-A	Method Blank	Total/NA	Water	533	
LCS 380-126394/17-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-126394/16-A	Lab Control Sample	Total/NA	Water	533	
380-128325-E-5-A MS	Matrix Spike	Total/NA	Water	533	
380-128325-F-5-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

### Analysis Batch: 126396

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-128380-1	Halawa Shaft Viewing Pool	Total/NA	Water	537.1	126363
380-128380-2	FB: Halawa Shaft Viewing Viewing Pool	Total/NA	Water	537.1	126363
MBL 380-126363/10-A	Method Blank	Total/NA	Water	537.1	126363
LCS 380-126363/12-A	Lab Control Sample	Total/NA	Water	537.1	126363
MRL 380-126363/11-A	Lab Control Sample	Total/NA	Water	537.1	126363
380-128380-1 MS	Halawa Shaft Viewing Pool	Total/NA	Water	537.1	126363
380-128380-1 MSD	Halawa Shaft Viewing Pool	Total/NA	Water	537.1	126363

### Analysis Batch: 126452

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-128380-1	Halawa Shaft Viewing Pool	Total/NA	Water	533	126394
380-128380-2	FB: Halawa Shaft Viewing Viewing Pool	Total/NA	Water	533	126394
MBL 380-126394/15-A	Method Blank	Total/NA	Water	533	126394
LCS 380-126394/17-A	Lab Control Sample	Total/NA	Water	533	126394
MRL 380-126394/16-A	Lab Control Sample	Total/NA	Water	533	126394
380-128325-E-5-A MS	Matrix Spike	Total/NA	Water	533	126394
380-128325-F-5-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	126394

# Lab Chronicle

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-128380-1  
 SDG: Weekly PFAS

**Client Sample ID: Halawa Shaft Viewing Pool**

**Lab Sample ID: 380-128380-1**

Date Collected: 01/02/25 10:00

Matrix: Water

Date Received: 01/03/25 08:55

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			126394	HM3M	EA POM	01/04/25 14:51
Total/NA	Analysis	533		1	126452	SZ9R	EA POM	01/06/25 09:39
Total/NA	Prep	537.1 DW			126363	E9PK	EA POM	01/03/25 16:31
Total/NA	Analysis	537.1		1	126396	M7ML	EA POM	01/04/25 17:29

**Client Sample ID: FB: Halawa Shaft Viewing Viewing Pool**

**Lab Sample ID: 380-128380-2**

Date Collected: 01/02/25 10:00

Matrix: Water

Date Received: 01/03/25 08:55

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			126394	HM3M	EA POM	01/04/25 14:51
Total/NA	Analysis	533		1	126452	SZ9R	EA POM	01/06/25 09:49
Total/NA	Prep	537.1 DW			126363	E9PK	EA POM	01/03/25 16:31
Total/NA	Analysis	537.1		1	126396	M7ML	EA POM	01/04/25 18:55

**Laboratory References:**

EA POM = Eurofins Eaton Analytical Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

# Accreditation/Certification Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

## Laboratory: Eurofins Eaton Analytical Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-25

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

# Method Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-128380-1  
SDG: Weekly PFAS

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
537.1	Perfluorinated Alkyl Acids (LC/MS)	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

EA POM = Eurofins Eaton Analytical Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



# Sample Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL


Job ID: 380-128380-1  
SDG: Weekly PFAS

---

<u>Lab Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Collected</u>	<u>Received</u>
380-128380-1	Halawa Shaft Viewing Pool	Water	01/02/25 10:00	01/03/25 08:55
380-128380-2	FB: Halawa Shaft Viewing Viewing Pool	Water	01/02/25 10:00	01/03/25 08:55

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

**Chain of Custody Record**

<b>Client Information</b>	Sampler: Ryan Greer Phone: 808-748-5840 PWSID:	Lab PM: Arada, Rachelle E-Mail: Rachelle.Arada@eurofins.com State of Origin: HI	COC No: 380-28005-2757 1 Page: Page 1 of 1 Job #:	
Address: 630 South Beretania Street Chemistry Lab City: Honolulu State Zip: HI, 96843 Phone: 808-748-5091 (Tel) Email: RFENSTEMACHER@hbws.org	Due Date Requested TAT Requested (days): Compliance Project: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No PO #: C20525101 exp 05312023 WO #:	Analysis Requested Perform MS/MSD (Yes or No) <input checked="" type="checkbox"/> Field Filtered Sample (Yes or No) <input checked="" type="checkbox"/> 626.1_626.1_SIM 8015B_GRO_LL (MOD) GRO 8015B_DRO_LL_CS - HNL Ranges C10-C24/C24-C36/C8-C18 626.2_PREC - (MOD) 626plus Plus TICs 637.1_DW_PREC - 637.1 Full List 633 - All Analytes	Preservation Codes R - NaThioSO4 RA - NaThioHCl Q - Na2SO3 QA - Na2SO3/HCl Y - Trizma I - NH4 Acetate Other:	Total Number of Containers: <input checked="" type="checkbox"/> Special Instructions/Note:
Project Name: RED-HILL/HBWS Sites Event Desc: RUSH Weekly Red Hill Site: Hawaii	Sample Date: 1/2/25 Sample Time: 1000 G Matrix (Water, Sewage, Groundwater, BT-Tissue, Air)	Sample Type (C=Comp, G=grab) Preservation Code:	R RA Q QA Y I 3 3 1 1	380-128380 COC 
Possible Hazard Identification <input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological	Sample Identification Halawa Shaft Viewing Pool FB Halawa Shaft Viewing Pool	Sample Date: 1/2/25 Sample Time: 1000 G Matrix: Water	Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months	Special Instructions/Note:
Empty Kit Relinquished by:	Date/Time: 1/2/25 1300 Date/Time:	Company: HBWS Company:	Method of Shipment:	Date/Time: 1/3/25 8053 Date/Time:
Relinquished by:	Date/Time:	Company:	Relinquished by:	Date/Time:
Relinquished by:	Date/Time:	Company:	Relinquished by:	Date/Time:
Custody Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Custody Seal No.	Cooler Temperature(s) °C and Other Remarks:	Cooler Temperature(s) °C and Other Remarks: 41.8°C YB Faw = 41.8°C GEL	Ver 04/02/2024



ORIGIN ID HIKA (808) 748-5840  
BWS CHEMLAB  
HONOLULU BOARD OF WATER SUPPLY  
630 S. BERETANIA ST  
CHEMICAL LABORATORY  
HONOLULU, HI 96843  
UNITED STATES US

SHIP DATE: 02JAN25  
ACTWGT 62.00 LB  
CAD: 258050552/INET4635  
DIMS 18x16x30 IN  
BILL RECIPIENT

TO EUROFINS RECEIVING DEPARTMENT  
EUROFINS DRINKING WATER TESTING  
941 CORPORATE CENTER DR

58CJ5/49B9/C8C4

POMONA CA 91768

REF: (626) 386-1100

PO: INV: DEPT:



FRI - 03 JAN 12:00P  
PRIORITY OVERNIGHT

TRK# 7711 6661 2101

WM ONTA 91768  
CA-US ONT



After printing this label  
CONSIGNEE COPY - PLEASE PLACE IN FRONT OF POUCH  
1 Fold the printed page along the horizontal line  
2 Place label in shipping pouch and affix it to your shipment

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our Service Guide. Written claims must be filed within strict time limits, see current FedEx Service Guide

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

# Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-128380-1  
SDG Number: Weekly PFAS

**Login Number: 128380**

**List Source: Eurofins Eaton Analytical Pomona**

**List Number: 1**

**Creator: Sanchez Velasquez, Gustavo**

Question	Answer	Comment
The coolers custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

