

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 308
Honolulu, Hawaii 96843

Generated 3/5/2023 3:30:31 PM

JOB DESCRIPTION

RED-HILL
RUSH Weekly Red Hill

JOB NUMBER

380-34727-1

Eurofins Drinking Water Testing Pomona

Job Notes

Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis.

Following the cover page are State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.

Test results relate only to the sample(s) tested.

Test results apply to the sample(s) as received, unless otherwise noted in the comments report (ISO/IEC 17025:2017).

This report shall not be reproduced except in full, without the written approval of the laboratory.

This report includes ISO/IEC 17025 and non-ISO 17025 accredited methods.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Generated
3/5/2023 3:30:31 PM

Authorized for release by
Rachelle Arada, Manager of Project Management
Rachelle.Arada@et.eurofinsus.com
(626)386-1106

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	6
Detection Summary	8
Client Sample Results	9
Action Limit Summary	19
Surrogate Summary	21
QC Sample Results	27
QC Association Summary	83
Lab Chronicle	89
Certification Summary	91
Method Summary	94
Sample Summary	95
Subcontract Data	96
Chain of Custody	171
Receipt Checklists	178

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
*-	LCS and/or LCSD is outside acceptance limits, low biased.
*+	LCS and/or LCSD is outside acceptance limits, high biased.
*1	LCS/LCSD RPD exceeds control limits.
^3-	Reporting Limit Check Standard is outside acceptance limits, low biased.
B	Analyte was found in the associated method blank.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

GC/MS VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

GC/MS Semi VOA

Qualifier	Qualifier Description
^3+	Reporting Limit Check Standard is outside acceptance limits, high biased
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

GC Semi VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

HPLC/IC

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

General Chemistry

Qualifier	Qualifier Description
^2	Calibration Blank (ICB and/or CCB) is outside acceptance limits.
B	Analyte was found in the associated method blank.
F1	MS and/or MSD recovery exceeds control limits.
HF	Field parameter with a holding time of 15 minutes. Test performed by laboratory at client's request.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Subcontract

Qualifier	Qualifier Description
U	This analyte was not detected.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Glossary (Continued)

Abbreviation	These commonly used abbreviations may or may not be present in this report.
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Job ID: 380-34727-1

Laboratory: Eurofins Drinking Water Testing Pomona

Narrative

Job Narrative
380-34727-1

Comments

No additional comments.

Receipt

The samples were received on 1/18/2023 10:00 AM. Unless otherwise noted below, the samples arrived in good condition, and where required, properly preserved and on ice. The temperatures of the 3 coolers at receipt time were 1.2° C, 1.4° C and 2.0° C

Receipt Exceptions

The following samples were received with ice present in the containers. The samples and containers appeared to be intact. AIE WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-1) and TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-2). 1 of 6 voa vials for 504.1 has ice formation.

The following samples were received with ice present in the containers. The samples and containers appeared to be intact. AIE WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-1) and TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-2). Ice present in plastic 500ml bottle for metals. Client was advised to resample.

The following samples were received with ice present in the containers. The samples and containers appeared to be intact. AIE WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-1) and TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-2). Ice present in plastic 500ml unpreserved bottle for TDS. Client was advised to resample.

One or more containers for the following samples were received broken or leaking: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-1) and TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-2). 1 of 3 525.2 bottles received broken.

The following samples were received with ice present in the containers. The samples and containers appeared to be intact. AIE WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-1) and TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-2). 1 of 2 525.2 amber glass 1L bottle has ice present.

The following samples were received with ice present in the containers. The samples and containers appeared to be intact. AIE WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-1) and TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-2). 1 of 2 plastic 125 bottles for anions has ice present.

The following samples were received with ice present in the containers. The samples and containers appeared to be intact. AIE WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-1) and TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-2). 1 of 2 amber glass bottles for 8015 jet fuel has ice formation.

Received 2 of 6 vials for 524.2 for trip blanks. TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-2)

Received 2 of 3 vials for 504 for trip blanks. TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-2)

GC/MS VOA

Method 524.2: The continuing calibration verification (CCV) associated with batch 380-30695 recovered above the upper control limit for 1,1,1-Trichloroethane, 1,2,4-Trimethylbenzene, 1,3,5-Trimethylbenzene, Bromobenzene, Bromodichloromethane, Bromoethane, Carbon disulfide, Carbon tetrachloride, Isopropylbenzene, m,p-Xylenes, m-Dichlorobenzene (1,3-DCB), N-Propylbenzene, o-Chlorotoluene, p-Chlorotoluene, p-Dichlorobenzene (1,4-DCB), p-Isopropyltoluene, sec-Butylbenzene, tert-Butylbenzene and Trichlorofluoromethane (Freon 11). The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported.

Method 524.2: The laboratory control sample (LCS) for analytical batch 380-30695 recovered outside control limits for the following analytes:

Case Narrative

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Job ID: 380-34727-1 (Continued)

Laboratory: Eurofins Drinking Water Testing Pomona (Continued)

analytes: 1,2,4-Trimethylbenzene, 1,3,5-Trimethylbenzene, Bromoethane, Carbon disulfide, Isopropylbenzene, m-Dichlorobenzene (1,3-DCB), o-Chlorotoluene, p-Dichlorobenzene (1,4-DCB) and tert-Butylbenzene. These analytes were biased high in the LCS and were not detected in the associated samples; therefore, the data have been reported.

Method 524.2: The laboratory control sample duplicate (LCSD) for analytical batch 380-30695 recovered outside control limits for the following analytes: 1,2,4-Trimethylbenzene, 1,3,5-Trimethylbenzene, Bromobenzene, Bromoethane, Carbon disulfide, Isopropylbenzene, m-Dichlorobenzene (1,3-DCB), o-Chlorotoluene, p-Dichlorobenzene (1,4-DCB), p-Isopropyltoluene, sec-Butylbenzene and tert-Butylbenzene. These analytes were biased high in the LCSD and were not detected in the associate samples; therefore, the data have been reported.

Method 524.2: The method blank for analytical batch 380-30695 contained 1,2,3-Trichlorobenzene above the reporting limit (RL). None of the samples associated with this method blank contained the target compound; therefore, re-extraction and/or re-analysis of samples were not performed.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

GC/MS Semi VOA

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

HPLC/IC

Method 300.0: The following sample was diluted due to the nature of the sample matrix: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-1). Elevated reporting limits (RLs) are provided.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

GC Semi VOA

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Metals

Method 200.8: The continuing calibration blank (CCB) for analytical batch 380-31025 contained Silver above the reporting limit (RL). All reported samples associated with this CCB were either ND for this analyte or contained this analyte at a concentration greater than 10X the value found in the CCB; therefore, re-analysis of samples was not performed.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

General Chemistry

Method SM 2320B: The matrix spike / matrix spike duplicate (MS/MSD) recoveries for analytical batch 380-30308 were outside control limits for one or more analytes, see QC Sample Results for detail. Sample matrix interference and/or non-homogeneity a suspected because the associated laboratory control sample (LCS) recovery is within acceptance limits.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

Subcontract non-Sister

See attached subcontract report.

Organic Prep

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Subcontract Work

Methods 8015 Ethanol, 8015 Gas (Purgeable) LL (EAL), 8015 LL DRO/MRO/JP5/JP8: These methods were subcontracted to EMAX Laboratories Inc. The subcontract laboratory certifications are different from that of the facility issuing the final report.

Method 625 Acid/Base/PAH + TICs: This method was subcontracted to Physis Environmental Laboratories. The subcontract laboratory certification is different from that of the facility issuing the final report.

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Lab Sample ID: 380-34727-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Dieldrin	0.010		0.0020	ug/L	1	505		Total/NA
Bromide	330		5.0	ug/L	1	300.0		Total/NA
Chloride	39		1.0	mg/L	2	300.0		Total/NA
Nitrate as N	0.31		0.10	mg/L	2	300.0		Total/NA
Nitrate Nitrite as N	0.31		0.10	mg/L	2	300.0		Total/NA
Sulfate	5.6		0.50	mg/L	2	300.0		Total/NA
Akalinity	220		2.0	mg/L	1	SM 2320B		Total/NA
Bicarbonate Alkalinity as CaCO3	220	^2	2.0	mg/L	1	SM 2320B		Total/NA
Specific Conductance	920	^2	2.0	umhos/cm	1	SM 2510B		Total/NA
pH	8.0	HF		SU	1	SM 4500 H+ B		Total/NA

**Client Sample ID: TB: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Lab Sample ID: 380-34727-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Drinking Water Testing Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-1

Matrix: Drinking Water

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS SIM)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Tertiary Butyl Alcohol (TBA)	ND		2.0	ug/L			01/20/23 18:10	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
Toluene-d8 (Surr)	98		70 - 130				01/20/23 18:10	1
4-Bromofluorobenzene (Surr)	102		70 - 130				01/20/23 18:10	1
1,2-Dichloroethane-d4 (Surr)	99		70 - 130				01/20/23 18:10	1

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	ug/L			01/26/23 07:21	1
1,1,1-Trichloroethane	ND		0.50	ug/L			01/26/23 07:21	1
1,1,2,2-Tetrachloroethane	ND		0.50	ug/L			01/26/23 07:21	1
1,1,2-Trichloroethane	ND		0.50	ug/L			01/26/23 07:21	1
1,1-Dichlorethylene	ND		0.50	ug/L			01/26/23 07:21	1
1,1-Dichloroethane	ND		0.50	ug/L			01/26/23 07:21	1
1,1-Dichloropropene	ND		0.50	ug/L			01/26/23 07:21	1
1,2,3-Trichlorobenzene	ND B		0.50	ug/L			01/26/23 07:21	1
1,2,3-Trichloropropane	ND		0.50	ug/L			01/26/23 07:21	1
1,2,4-Trichlorobenzene	ND		0.50	ug/L			01/26/23 07:21	1
1,2,4-Trimethyl benzene	ND *+		0.50	ug/L			01/26/23 07:21	1
1,2-Dichloroethane	ND		0.50	ug/L			01/26/23 07:21	1
1,2-Dichloropropane	ND		0.50	ug/L			01/26/23 07:21	1
1,3,5-Trimethyl benzene	ND *+		0.50	ug/L			01/26/23 07:21	1
1,3-Dichloropropane	ND		0.50	ug/L			01/26/23 07:21	1
1,3-Dichloropropene, Total	ND		0.50	ug/L			01/26/23 07:21	1
2,2-Dichloropropane	ND		0.50	ug/L			01/26/23 07:21	1
2-Butanone (MEK)	ND		5.0	ug/L			01/30/23 17:31	1
4-Methyl-2-pentanone (MIBK)	ND		5.0	ug/L			01/30/23 17:31	1
Acetone	ND		500	ug/L			01/30/23 17:31	1
Benzene	ND		0.50	ug/L			01/26/23 07:21	1
Bromobenzene	ND *+		0.50	ug/L			01/26/23 07:21	1
Bromoform	ND		0.50	ug/L			01/26/23 07:21	1
Bromomethane (Methyl Bromide)	ND		0.50	ug/L			01/26/23 07:21	1
Carbon disulfide	ND *+		0.50	ug/L			01/26/23 07:21	1
Carbon tetrachloride	ND		0.50	ug/L			01/26/23 07:21	1
Chlorobenzene	ND		0.50	ug/L			01/26/23 07:21	1
Chlorodibromomethane	ND		0.50	ug/L			01/26/23 07:21	1
Chloroethane	ND		0.50	ug/L			01/26/23 07:21	1
Chloroform (Trichloromethane)	ND		0.50	ug/L			01/26/23 07:21	1
Chloromethane (methyl chloride)	ND		0.50	ug/L			01/26/23 07:21	1
cis-1,2-Dichloroethylene	ND		0.50	ug/L			01/26/23 07:21	1
cis-1,3-Dichloropropene	ND		0.50	ug/L			01/26/23 07:21	1
Dibromomethane	ND		0.50	ug/L			01/26/23 07:21	1
Dichlorodifluoromethane	ND		0.50	ug/L			01/26/23 07:21	1
Dichloromethane	ND		0.50	ug/L			01/26/23 07:21	1
Diisopropyl ether	ND		3.0	ug/L			01/26/23 07:21	1

Eurofins Drinking Water Testing Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Lab Sample ID: 380-34727-1

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Matrix: Drinking Water

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Ethylbenzene	ND		0.50	ug/L		01/26/23 07:21		1
Hexachlorobutadiene	ND		0.50	ug/L		01/26/23 07:21		1
Isopropyl benzene	ND	++	0.50	ug/L		01/26/23 07:21		1
m,p-Xylenes	ND		0.50	ug/L		01/26/23 07:21		1
m-Dichlorobenzene (1,3-DCB)	ND	++	0.50	ug/L		01/26/23 07:21		1
Methyl-tert-butyl Ether (MTBE)	ND		0.50	ug/L		01/26/23 07:21		1
Naphthalene	ND		0.50	ug/L		01/30/23 17:31		1
n-Butylbenzene	ND		0.50	ug/L		01/26/23 07:21		1
N-Propylbenzene	ND		0.50	ug/L		01/26/23 07:21		1
o-Chlorotoluene	ND	++	0.50	ug/L		01/26/23 07:21		1
o-Dichlorobenzene (1,2-DCB)	ND		0.50	ug/L		01/26/23 07:21		1
o-Xylene	ND		0.50	ug/L		01/26/23 07:21		1
p-Chlorotoluene	ND		0.50	ug/L		01/26/23 07:21		1
p-Dichlorobenzene (1,4-DCB)	ND	++	0.50	ug/L		01/26/23 07:21		1
p-Isopropyltoluene	ND	++	0.50	ug/L		01/26/23 07:21		1
sec-Butylbenzene	ND	++	0.50	ug/L		01/26/23 07:21		1
Styrene	ND		0.50	ug/L		01/26/23 07:21		1
Tert-amyl methyl ether	ND		3.0	ug/L		01/26/23 07:21		1
Tert-butyl ethyl ether	ND		3.0	ug/L		01/26/23 07:21		1
tert-Butylbenzene	ND	++	0.50	ug/L		01/26/23 07:21		1
Tetrachloroethylene (PCE)	ND		0.50	ug/L		01/26/23 07:21		1
Toluene	ND		0.50	ug/L		01/26/23 07:21		1
trans-1,2-Dichloroethylene	ND		0.50	ug/L		01/26/23 07:21		1
trans-1,3-Dichloropropene	ND		0.50	ug/L		01/26/23 07:21		1
Trichloroethylene (TCE)	ND		0.50	ug/L		01/26/23 07:21		1
Trichlorofluoromethane (Freon 11)	ND		0.50	ug/L		01/26/23 07:21		1
Trichlorotrifluoroethane	ND		0.50	ug/L		01/26/23 07:21		1
Vinyl Chloride (VC)	ND		0.30	ug/L		01/26/23 07:21		1
Xylenes, Total	ND		0.50	ug/L		01/26/23 07:21		1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Unknown	15	T J	ug/L		0.99	N/A		01/26/23 07:21	1
Unknown	17	T J	ug/L		0.99	N/A		01/30/23 17:31	1
Unknown	0.50	T J	ug/L		3.01	N/A		01/26/23 07:21	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	111		70 - 130		01/26/23 07:21	1
1,2-Dichloroethane-d4 (Surr)	107		70 - 130		01/30/23 17:31	1
4-Bromofluorobenzene (Surr)	117		70 - 130		01/26/23 07:21	1
4-Bromofluorobenzene (Surr)	108		70 - 130		01/30/23 17:31	1
Toluene-d8 (Surr)	90		70 - 130		01/26/23 07:21	1
Toluene-d8 (Surr)	87		70 - 130		01/30/23 17:31	1

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
2,4'-DDD	ND		0.10	ug/L		01/20/23 05:58	01/20/23 18:06	1
2,4'-DDE	ND		0.10	ug/L		01/20/23 05:58	01/20/23 18:06	1
2,4'-DDT	ND		0.10	ug/L		01/20/23 05:58	01/20/23 18:06	1
2,4-Dinitrotoluene	ND		0.10	ug/L		01/20/23 05:58	01/20/23 18:06	1

Eurofins Drinking Water Testing Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-1

Matrix: Drinking Water

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
2,6-Dinitrotoluene	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
4,4'-DDD	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
4,4'-DDE	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
4,4'-DDT	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Acenaphthene	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Acenaphthylene	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Acetochlor	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Alachlor	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
alpha-BHC	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
alpha-Chlordane	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Anthracene	ND		0.020	ug/L	01/20/23 05:58	01/20/23 18:06		1
Atrazine	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Benz(a)anthracene	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Benzo[a]pyrene	ND		0.020	ug/L	01/20/23 05:58	01/20/23 18:06		1
Benzo[b]fluoranthene	ND		0.020	ug/L	01/20/23 05:58	01/20/23 18:06		1
Benzo[g,h,i]perylene	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Benzo[k]fluoranthene	ND		0.020	ug/L	01/20/23 05:58	01/20/23 18:06		1
beta-BHC	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Bis(2-ethylhexyl) phthalate	ND		0.60	ug/L	01/20/23 05:58	01/20/23 18:06		1
Bromacil	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Butachlor	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Butylbenzylphthalate	ND		0.50	ug/L	01/20/23 05:58	01/20/23 18:06		1
Chlorobenzilate	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Chloroneb	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Chlorothalonil (Draconil, Bravo)	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Chlorpyrifos	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Chrysene	ND		0.020	ug/L	01/20/23 05:58	01/20/23 18:06		1
delta-BHC	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Di(2-ethylhexyl)adipate	ND	^3+	0.60	ug/L	01/20/23 05:58	01/20/23 18:06		1
Dibenz(a,h)anthracene	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Diclorvos (DDVP)	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Dieldrin	ND		0.20	ug/L	01/20/23 05:58	01/20/23 18:06		1
Diethylphthalate	ND		0.50	ug/L	01/20/23 05:58	01/20/23 18:06		1
Dimethylphthalate	ND		0.50	ug/L	01/20/23 05:58	01/20/23 18:06		1
Di-n-butyl phthalate	ND		1.0	ug/L	01/20/23 05:58	01/20/23 18:06		1
Di-n-octyl phthalate	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Endosulfan I (Alpha)	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Endosulfan II (Beta)	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Endosulfan sulfate	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Endrin	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Endrin aldehyde	ND	^3+	0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
EPTC	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Fluoranthene	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Fluorene	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
gamma-BHC (Lindane)	ND		0.040	ug/L	01/20/23 05:58	01/20/23 18:06		1
gamma-Chlordane	ND	^3+	0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Heptachlor	ND		0.040	ug/L	01/20/23 05:58	01/20/23 18:06		1
Heptachlor epoxide (isomer B)	ND	^3+	0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1

Eurofins Drinking Water Testing Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-1

Matrix: Drinking Water

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexachlorobenzene	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Hexachlorocyclopentadiene	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Indeno[1,2,3-cd]pyrene	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Isophorone	ND		0.50	ug/L	01/20/23 05:58	01/20/23 18:06		1
Malathion	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Methoxychlor	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Metolachlor	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Metribuzin	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Molinate	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Naphthalene	ND		0.30	ug/L	01/20/23 05:58	01/20/23 18:06		1
Parathion	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Pendimethalin (Penoxaline)	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Phenanthrene	ND		0.040	ug/L	01/20/23 05:58	01/20/23 18:06		1
Propachlor	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Pyrene	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Simazine	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Terbacil	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Terbutylazine	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
Thiobencarb	ND		0.20	ug/L	01/20/23 05:58	01/20/23 18:06		1
Total Permethrin (mixed isomers)	ND		0.20	ug/L	01/20/23 05:58	01/20/23 18:06		1
trans-Nonachlor	ND		0.050	ug/L	01/20/23 05:58	01/20/23 18:06		1
Trifluralin	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
1-Methylnaphthalene	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1
2-Methylnaphthalene	ND		0.10	ug/L	01/20/23 05:58	01/20/23 18:06		1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	01/20/23 05:58	01/20/23 18:06	1
Surrogate									
%Recovery									
2-Nitro-m-xylene									
99									
Limits									
70 - 130									
Perylene-d12									
97									
Triphenylphosphate									
108									
70 - 130									
Prepared									
01/20/23 05:58									
Analyzed									
01/20/23 18:06									
Dil Fac									
1									

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,3-Trichloropropane	ND		0.041	ug/L	01/23/23 14:25	01/23/23 22:49		1
1,2-D bromo-3-Chloropropane	ND		0.010	ug/L	01/23/23 14:25	01/23/23 22:49		1
1,2-D bromoethane	ND		0.010	ug/L	01/23/23 14:25	01/23/23 22:49		1
Surrogate								
%Recovery								
117								
Limits								
60 - 140								
Prepared								
01/23/23 14:25								
Analyzed								
01/23/23 22:49								
Dil Fac								
1								

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Alachlor	ND		0.099	ug/L	01/20/23 14:15	01/20/23 20:41		1
Aldrin	ND		0.0020	ug/L	01/20/23 14:15	01/20/23 20:41		1
Chlordane (n.o.s.)	ND		0.099	ug/L	01/20/23 14:15	01/20/23 20:41		1
Dieldrin	0.010		0.0020	ug/L	01/20/23 14:15	01/20/23 20:41		1
Endrin	ND		0.0099	ug/L	01/20/23 14:15	01/20/23 20:41		1

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Lab Sample ID: 380-34727-1

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Matrix: Drinking Water

Method: EPA 505 - Organochlorine Pesticides/PCBs (GC) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
gamma-BHC (Lindane)	ND		0.0099	ug/L		01/20/23 14:15	01/20/23 20:41	1
Heptachlor	ND		0.0099	ug/L		01/20/23 14:15	01/20/23 20:41	1
Heptachlor epoxide	ND		0.0099	ug/L		01/20/23 14:15	01/20/23 20:41	1
Methoxychlor	ND		0.050	ug/L		01/20/23 14:15	01/20/23 20:41	1
PCB-1016	ND		0.070	ug/L		01/20/23 14:15	01/20/23 20:41	1
PCB-1221	ND		0.099	ug/L		01/20/23 14:15	01/20/23 20:41	1
PCB-1232	ND		0.099	ug/L		01/20/23 14:15	01/20/23 20:41	1
PCB-1242	ND		0.099	ug/L		01/20/23 14:15	01/20/23 20:41	1
PCB-1248	ND		0.099	ug/L		01/20/23 14:15	01/20/23 20:41	1
PCB-1254	ND		0.099	ug/L		01/20/23 14:15	01/20/23 20:41	1
PCB-1260	ND		0.070	ug/L		01/20/23 14:15	01/20/23 20:41	1
Polychlorinated biphenyls, Total	ND		0.099	ug/L		01/20/23 14:15	01/20/23 20:41	1
Toxaphene	ND		0.099	ug/L		01/20/23 14:15	01/20/23 20:41	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
Tetrachloro-m-xylene	99		70 - 130			01/20/23 14:15	01/20/23 20:41	1

Method: EPA 300.0 - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Bromide	330		5.0	ug/L			01/23/23 22:46	1
Chloride	39		1.0	mg/L			01/18/23 22:43	2
Nitrate as N	0.31		0.10	mg/L			01/18/23 22:43	2
Nitrate Nitrite as N	0.31		0.10	mg/L			01/18/23 22:43	2
Sulfate	5.6		0.50	mg/L			01/18/23 22:43	2
Nitrite as N	ND		0.10	mg/L			01/18/23 22:43	2

Method: EPA 245.1 - Mercury (CVAA)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	ND		0.10	ug/L		01/20/23 16:44	01/20/23 20:01	1

General Chemistry

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Alkalinity (SM 2320B)	220		2.0	mg/L			01/19/23 19:07	1
Bicarbonate Alkalinity as CaCO3 (SM 2320B)	220 ^2		2.0	mg/L			01/19/23 19:07	1
Carbonate Alkalinity as CaCO3 (SM 2320B)	ND		2.0	mg/L			01/19/23 19:07	1
Specific Conductance (SM 2510B)	920 ^2		2.0	umhos/cm			01/19/23 19:07	1
Fluoride (SM 4500 F C)	ND		0.050	mg/L			01/19/23 14:57	1
pH (SM 4500 H+ B)	8.0 HF			SU			01/19/23 19:07	1
Sulfide (SM 4500 S2 D)	ND		0.050	mg/L			01/24/23 12:17	1

Method: 625 Acid/Base/PAH + TICs - EPA 625 Base/Neutral and Acid Organics i

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	ND		0.005	0.001	ug/L		01/20/23 00:00	02/14/23 01:30	1
1-Methylphenanthrene	ND		0.005	0.001	ug/L		01/20/23 00:00	02/14/23 01:30	1
2,3,5-Trimethylnaphthalene	ND		0.005	0.001	ug/L		01/20/23 00:00	02/14/23 01:30	1
2,4,5-Trichlorophenol	ND		0.1	0.05	ug/L		01/20/23 00:00	02/14/23 01:30	1
2,4,6-Trichlorophenol	ND		0.1	0.05	ug/L		01/20/23 00:00	02/14/23 01:30	1
2,4-Dichlorophenol	ND		0.1	0.05	ug/L		01/20/23 00:00	02/14/23 01:30	1

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-1

Matrix: Drinking Water

Method: 625 Acid/Base/PAH + TICs - EPA 625 Base/Neutral and Acid Organics i (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
2,4-Dinitrophenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/14/23 01:30		1
2,6-Dichlorophenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
2,6-Dimethylnaphthalene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
2,6-Di-tert-butyl-4-methylphenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
2,6-Di-tert-butylphenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
2-Chloronaphthalene	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
2-Chlorophenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
2-Methyl-4,6-dinitrophenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/14/23 01:30		1
2-Methylnaphthalene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
2-Methylphenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/14/23 01:30		1
2-Nitroaniline	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
2-Nitrophenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/14/23 01:30		1
3+4-Methylphenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/14/23 01:30		1
3-Nitroaniline	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
4-Bromophenylphenyl ether	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
4-Chloro-3-methylphenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/14/23 01:30		1
4-Chloroaniline	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
4-Chlorophenylphenyl ether	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
4-Nitroaniline	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
4-Nitrophenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/14/23 01:30		1
6-tert-butyl-2,4-dimethylphenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
Acenaphthene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Acenaphthylene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Aniline	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
Anthracene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Benz[a]anthracene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Benzidine	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
Benzo[a]pyrene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Benzo[b]fluoranthene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Benzo[e]pyrene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Benzo[g,h,i]perylene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Benzo[k]fluoranthene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Benzoic Acid	ND		0.2	0.1	µg/L	01/20/23 00:00	02/14/23 01:30		1
Benzyl Alcohol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/14/23 01:30		1
Biphenyl	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Bis(2-Chloroethoxy) methane	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
Bis(2-Chloroethyl) ether	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
Bis(2-Chloroisopropyl) ether	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
Chrysene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Dibenz[a,h]anthracene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Dibenzo[a,l]pyrene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Dibenzofuran	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
Dibenzothiophene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Disalicylidene propanediamine	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
Fluoranthene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Fluorene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1
Hexachloroethane	ND		0.1	0.05	µg/L	01/20/23 00:00	02/14/23 01:30		1
Indeno[1,2,3-cd]pyrene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/14/23 01:30		1

Eurofins Drinking Water Testing Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-1

Matrix: Drinking Water

Method: 625 Acid/Base/PAH + TICs - EPA 625 Base/Neutral and Acid Organics i (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Naphthalene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/14/23 01:30	1
Nitrobenzene	ND		0.1	0.05	µg/L		01/20/23 00:00	02/14/23 01:30	1
N-Nitrosodi-n-propylamine	ND		0.1	0.05	µg/L		01/20/23 00:00	02/14/23 01:30	1
N-Nitrosodiphenylamine	ND		0.1	0.05	µg/L		01/20/23 00:00	02/14/23 01:30	1
Pentachlorophenol	ND		0.1	0.05	µg/L		01/20/23 00:00	02/14/23 01:30	1
Perylene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/14/23 01:30	1
Phenanthrene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/14/23 01:30	1
Phenol	ND		0.2	0.1	µg/L		01/20/23 00:00	02/14/23 01:30	1
p-tert-Butylphenol	ND		0.1	0.05	µg/L		01/20/23 00:00	02/14/23 01:30	1
Pyrene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/14/23 01:30	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
(2,4,6-Tribromophenol)	86		31 - 143				01/20/23 00:00	02/14/23 01:30	1
(d10-Acenaphthene)	91		27 - 133				01/20/23 00:00	02/14/23 01:30	1
(d10-Phenanthrene)	96		43 - 129				01/20/23 00:00	02/14/23 01:30	1
(d12-Chrysene)	95		52 - 144				01/20/23 00:00	02/14/23 01:30	1
(d12-Perylene)	90		36 - 161				01/20/23 00:00	02/14/23 01:30	1
(d5-Phenol)	20		0 - 85				01/20/23 00:00	02/14/23 01:30	1
(d8-Naphthalene)	81		25 - 125				01/20/23 00:00	02/14/23 01:30	1

Method: 8015 Ethanol - SW846 8015B Gasoline Range Organics

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
ETHANOL	ND	U	2000		ug/L			01/20/23 13:35	1

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
GASOLINE	ND	U	0.02		mg/L			01/20/23 01:52	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
BROMOFLUOROBENZENE	78		60 - 140					01/20/23 01:52	1

Method: 8015 LL DRO/MRO/JP5/JP8 - 8015 - TPH DRO/ORO

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
DIESEL	ND	U	0.027		mg/L			01/24/23 22:04	1
JP5	ND	U	0.055		mg/L			01/24/23 22:04	1
JP8	ND	U	0.055		mg/L			01/24/23 22:04	1
MOTOR OIL	ND	U	0.055		mg/L			01/24/23 22:04	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
BROMOBENZENE	96		60 - 130					01/24/23 22:04	1
HEXACOSANE	121		60 - 130					01/24/23 22:04	1

**Client Sample ID: TB: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-2

Matrix: Water

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS SIM)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Tertiary Butyl Alcohol (TBA)	ND		2.0	ug/L			01/20/23 18:34	1

Eurofins Drinking Water Testing Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: TB: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-2

Matrix: Water

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Toluene-d8 (Surr)	97		70 - 130		01/20/23 18:34	1
4-Bromofluorobenzene (Surr)	102		70 - 130		01/20/23 18:34	1
1,2-Dichloroethane-d4 (Surr)	98		70 - 130		01/20/23 18:34	1

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	ug/L		01/21/23 06:44		1
1,1,1-Trichloroethane	ND		0.50	ug/L		01/21/23 06:44		1
1,1,2,2-Tetrachloroethane	ND		0.50	ug/L		01/21/23 06:44		1
1,1,2-Trichloroethane	ND		0.50	ug/L		01/21/23 06:44		1
1,1-Dichloroethane	ND		0.50	ug/L		01/21/23 06:44		1
1,1-Dichlorethylene	ND		0.50	ug/L		01/21/23 06:44		1
1,1-Dichloropropene	ND		0.50	ug/L		01/21/23 06:44		1
1,2,3-Trichlorobenzene	ND		0.50	ug/L		01/21/23 06:44		1
1,2,3-Trichloropropane	ND		0.50	ug/L		01/21/23 06:44		1
1,2,4-Trichlorobenzene	ND		0.50	ug/L		01/21/23 06:44		1
1,2,4-Trimethyl benzene	ND		0.50	ug/L		01/21/23 06:44		1
1,2-Dichloroethane	ND		0.50	ug/L		01/21/23 06:44		1
1,2-Dichloropropane	ND		0.50	ug/L		01/21/23 06:44		1
1,3,5-Trimethyl benzene	ND		0.50	ug/L		01/21/23 06:44		1
1,3-Dichloropropane	ND		0.50	ug/L		01/21/23 06:44		1
2,2-Dichloropropane	ND		0.50	ug/L		01/21/23 06:44		1
2-Butanone (MEK)	ND		5.0	ug/L		01/21/23 06:44		1
4-Methyl-2-pentanone (MIBK)	ND		5.0	ug/L		01/21/23 06:44		1
Acetone	ND		500	ug/L		01/21/23 06:44		1
Benzene	ND		0.50	ug/L		01/21/23 06:44		1
Bromobenzene	ND		0.50	ug/L		01/21/23 06:44		1
Bromochloromethane	ND		0.50	ug/L		01/21/23 06:44		1
Bromodichloromethane	ND		0.50	ug/L		01/21/23 06:44		1
Bromoform	ND		0.50	ug/L		01/21/23 06:44		1
Bromomethane (Methyl Bromide)	ND		0.50	ug/L		01/21/23 06:44		1
Carbon disulfide	ND		0.50	ug/L		01/21/23 06:44		1
Carbon tetrachloride	ND		0.50	ug/L		01/21/23 06:44		1
Chlorobenzene	ND		0.50	ug/L		01/21/23 06:44		1
Chlorodibromomethane	ND		0.50	ug/L		01/21/23 06:44		1
Chloroethane	ND		0.50	ug/L		01/21/23 06:44		1
Chloroform (Trichloromethane)	ND		0.50	ug/L		01/21/23 06:44		1
Dichloromethane	ND		0.50	ug/L		01/21/23 06:44		1
cis-1,2-Dichloroethylene	ND		0.50	ug/L		01/21/23 06:44		1
cis-1,3-Dichloropropene	ND		0.50	ug/L		01/21/23 06:44		1
Dibromomethane	ND		0.50	ug/L		01/21/23 06:44		1
Dichlorodifluoromethane	ND		0.50	ug/L		01/21/23 06:44		1
Ethylbenzene	ND		0.50	ug/L		01/21/23 06:44		1
Hexachlorobutadiene	ND		0.50	ug/L		01/21/23 06:44		1
Isopropyl benzene	ND		0.50	ug/L		01/21/23 06:44		1
m,p-Xylenes	ND		0.50	ug/L		01/21/23 06:44		1
m-Dichlorobenzene (1,3-DCB)	ND		0.50	ug/L		01/21/23 06:44		1
Methyl-tert-butyl Ether (MTBE)	ND		0.50	ug/L		01/21/23 06:44		1
Naphthalene	ND		0.50	ug/L		01/21/23 06:44		1

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: TB: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-2

Matrix: Water

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
n-Butylbenzene	ND		0.50	ug/L			01/21/23 06:44	1
N-Propylbenzene	ND		0.50	ug/L			01/21/23 06:44	1
o-Dichlorobenzene (1,2-DCB)	ND		0.50	ug/L			01/21/23 06:44	1
o-Chlorotoluene	ND		0.50	ug/L			01/21/23 06:44	1
o-Xylene	ND		0.50	ug/L			01/21/23 06:44	1
p-Chlorotoluene	ND		0.50	ug/L			01/21/23 06:44	1
p-Dichlorobenzene (1,4-DCB)	ND		0.50	ug/L			01/21/23 06:44	1
p-Isopropyltoluene	ND		0.50	ug/L			01/21/23 06:44	1
sec-Butylbenzene	ND		0.50	ug/L			01/21/23 06:44	1
Styrene	ND		0.50	ug/L			01/21/23 06:44	1
Tert-amyl methyl ether	ND		3.0	ug/L			01/21/23 06:44	1
Tert-butyl ethyl ether	ND		3.0	ug/L			01/21/23 06:44	1
tert-Butylbenzene	ND		0.50	ug/L			01/21/23 06:44	1
Tetrachloroethene (PCE)	ND		0.50	ug/L			01/21/23 06:44	1
Toluene	ND		0.50	ug/L			01/21/23 06:44	1
1,3-Dichloropropene, Total	ND		0.50	ug/L			01/21/23 06:44	1
Xylenes, Total	ND		0.50	ug/L			01/21/23 06:44	1
trans-1,2-Dichloroethylene	ND		0.50	ug/L			01/21/23 06:44	1
trans-1,3-Dichloropropene	ND		0.50	ug/L			01/21/23 06:44	1
Trichloroethylene (TCE)	ND		0.50	ug/L			01/21/23 06:44	1
Trichlorofluoromethane (Freon 11)	ND		0.50	ug/L			01/21/23 06:44	1
Vinyl Chloride (VC)	ND		0.30	ug/L			01/21/23 06:44	1
Trichlorotrifluoroethane	ND		0.50	ug/L			01/21/23 06:44	1
Bromoethane	ND		0.50	ug/L			01/21/23 06:44	1
Chloromethane (methyl chloride)	ND		0.50	ug/L			01/21/23 06:44	1
Diisopropyl ether	ND		3.0	ug/L			01/21/23 06:44	1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Unknown	6.3	T J	ug/L		0.99	N/A		01/21/23 06:44	1
Acetaldehyde	7.0	T J N	ug/L		1.43	75-07-0		01/21/23 06:44	1
Furfural	18	T J N	ug/L		9.76	98-01-1		01/21/23 06:44	1

Surrogate	%Recovery	Qualifier	Limits		Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		70 - 130			01/21/23 06:44	1
4-Bromofluorobenzene (Surr)	96		70 - 130			01/21/23 06:44	1
Toluene-d8 (Surr)	83		70 - 130			01/21/23 06:44	1

Method: EPA-DW2 504.1 - EDB, DBCP and 1,2,3-TCP (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,3-Trichloropropane	ND		0.041	ug/L		01/23/23 14:25	01/23/23 23:24	1
1,2-D bromo-3-Chloropropane	ND		0.010	ug/L		01/23/23 14:25	01/23/23 23:24	1
1,2-D bromoethane	ND		0.010	ug/L		01/23/23 14:25	01/23/23 23:24	1
Surrogate	%Recovery	Qualifier	Limits		Prepared	Analyzed	Dil Fac	
1,2-Dibromopropane (Surr)	103		60 - 140		01/23/23 14:25	01/23/23 23:24	1	

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
GASOLINE	ND	U	0.02		mg/L			01/20/23 02:29	1

Eurofins Drinking Water Testing Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: TB: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-2

Matrix: Water

<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
BROMOFLUOROBENZENE	79		60 - 140		01/20/23 02:29	1

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Lab Sample ID: 380-34727-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	HI Org	EPAMCL	EPAMCL	Method	Prep Type
				Limit	Limit	S Limit		
1,1,1-Trichloroethane	ND		ug/L	200.0	200		524.2	Total/NA
1,1,2-Trichloroethane	ND		ug/L	5.000	5		524.2	Total/NA
1,1-Dichlorethylene	ND		ug/L	7.000	7		524.2	Total/NA
1,2,3-Trichloropropane	ND		ug/L				524.2	Total/NA
1,2,4-Trichlorobenzene	ND		ug/L	70.00	70		524.2	Total/NA
1,2-Dichloroethane	ND		ug/L	5.000	5		524.2	Total/NA
1,2-Dichloropropane	ND		ug/L	5.000	5		524.2	Total/NA
Benzene	ND		ug/L	5.000	5		524.2	Total/NA
Carbon tetrachloride	ND		ug/L	5.000	5		524.2	Total/NA
Chlorobenzene	ND		ug/L	100.0	100		524.2	Total/NA
cis-1,2-Dichloroethylene	ND		ug/L	70.00	70		524.2	Total/NA
Dichloromethane	ND		ug/L	5.000	5		524.2	Total/NA
Ethylbenzene	ND		ug/L	700.0	700		524.2	Total/NA
o-Dichlorobenzene (1,2-DCB)	ND		ug/L	600.0	600		524.2	Total/NA
p-Dichlorobenzene (1,4-DCB)	ND	**+	ug/L	75.000	75		524.2	Total/NA
Styrene	ND		ug/L	100.0	100		524.2	Total/NA
Tetrachloroethylene (PCE)	ND		ug/L	5.000	5		524.2	Total/NA
Toluene	ND		ug/L	1000	1000		524.2	Total/NA
trans-1,2-Dichloroethylene	ND		ug/L	100.0	100		524.2	Total/NA
Trichloroethylene (TCE)	ND		ug/L	5.000	5		524.2	Total/NA
Vinyl Chloride (VC)	ND		ug/L	2.000	2		524.2	Total/NA
Xylenes, Total	ND		ug/L	10000	10000		524.2	Total/NA
Alachlor	ND		ug/L		2		525.2	Total/NA
Atrazine	ND		ug/L		3		525.2	Total/NA
Benzo[a]pyrene	ND		ug/L		0.2		525.2	Total/NA
Bis(2-ethylhexyl) phthalate	ND		ug/L		6		525.2	Total/NA
Di(2-ethylhexyl)adipate	ND	^3+	ug/L		400		525.2	Total/NA
Endrin	ND		ug/L		2		525.2	Total/NA
gamma-BHC (Lindane)	ND		ug/L		0.2		525.2	Total/NA
Heptachlor	ND		ug/L		0.4		525.2	Total/NA
Heptachlor epoxide (isomer B)	ND	^3+	ug/L		0.2		525.2	Total/NA
Hexachlorobenzene	ND		ug/L		1		525.2	Total/NA
Hexachlorocyclopentadiene	ND		ug/L		50		525.2	Total/NA
Methoxychlor	ND		ug/L		40		525.2	Total/NA
Simazine	ND		ug/L		4		525.2	Total/NA
1,2,3-Trichloropropane	ND		ug/L				504.1	Total/NA
1,2-D bromo-3-Chloropropane	ND		ug/L		0.2		504.1	Total/NA
1,2-D bromoethane	ND		ug/L		0.05		504.1	Total/NA
Alachlor	ND		ug/L		2		505	Total/NA
Endrin	ND		ug/L		2		505	Total/NA
gamma-BHC (Lindane)	ND		ug/L		0.2		505	Total/NA
Heptachlor	ND		ug/L		0.4		505	Total/NA
Heptachlor epoxide	ND		ug/L		0.2		505	Total/NA
Methoxychlor	ND		ug/L		40		505	Total/NA
Polychlorinated biphenyls, Total	ND		ug/L		0.5		505	Total/NA
Toxaphene	ND		ug/L		3		505	Total/NA

Eurofins Drinking Water Testing Pomona

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Client Sample ID: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (Continued)

Lab Sample ID: 380-34727-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	HI Org	EPAMCL	EPAMCL	Method	Prep Type
				Limit	Limit	S Limit		
Chloride	39		mg/L			250	300.0	Total/NA
Nitrate as N	0.31		mg/L		10		300.0	Total/NA
Nitrate Nitrite as N	0.31		mg/L		10		300.0	Total/NA
Sulfate	5.6		mg/L			250	300.0	Total/NA
Nitrite as N	ND		mg/L		1		300.0	Total/NA
Mercury	ND		ug/L		2		245.1	Total/NA
Fluoride	ND		mg/L		4	2	SM 4500 F C	Total/NA

Client Sample ID: TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400)

Lab Sample ID: 380-34727-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	HI Org	EPAMCL	RL	Method	Prep Type
				Limit	Limit			
1,1,1-Trichloroethane	ND		ug/L	200.0	200	0.50	524.2	Total/NA
1,1,2-Trichloroethane	ND		ug/L	5.000	5	0.50	524.2	Total/NA
1,1-Dichlorethylene	ND		ug/L	7.000	7	0.50	524.2	Total/NA
1,2,3-Trichloropropane	ND		ug/L			0.50	524.2	Total/NA
1,2,4-Trichlorobenzene	ND		ug/L	70.00	70	0.50	524.2	Total/NA
1,2-Dichloroethane	ND		ug/L	5.000	5	0.50	524.2	Total/NA
1,2-Dichloropropane	ND		ug/L	5.000	5	0.50	524.2	Total/NA
Benzene	ND		ug/L	5.000	5	0.50	524.2	Total/NA
Carbon tetrachloride	ND		ug/L	5.000	5	0.50	524.2	Total/NA
Chlorobenzene	ND		ug/L	100.0	100	0.50	524.2	Total/NA
Dichloromethane	ND		ug/L	5.000	5	0.50	524.2	Total/NA
cis-1,2-Dichloroethylene	ND		ug/L	70.00	70	0.50	524.2	Total/NA
Ethylbenzene	ND		ug/L	700.0	700	0.50	524.2	Total/NA
o-Dichlorobenzene (1,2-DCB)	ND		ug/L	600.0	600	0.50	524.2	Total/NA
p-Dichlorobenzene (1,4-DCB)	ND		ug/L	75.000	75	0.50	524.2	Total/NA
Styrene	ND		ug/L	100.0	100	0.50	524.2	Total/NA
Tetrachloroethylene (PCE)	ND		ug/L	5.000	5	0.50	524.2	Total/NA
Toluene	ND		ug/L	1000	1000	0.50	524.2	Total/NA
Xylenes, Total	ND		ug/L	10000	10000	0.50	524.2	Total/NA
trans-1,2-Dichloroethylene	ND		ug/L	100.0	100	0.50	524.2	Total/NA
Trichloroethylene (TCE)	ND		ug/L	5.000	5	0.50	524.2	Total/NA
Vinyl Chloride (VC)	ND		ug/L	2.000	2	0.30	524.2	Total/NA
1,2,3-Trichloropropane	ND		ug/L			0.041	504.1	Total/NA
1,2-D bromo-3-Chloropropane	ND		ug/L		0.2	0.010	504.1	Total/NA
1,2-D bromoethane	ND		ug/L		0.05	0.010	504.1	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS SIM)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		TOL (70-130)	BFB (70-130)	DCA (70-130)
380-34727-1	AIEA WELLS PUMPS 1&2 (260)	98	102	99
Surrogate Legend				
TOL = Toluene-d8 (Surr)				
BFB = 4-Bromofluorobenzene (Surr)				
DCA = 1,2-Dichloroethane-d4 (Surr)				

Method: 524.2 - Volatile Organic Compounds (GC/MS SIM)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		TOL (70-130)	BFB (70-130)	DCA (70-130)
380-34727-2	TB: AIEA WELLS PUMPS 1&2 (97	102	98
LCS 380-30366/2	Lab Control Sample	102	97	98
LCSD 380-30366/3	Lab Control Sample Dup	101	98	99
MB 380-30366/5	Method Blank	98	96	100
Surrogate Legend				
TOL = Toluene-d8 (Surr)				
BFB = 4-Bromofluorobenzene (Surr)				
DCA = 1,2-Dichloroethane-d4 (Surr)				

Method: 524.2 - Volatile Organic Compounds (GC/MS SIM)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		TOL (50-150)	BFB (50-150)	DCA (50-150)
MRL 380-30366/4	Lab Control Sample	100	98	99
Surrogate Legend				
TOL = Toluene-d8 (Surr)				
BFB = 4-Bromofluorobenzene (Surr)				
DCA = 1,2-Dichloroethane-d4 (Surr)				

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		DCA (70-130)	BFB (70-130)	TOL (70-130)
380-34727-1	AIEA WELLS PUMPS 1&2 (260)	111	117	90
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP400)	107	108	87
Surrogate Legend				
DCA = 1,2-Dichloroethane-d4 (Surr)				
BFB = 4-Bromofluorobenzene (Surr)				
TOL = Toluene-d8 (Surr)				

Surrogate Summary

Client: City & County of Honolulu

Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		DCA (70-130)	BFB (70-130)	TOL (70-130)
380-34727-2	TB: AIEA WELLS PUMPS 1&2 (99	96	83
LCS 380-30382/11	Lab Control Sample	94	100	96
LCS 380-30675/11	Lab Control Sample	98	108	99
LCS 380-30695/3	Lab Control Sample	96	129	107
LCS 380-30956/4	Lab Control Sample	99	99	102
LCSD 380-30382/12	Lab Control Sample Dup	97	92	97
LCSD 380-30675/12	Lab Control Sample Dup	96	101	100
LCSD 380-30695/4	Lab Control Sample Dup	99	120	101
LCSD 380-30956/5	Lab Control Sample Dup	96	98	100
MB 380-30382/15	Method Blank	102	95	94
MB 380-30675/15	Method Blank	111	107	92
MB 380-30695/5	Method Blank	102	129	95
MB 380-30956/8	Method Blank	101	92	79
MRL 380-30382/10	Lab Control Sample	100	86	93
MRL 380-30382/14	Lab Control Sample	101	98	96
MRL 380-30675/10	Lab Control Sample	97	99	92
MRL 380-30675/14	Lab Control Sample	96	130	97
MRL 380-30956/3	Lab Control Sample	99	104	89
MRL 380-30956/7	Lab Control Sample	102	97	91

Surrogate Legend

DCA = 1,2-Dichloroethane-d4 (Surr)

BFB = 4-Bromofluorobenzene (Surr)

TOL = Toluene-d8 (Surr)

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-34727-1	AIEA WELLS PUMPS 1&2 (260)	99	97	108

Surrogate Legend

2NMX = 2-Nitro-m-xylene

PRY = Perylene-d12

TPP = Triphenylphosphate

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-34654-R-1-A MS	Matrix Spike	100	99	108
380-34720-V-2-A DU	Duplicate	99	97	112
LCS 380-30258/3-A	Lab Control Sample	97	95	108
LCSD 380-30258/4-A	Lab Control Sample Dup	99	97	107
MB 380-30258/1-A	Method Blank	101	93	105
MRL 380-30258/2-A	Lab Control Sample	100	91	109

Surrogate Legend

Surrogate Summary

Client: City & County of Honolulu

Project/Site: RED-HILL

2NMX = 2-Nitro-m-xylene

PRY = Perylene-d12

TPP = Triphenylphosphate

Job ID: 380-34727-1

Method: 504.1 - EDB, DBCP and 1,2,3-TCP (GC)

Matrix: Drinking Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	DBPP1 (60-140)
380-34727-1	AIEA WELLS PUMPS 1&2 (260)	117

Surrogate Legend

DBPP = 1,2-D bromopropane (Surr)

Method: 504.1 - EDB, DBCP and 1,2,3-TCP (GC)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	DBPP1 (60-140)
380-34654-B-1-A MS	Matrix Spike	109
380-34654-J-2-A DU	Duplicate	111
380-34727-2	TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400)	103
LCS 380-30432/3-A	Lab Control Sample	110
MBL 380-30432/4-A	Method Blank	105
MRL 380-30432/1-A	Lab Control Sample	113
MRL 380-30432/2-A	Lab Control Sample	112

Surrogate Legend

DBPP = 1,2-D bromopropane (Surr)

Method: 505 - Organochlorine Pesticides/PCBs (GC)

Matrix: Drinking Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	TCX1 (70-130)
380-34727-1	AIEA WELLS PUMPS 1&2 (260)	99

Surrogate Legend

TCX = Tetrachloro-m-xylene

Method: 505 - Organochlorine Pesticides/PCBs (GC)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	TCX1 (70-130)
380-34454-P-1-A MS	Matrix Spike	99
380-34454-Q-1-A MS	Matrix Spike	91
380-34654-E-1-A MS	Matrix Spike	99
380-34654-F-1-A MS	Matrix Spike	94
MB 380-30329/7-A	Method Blank	101
MRL 380-30329/2-A	Lab Control Sample	94
MRL 380-30329/3-A	Lab Control Sample	100
MRL 380-30329/4-A	Lab Control Sample	99
MRL 380-30329/5-A	Lab Control Sample	94
MRL 380-30329/6-A	Lab Control Sample	93

Surrogate Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Surrogate Legend

TCX = Tetrachloro-m-xylene

Method: 625 Acid/Base/PAH + TICs - EPA 625 Base/Neutral and Acid Organics i

Matrix: Blank Matrix

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)						
		Acenaphthl (27-133)	Phenanth (43-129)	CRY (52-144)	NPT (25-125)	PHL (0-130)	PRY (36-161)	TBP (30-130)
103732-B1	Method Blank	98	97	104	86	76	96	93
103732-BS1	Lab Control Sample	93	93	102	80	82	95	108
103732-BS2	Lab Control Sample Dup	96	96	105	93	95	92	107

Surrogate Legend

(d10-Acenaphthene) = (d10-Acenaphthene)

(d10-Phenanthrene) = (d10-Phenanthrene)

CRY = (d12-Chrysene)

NPT = (d8-Naphthalene)

PHL = (d5-Phenol)

PRY = (d12-Perylene)

TBP = (2,4,6-Tribromophenol)

Method: 625 Acid/Base/PAH + TICs - EPA 625 Base/Neutral and Acid Organics i

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)						
		Acenaphthl (27-133)	Phenanth (43-129)	CRY (52-144)	NPT (25-125)	PHL (0-85)	PRY (36-161)	TBP (31-143)
380-34727-1	AIEA WELLS PUMPS 1&2 (260)	9	96	95	81	20	90	86

Surrogate Legend

(d10-Acenaphthene) = (d10-Acenaphthene)

(d10-Phenanthrene) = (d10-Phenanthrene)

CRY = (d12-Chrysene)

NPT = (d8-Naphthalene)

PHL = (d5-Phenol)

PRY = (d12-Perylene)

TBP = (2,4,6-Tribromophenol)

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)						
		BFB (60-140)						
380-34727-1	AIEA WELLS PUMPS 1&2 (260)	78						

Surrogate Legend

BFB = BROMOFLUOROBENZENE

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)						
		BFB (60-140)						
380-34727-2	TB: AIEA WELLS PUMPS 1&2 (79						

Surrogate Legend

Eurofins Drinking Water Testing Pomona

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL
L HEXACOSANE = HEXACOSANE

Job ID: 380-34727-1

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-30382/15

Matrix: Water

Analysis Batch: 30382

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	ug/L			01/21/23 00:12	1
1,1,1-Trichloroethane	ND		0.50	ug/L			01/21/23 00:12	1
1,1,2,2-Tetrachloroethane	ND		0.50	ug/L			01/21/23 00:12	1
1,1,2-Trichloroethane	ND		0.50	ug/L			01/21/23 00:12	1
1,1-Dichloroethane	ND		0.50	ug/L			01/21/23 00:12	1
1,1-Dichlorethylene	ND		0.50	ug/L			01/21/23 00:12	1
1,1-Dichloropropene	ND		0.50	ug/L			01/21/23 00:12	1
1,2,3-Trichlorobenzene	ND		0.50	ug/L			01/21/23 00:12	1
1,2,3-Trichloropropane	ND		0.50	ug/L			01/21/23 00:12	1
1,2,4-Trichlorobenzene	ND		0.50	ug/L			01/21/23 00:12	1
1,2,4-Trimethyl benzene	ND		0.50	ug/L			01/21/23 00:12	1
1,2-Dichloroethane	ND		0.50	ug/L			01/21/23 00:12	1
1,2-Dichloropropane	ND		0.50	ug/L			01/21/23 00:12	1
1,3,5-Trimethyl benzene	ND		0.50	ug/L			01/21/23 00:12	1
1,3-Dichloropropane	ND		0.50	ug/L			01/21/23 00:12	1
2,2-Dichloropropane	ND		0.50	ug/L			01/21/23 00:12	1
2-Butanone (MEK)	ND		5.0	ug/L			01/21/23 00:12	1
4-Methyl-2-pentanone (MIBK)	ND		5.0	ug/L			01/21/23 00:12	1
Acetone	ND		500	ug/L			01/21/23 00:12	1
Benzene	ND		0.50	ug/L			01/21/23 00:12	1
Bromobenzene	ND		0.50	ug/L			01/21/23 00:12	1
Bromochloromethane	ND		0.50	ug/L			01/21/23 00:12	1
Bromodichloromethane	ND		0.50	ug/L			01/21/23 00:12	1
Bromoform	ND		0.50	ug/L			01/21/23 00:12	1
Bromomethane (Methyl Bromide)	ND		0.50	ug/L			01/21/23 00:12	1
Carbon disulfide	ND		0.50	ug/L			01/21/23 00:12	1
Carbon tetrachloride	ND		0.50	ug/L			01/21/23 00:12	1
Chlorobenzene	ND		0.50	ug/L			01/21/23 00:12	1
Chlorodibromomethane	ND		0.50	ug/L			01/21/23 00:12	1
Chloroethane	ND		0.50	ug/L			01/21/23 00:12	1
Chloroform (Trichloromethane)	ND		0.50	ug/L			01/21/23 00:12	1
cis-1,2-Dichloroethylene	ND		0.50	ug/L			01/21/23 00:12	1
cis-1,3-Dichloropropene	ND		0.50	ug/L			01/21/23 00:12	1
Dibromomethane	ND		0.50	ug/L			01/21/23 00:12	1
Dichlorodifluoromethane	ND		0.50	ug/L			01/21/23 00:12	1
Dichloromethane	ND		0.50	ug/L			01/21/23 00:12	1
Ethylbenzene	ND		0.50	ug/L			01/21/23 00:12	1
Hexachlorobutadiene	ND		0.50	ug/L			01/21/23 00:12	1
Isopropyl benzene	ND		0.50	ug/L			01/21/23 00:12	1
m,p-Xylenes	ND		0.50	ug/L			01/21/23 00:12	1
m-Dichlorobenzene (1,3-DCB)	ND		0.50	ug/L			01/21/23 00:12	1
Methyl-tert-butyl Ether (MTBE)	ND		0.50	ug/L			01/21/23 00:12	1
Naphthalene	ND		0.50	ug/L			01/21/23 00:12	1
n-Butylbenzene	ND		0.50	ug/L			01/21/23 00:12	1
N-Propylbenzene	ND		0.50	ug/L			01/21/23 00:12	1
o-Chlorotoluene	ND		0.50	ug/L			01/21/23 00:12	1
o-Dichlorobenzene (1,2-DCB)	ND		0.50	ug/L			01/21/23 00:12	1
o-Xylene	ND		0.50	ug/L			01/21/23 00:12	1

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-30382/15

Matrix: Water

Analysis Batch: 30382

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
p-Chlorotoluene	ND		0.50	ug/L		01/21/23 00:12		1
p-Dichlorobenzene (1,4-DCB)	ND		0.50	ug/L		01/21/23 00:12		1
p-Isopropyltoluene	ND		0.50	ug/L		01/21/23 00:12		1
sec-Butylbenzene	ND		0.50	ug/L		01/21/23 00:12		1
Styrene	ND		0.50	ug/L		01/21/23 00:12		1
Tert-amyl methyl ether	ND		3.0	ug/L		01/21/23 00:12		1
1,3-Dichloropropene, Total	ND		0.50	ug/L		01/21/23 00:12		1
Tert-butyl ethyl ether	ND		3.0	ug/L		01/21/23 00:12		1
tert-Butylbenzene	ND		0.50	ug/L		01/21/23 00:12		1
Tetrachloroethylene (PCE)	ND		0.50	ug/L		01/21/23 00:12		1
Toluene	ND		0.50	ug/L		01/21/23 00:12		1
trans-1,2-Dichloroethylene	ND		0.50	ug/L		01/21/23 00:12		1
trans-1,3-Dichloropropene	ND		0.50	ug/L		01/21/23 00:12		1
Trichloroethylene (TCE)	ND		0.50	ug/L		01/21/23 00:12		1
Bromoethane	ND		0.50	ug/L		01/21/23 00:12		1
Trichlorofluoromethane (Freon 11)	ND		0.50	ug/L		01/21/23 00:12		1
Chloromethane (methyl chloride)	ND		0.50	ug/L		01/21/23 00:12		1
Trichlorotrifluoroethane	ND		0.50	ug/L		01/21/23 00:12		1
Diisopropyl ether	ND		3.0	ug/L		01/21/23 00:12		1
Vinyl Chloride (VC)	ND		0.30	ug/L		01/21/23 00:12		1
Xylenes, Total	ND		0.50	ug/L		01/21/23 00:12		1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A		01/21/23 00:12	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		70 - 130		01/21/23 00:12	1
4-Bromofluorobenzene (Surr)	95		70 - 130		01/21/23 00:12	1
Toluene-d8 (Surr)	94		70 - 130		01/21/23 00:12	1

Lab Sample ID: LCS 380-30382/11

Matrix: Water

Analysis Batch: 30382

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec Limits
1,1,1,2-Tetrachloroethane	5.00	5.50		ug/L	110	70 - 130
1,1,1-Trichloroethane	5.00	5.13		ug/L	103	70 - 130
1,1,2,2-Tetrachloroethane	5.00	5.64		ug/L	113	70 - 130
1,1,2-Trichloroethane	5.00	5.26		ug/L	105	70 - 130
1,1-Dichloroethane	5.00	5.53		ug/L	111	70 - 130
1,1-Dichlorethylene	5.00	5.57		ug/L	111	70 - 130
1,1-Dichloropropene	5.00	5.47		ug/L	109	70 - 130
1,2,3-Trichlorobenzene	5.00	6.08		ug/L	122	70 - 130
1,2,3-Trichloropropane	5.00	5.67		ug/L	113	70 - 130
1,2,4-Trichlorobenzene	5.00	5.94		ug/L	119	70 - 130
1,2,4-Trimethyl benzene	5.00	5.79		ug/L	116	70 - 130
1,2-Dichloroethane	5.00	5.13		ug/L	103	70 - 130
1,2-Dichloropropane	5.00	5.33		ug/L	107	70 - 130

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-30382/11

Matrix: Water

Analysis Batch: 30382

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
1,3,5-Trimethyl benzene	5.00	5.79		ug/L	116	70 - 130	
1,3-Dichloropropane	5.00	5.44		ug/L	109	70 - 130	
2,2-Dichloropropane	5.00	5.03		ug/L	101	70 - 130	
2-Butanone (MEK)	50.0	49.4		ug/L	99	70 - 130	
4-Methyl-2-pentanone (MIBK)	50.0	54.3		ug/L	109	70 - 130	
Acetone	50.0	53.1	J	ug/L	106	70 - 130	
Benzene	5.00	5.39		ug/L	108	70 - 130	
Bromobenzene	5.00	5.63		ug/L	113	70 - 130	
Bromochloromethane	5.00	5.62		ug/L	112	70 - 130	
Bromodichloromethane	5.00	5.54		ug/L	111	70 - 130	
Bromoform	5.00	5.36		ug/L	107	70 - 130	
Bromomethane (Methyl Bromide)	5.00	4.72		ug/L	94	70 - 130	
Carbon disulfide	5.00	5.53		ug/L	111	70 - 130	
Carbon tetrachloride	5.00	5.47		ug/L	109	70 - 130	
Chlorobenzene	5.00	5.38		ug/L	108	70 - 130	
Chlorodibromomethane	5.00	4.93		ug/L	99	70 - 130	
cis-1,3-Dichloropropene	5.00	5.33		ug/L	107	70 - 130	
Dichloromethane	5.00	5.56		ug/L	111	70 - 130	
Ethylbenzene	5.00	5.40		ug/L	108	70 - 130	
Hexachlorobutadiene	5.00	5.76		ug/L	115	70 - 130	
Isopropyl benzene	5.00	5.80		ug/L	116	70 - 130	
m,p-Xylenes	10.0	10.9		ug/L	109	70 - 130	
m-Dichlorobenzene (1,3-DCB)	5.00	5.72		ug/L	114	70 - 130	
Methyl-tert-butyl Ether (MTBE)	5.00	5.40		ug/L	108	70 - 130	
Naphthalene	5.00	6.04		ug/L	121	70 - 130	
n-Butylbenzene	5.00	5.58		ug/L	112	70 - 130	
N-Propylbenzene	5.00	5.43		ug/L	109	70 - 130	
o-Chlorotoluene	5.00	5.90		ug/L	118	70 - 130	
o-Dichlorobenzene (1,2-DCB)	5.00	5.68		ug/L	114	70 - 130	
o-Xylene	5.00	5.12		ug/L	102	70 - 130	
p-Chlorotoluene	5.00	5.32		ug/L	106	70 - 130	
p-Dichlorobenzene (1,4-DCB)	5.00	5.52		ug/L	110	70 - 130	
p-Isopropyltoluene	5.00	5.78		ug/L	116	70 - 130	
sec-Butylbenzene	5.00	5.87		ug/L	117	70 - 130	
Styrene	5.00	5.20		ug/L	104	70 - 130	
Tert-amyl methyl ether	5.00	5.29		ug/L	106	70 - 130	
1,3-Dichloropropene, Total	10.0	10.1		ug/L	101	70 - 130	
Tert-butyl ethyl ether	5.00	5.73		ug/L	115	70 - 130	
tert-Butylbenzene	5.00	5.80		ug/L	116	70 - 130	
Tetrachloroethylene (PCE)	5.00	5.44		ug/L	109	70 - 130	
Toluene	5.00	5.36		ug/L	107	70 - 130	
trans-1,2-Dichloroethylene	5.00	5.55		ug/L	111	70 - 130	
trans-1,3-Dichloropropene	5.00	4.74		ug/L	95	70 - 130	
Trichloroethylene (TCE)	5.00	5.35		ug/L	107	70 - 130	
Bromoethane	5.00	5.48		ug/L	110	70 - 130	
Trichlorofluoromethane (Freon 11)	5.00	5.84		ug/L	117	70 - 130	
Trichlorotrifluoroethane	5.00	5.66		ug/L	113	70 - 130	
Disopropyl ether	5.00	5.62		ug/L	112	70 - 130	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-30382/11

Matrix: Water

Analysis Batch: 30382

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Vinyl Chloride (VC)	5.00	4.62		ug/L	92	70 - 130	
Xylenes, Total	15.0	16.1		ug/L	107	70 - 130	

Surrogate	LCS %Recovery	LCS Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	94		70 - 130
4-Bromofluorobenzene (Surr)	100		70 - 130
Toluene-d8 (Surr)	96		70 - 130

Lab Sample ID: LCSD 380-30382/12

Matrix: Water

Analysis Batch: 30382

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1,1,1,2-Tetrachloroethane	5.00	4.89		ug/L	98	70 - 130		12	20
1,1,1-Trichloroethane	5.00	4.95		ug/L	99	70 - 130		4	20
1,1,2,2-Tetrachloroethane	5.00	5.17		ug/L	103	70 - 130		9	20
1,1,2-Trichloroethane	5.00	5.02		ug/L	100	70 - 130		5	20
1,1-Dichloroethane	5.00	5.16		ug/L	103	70 - 130		7	20
1,1-Dichlorethylene	5.00	4.96		ug/L	99	70 - 130		11	20
1,1-Dichloropropene	5.00	5.01		ug/L	100	70 - 130		9	20
1,2,3-Trichlorobenzene	5.00	5.94		ug/L	119	70 - 130		2	20
1,2,3-Trichloropropane	5.00	5.44		ug/L	109	70 - 130		4	20
1,2,4-Trichlorobenzene	5.00	5.61		ug/L	112	70 - 130		6	20
1,2,4-Trimethyl benzene	5.00	5.36		ug/L	107	70 - 130		8	20
1,2-Dichloroethane	5.00	4.58		ug/L	92	70 - 130		11	20
1,2-Dichloropropane	5.00	4.90		ug/L	98	70 - 130		8	20
1,3,5-Trimethyl benzene	5.00	5.28		ug/L	106	70 - 130		9	20
1,3-Dichloropropane	5.00	5.02		ug/L	100	70 - 130		8	20
2,2-Dichloropropane	5.00	4.87		ug/L	97	70 - 130		3	20
2-Butanone (MEK)	50.0	46.3		ug/L	93	70 - 130		6	20
4-Methyl-2-pentanone (MIBK)	50.0	53.0		ug/L	106	70 - 130		2	20
Acetone	50.0	48.4	J	ug/L	97	70 - 130		9	20
Benzene	5.00	4.85		ug/L	97	70 - 130		10	20
Bromobenzene	5.00	5.20		ug/L	104	70 - 130		8	20
Bromochloromethane	5.00	5.30		ug/L	106	70 - 130		6	20
Bromodichloromethane	5.00	4.96		ug/L	99	70 - 130		11	20
Bromoform	5.00	5.11		ug/L	102	70 - 130		5	20
Bromomethane (Methyl Bromide)	5.00	5.13		ug/L	103	70 - 130		8	20
Carbon disulfide	5.00	4.86		ug/L	97	70 - 130		13	20
Carbon tetrachloride	5.00	4.85		ug/L	97	70 - 130		12	20
Chlorobenzene	5.00	4.95		ug/L	99	70 - 130		8	20
Chlorodibromomethane	5.00	4.55		ug/L	91	70 - 130		8	20
cis-1,3-Dichloropropene	5.00	4.81		ug/L	96	70 - 130		10	20
Dichloromethane	5.00	5.29		ug/L	106	70 - 130		5	20
Ethylbenzene	5.00	4.93		ug/L	99	70 - 130		9	20
Hexachlorobutadiene	5.00	5.13		ug/L	103	70 - 130		12	20
Isopropyl benzene	5.00	5.17		ug/L	103	70 - 130		11	20
m,p-Xylenes	10.0	9.99		ug/L	100	70 - 130		9	20

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 380-30382/12

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Matrix: Water
Analysis Batch: 30382

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD RPD	RPD Limit
m-Dichlorobenzene (1,3-DCB)	5.00	5.28		ug/L	106	70 - 130	8	20	
Methyl-tert-butyl Ether (MTBE)	5.00	5.25		ug/L	105	70 - 130	3	20	
Naphthalene	5.00	6.01		ug/L	120	70 - 130	1	20	
n-Butylbenzene	5.00	5.50		ug/L	110	70 - 130	2	20	
N-Propylbenzene	5.00	4.94		ug/L	99	70 - 130	10	20	
o-Chlorotoluene	5.00	5.30		ug/L	106	70 - 130	11	20	
o-Dichlorobenzene (1,2-DCB)	5.00	5.69		ug/L	114	70 - 130	0	20	
o-Xylene	5.00	4.82		ug/L	96	70 - 130	6	20	
p-Chlorotoluene	5.00	5.04		ug/L	101	70 - 130	5	20	
p-Dichlorobenzene (1,4-DCB)	5.00	5.09		ug/L	102	70 - 130	8	20	
p-Isopropyltoluene	5.00	5.13		ug/L	103	70 - 130	12	20	
sec-Butylbenzene	5.00	5.27		ug/L	105	70 - 130	11	20	
Styrene	5.00	4.91		ug/L	98	70 - 130	6	20	
Tert-amyl methyl ether	5.00	4.92		ug/L	98	70 - 130	7	20	
1,3-Dichloropropene, Total	10.0	9.33		ug/L	93	70 - 130	8	20	
Tert-butyl ethyl ether	5.00	5.42		ug/L	108	70 - 130	6	20	
tert-Butylbenzene	5.00	5.19		ug/L	104	70 - 130	11	20	
Tetrachloroethylene (PCE)	5.00	4.75		ug/L	95	70 - 130	14	20	
Toluene	5.00	4.83		ug/L	97	70 - 130	10	20	
trans-1,2-Dichloroethylene	5.00	4.98		ug/L	100	70 - 130	11	20	
trans-1,3-Dichloropropene	5.00	4.52		ug/L	90	70 - 130	5	20	
Trichloroethylene (TCE)	5.00	4.92		ug/L	98	70 - 130	8	20	
Bromoethane	5.00	4.94		ug/L	99	70 - 130	10	20	
Trichlorofluoromethane (Freon 11)	5.00	5.44		ug/L	109	70 - 130	7	20	
Trichlorotrifluoroethane	5.00	5.12		ug/L	102	70 - 130	10	20	
Diisopropyl ether	5.00	5.26		ug/L	105	70 - 130	6	20	
Vinyl Chloride (VC)	5.00	4.85		ug/L	97	70 - 130	5	20	
Xylenes, Total	15.0	14.8		ug/L	99	70 - 130	8	20	

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	97		70 - 130
4-Bromofluorobenzene (Surr)	92		70 - 130
Toluene-d8 (Surr)	97		70 - 130

Lab Sample ID: MRL 380-30382/10

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Matrix: Water
Analysis Batch: 30382

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
m,p-Xylenes	0.500	0.680		ug/L	136	50 - 150	
Vinyl Chloride (VC)	0.250	0.313		ug/L	125	50 - 150	

Surrogate	MRL %Recovery	MRL Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	100		70 - 130
4-Bromofluorobenzene (Surr)	86		70 - 130
Toluene-d8 (Surr)	93		70 - 130

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-30382/14

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Matrix: Water
Analysis Batch: 30382

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1,1,1,2-Tetrachloroethane	0.500	0.442	J	ug/L	88	50 - 150	
1,1,1-Trichloroethane	0.500	0.514		ug/L	103	50 - 150	
1,1,2,2-Tetrachloroethane	0.500	0.509		ug/L	102	50 - 150	
1,1,2-Trichloroethane	0.500	0.484	J	ug/L	97	50 - 150	
1,1-Dichloroethane	0.500	0.550		ug/L	110	50 - 150	
1,1-Dichlorethylene	0.500	0.593		ug/L	119	50 - 150	
1,1-Dichloropropene	0.500	0.521		ug/L	104	50 - 150	
1,2,3-Trichlorobenzene	0.500	0.673		ug/L	135	50 - 150	
1,2,3-Trichloropropane	0.500	0.547		ug/L	109	50 - 150	
1,2,4-Trichlorobenzene	0.500	0.598		ug/L	120	50 - 150	
1,2,4-Trimethyl benzene	0.500	0.479	J	ug/L	96	50 - 150	
1,2-Dichloroethane	0.500	0.550		ug/L	110	50 - 150	
1,2-Dichloropropane	0.500	0.543		ug/L	109	50 - 150	
1,3,5-Trimethyl benzene	0.500	0.462	J	ug/L	92	50 - 150	
1,3-Dichloropropane	0.500	0.533		ug/L	107	50 - 150	
2,2-Dichloropropane	0.500	0.476	J	ug/L	95	50 - 150	
2-Butanone (MEK)	5.00	5.36		ug/L	107	50 - 150	
4-Methyl-2-pentanone (MIBK)	5.00	4.70	J	ug/L	94	50 - 150	
Acetone	5.00	5.79	J	ug/L	116	50 - 150	
Benzene	0.500	0.527		ug/L	105	50 - 150	
Bromobenzene	0.500	0.542		ug/L	108	50 - 150	
Bromoform	0.500	0.572		ug/L	114	50 - 150	
Bromochloromethane	0.500	0.481	J	ug/L	96	50 - 150	
Bromodichloromethane	0.500	0.593		ug/L	119	50 - 150	
Bromomethane (Methyl Bromide)	0.500	0.681		ug/L	136	50 - 150	
Carbon disulfide	0.500	0.448	J	ug/L	90	50 - 150	
Carbon tetrachloride	0.500	0.460	J	ug/L	92	50 - 150	
Chlorobenzene	0.500	0.500		ug/L	100	50 - 150	
Chlorodibromomethane	0.500	0.519		ug/L	104	50 - 150	
cis-1,3-Dichloropropene	0.500	0.411	J	ug/L	82	50 - 150	
Dichloromethane	0.500	0.581		ug/L	116	50 - 150	
Ethylbenzene	0.500	0.503		ug/L	101	50 - 150	
Hexachlorobutadiene	0.500	0.662		ug/L	132	50 - 150	
Isopropyl benzene	0.500	0.477	J	ug/L	95	50 - 150	
m,p-Xylenes	1.00	1.01		ug/L	101	50 - 150	
m-Dichlorobenzene (1,3-DCB)	0.500	0.546		ug/L	109	50 - 150	
Methyl-tert-butyl Ether (MTBE)	0.500	0.539		ug/L	108	50 - 150	
Naphthalene	0.500	0.585		ug/L	117	50 - 150	
n-Butylbenzene	0.500	0.496	J	ug/L	99	50 - 150	
N-Propylbenzene	0.500	0.500		ug/L	100	50 - 150	
o-Chlorotoluene	0.500	0.511		ug/L	102	50 - 150	
o-Dichlorobenzene (1,2-DCB)	0.500	0.549		ug/L	110	50 - 150	
o-Xylene	0.500	0.528		ug/L	106	50 - 150	
p-Chlorotoluene	0.500	0.526		ug/L	105	50 - 150	
p-Dichlorobenzene (1,4-DCB)	0.500	0.526		ug/L	105	50 - 150	
p-Isopropyltoluene	0.500	0.481	J	ug/L	96	50 - 150	
sec-Butylbenzene	0.500	0.495	J	ug/L	99	50 - 150	
Styrene	0.500	0.453	J	ug/L	91	50 - 150	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-30382/14

Matrix: Water

Analysis Batch: 30382

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
Tert-amyl methyl ether	0.500	0.509	J	ug/L		102	50 - 150
1,3-Dichloropropene, Total	1.00	0.882		ug/L		88	50 - 150
Tert-butyl ethyl ether	0.500	0.562	J	ug/L		112	50 - 150
tert-Butylbenzene	0.500	0.490	J	ug/L		98	50 - 150
Tetrachloroethene (PCE)	0.500	0.527		ug/L		105	50 - 150
Toluene	0.500	0.510		ug/L		102	50 - 150
trans-1,2-Dichloroethylene	0.500	0.675		ug/L		135	50 - 150
trans-1,3-Dichloropropene	0.500	0.471	J	ug/L		94	50 - 150
Trichloroethylene (TCE)	0.500	0.508		ug/L		102	50 - 150
Bromoethane	0.500	0.568		ug/L		114	50 - 150
Trichlorofluoromethane (Freon 11)	0.500	0.520		ug/L		104	50 - 150
Trichlorotrifluoroethane	0.500	0.579		ug/L		116	50 - 150
Diisopropyl ether	0.500	0.554	J	ug/L		111	50 - 150
Vinyl Chloride (VC)	0.500	0.320		ug/L		64	50 - 150
Xylenes, Total	1.50	1.54		ug/L		103	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	101		70 - 130
4-Bromofluorobenzene (Surr)	98		70 - 130
Toluene-d8 (Surr)	96		70 - 130

Lab Sample ID: MB 380-30675/15

Matrix: Water

Analysis Batch: 30675

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	ug/L			01/25/23 19:55	1
1,1,1-Trichloroethane	ND		0.50	ug/L			01/25/23 19:55	1
1,1,2,2-Tetrachloroethane	ND		0.50	ug/L			01/25/23 19:55	1
1,1,2-Trichloroethane	ND		0.50	ug/L			01/25/23 19:55	1
1,1-Dichloroethane	ND		0.50	ug/L			01/25/23 19:55	1
1,1-Dichlorethylene	ND		0.50	ug/L			01/25/23 19:55	1
1,1-Dichloropropene	ND		0.50	ug/L			01/25/23 19:55	1
1,2,3-Trichlorobenzene	ND		0.50	ug/L			01/25/23 19:55	1
1,2,3-Trichloropropane	ND		0.50	ug/L			01/25/23 19:55	1
1,2,4-Trichlorobenzene	ND		0.50	ug/L			01/25/23 19:55	1
1,2,4-Trimethyl benzene	ND		0.50	ug/L			01/25/23 19:55	1
1,2-Dichloroethane	ND		0.50	ug/L			01/25/23 19:55	1
1,2-Dichloropropane	ND		0.50	ug/L			01/25/23 19:55	1
1,3,5-Trimethyl benzene	ND		0.50	ug/L			01/25/23 19:55	1
1,3-Dichloropropane	ND		0.50	ug/L			01/25/23 19:55	1
2,2-Dichloropropane	ND		0.50	ug/L			01/25/23 19:55	1
2-Butanone (MEK)	ND		5.0	ug/L			01/25/23 19:55	1
4-Methyl-2-pentanone (MIBK)	ND		5.0	ug/L			01/25/23 19:55	1
Acetone	ND		500	ug/L			01/25/23 19:55	1
Benzene	ND		0.50	ug/L			01/25/23 19:55	1
Bromobenzene	ND		0.50	ug/L			01/25/23 19:55	1
Bromochloromethane	ND		0.50	ug/L			01/25/23 19:55	1

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-30675/15

Matrix: Water

Analysis Batch: 30675

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Bromodichloromethane	ND		0.50	ug/L		01/25/23 19:55		1
Bromoform	ND		0.50	ug/L		01/25/23 19:55		1
Bromomethane (Methyl Bromide)	ND		0.50	ug/L		01/25/23 19:55		1
Carbon disulfide	ND		0.50	ug/L		01/25/23 19:55		1
Carbon tetrachloride	ND		0.50	ug/L		01/25/23 19:55		1
Chlorobenzene	ND		0.50	ug/L		01/25/23 19:55		1
Chlorodibromomethane	ND		0.50	ug/L		01/25/23 19:55		1
Chloroethane	ND		0.50	ug/L		01/25/23 19:55		1
Chloroform (Trichloromethane)	ND		0.50	ug/L		01/25/23 19:55		1
cis-1,2-Dichloroethylene	ND		0.50	ug/L		01/25/23 19:55		1
cis-1,3-Dichloropropene	ND		0.50	ug/L		01/25/23 19:55		1
Dibromomethane	ND		0.50	ug/L		01/25/23 19:55		1
Dichlorodifluoromethane	ND		0.50	ug/L		01/25/23 19:55		1
Dichloromethane	ND		0.50	ug/L		01/25/23 19:55		1
Ethylbenzene	ND		0.50	ug/L		01/25/23 19:55		1
Hexachlorobutadiene	ND		0.50	ug/L		01/25/23 19:55		1
Isopropyl benzene	ND		0.50	ug/L		01/25/23 19:55		1
m,p-Xylenes	ND		0.50	ug/L		01/25/23 19:55		1
m-Dichlorobenzene (1,3-DCB)	ND		0.50	ug/L		01/25/23 19:55		1
Methyl-tert-butyl Ether (MTBE)	ND		0.50	ug/L		01/25/23 19:55		1
Naphthalene	ND		0.50	ug/L		01/25/23 19:55		1
n-Butylbenzene	ND		0.50	ug/L		01/25/23 19:55		1
N-Propylbenzene	ND		0.50	ug/L		01/25/23 19:55		1
o-Chlorotoluene	ND		0.50	ug/L		01/25/23 19:55		1
o-Dichlorobenzene (1,2-DCB)	ND		0.50	ug/L		01/25/23 19:55		1
o-Xylene	ND		0.50	ug/L		01/25/23 19:55		1
p-Chlorotoluene	ND		0.50	ug/L		01/25/23 19:55		1
p-Dichlorobenzene (1,4-DCB)	ND		0.50	ug/L		01/25/23 19:55		1
p-Isopropyltoluene	ND		0.50	ug/L		01/25/23 19:55		1
sec-Butylbenzene	ND		0.50	ug/L		01/25/23 19:55		1
Styrene	ND		0.50	ug/L		01/25/23 19:55		1
Tert-amyl methyl ether	ND		3.0	ug/L		01/25/23 19:55		1
1,3-Dichloropropene, Total	ND		0.50	ug/L		01/25/23 19:55		1
Tert-butyl ethyl ether	ND		3.0	ug/L		01/25/23 19:55		1
tert-Butylbenzene	ND		0.50	ug/L		01/25/23 19:55		1
Tetrachloroethene (PCE)	ND		0.50	ug/L		01/25/23 19:55		1
Toluene	ND		0.50	ug/L		01/25/23 19:55		1
trans-1,2-Dichloroethylene	ND		0.50	ug/L		01/25/23 19:55		1
trans-1,3-Dichloropropene	ND		0.50	ug/L		01/25/23 19:55		1
Trichloroethylene (TCE)	ND		0.50	ug/L		01/25/23 19:55		1
Bromoethane	ND		0.50	ug/L		01/25/23 19:55		1
Trichlorofluoromethane (Freon 11)	ND		0.50	ug/L		01/25/23 19:55		1
Chloromethane (methyl chloride)	ND		0.50	ug/L		01/25/23 19:55		1
Trichlorotrifluoroethane	ND		0.50	ug/L		01/25/23 19:55		1
Diisopropyl ether	ND		3.0	ug/L		01/25/23 19:55		1
Vinyl Chloride (VC)	ND		0.30	ug/L		01/25/23 19:55		1
Xylenes, Total	ND		0.50	ug/L		01/25/23 19:55		1

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-30675/15

Matrix: Water

Analysis Batch: 30675

Client Sample ID: Method Blank
Prep Type: Total/NA

Tentatively Identified Compound	MB		Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
	Est. Result	MB Qualifier							
Tentatively Identified Compound	None		ug/L			N/A		01/25/23 19:55	1
Surrogate									
1,2-Dichloroethane-d4 (Surr)	111	%Recovery	MB Qualifier	Limits			Prepared	01/25/23 19:55	1
4-Bromofluorobenzene (Surr)	107			70 - 130				01/25/23 19:55	1
Toluene-d8 (Surr)	92			70 - 130				01/25/23 19:55	1

Lab Sample ID: LCS 380-30675/11

Matrix: Water

Analysis Batch: 30675

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS		Unit	D	%Rec	%Rec Limits
		Result	Qualifier				
1,1,1,2-Tetrachloroethane	5.00	5.40		ug/L		108	70 - 130
1,1,1-Trichloroethane	5.00	5.45		ug/L		109	70 - 130
1,1,2,2-Tetrachloroethane	5.00	5.56		ug/L		111	70 - 130
1,1,2-Trichloroethane	5.00	5.07		ug/L		101	70 - 130
1,1-Dichloroethane	5.00	5.16		ug/L		103	70 - 130
1,1-Dichlorethylene	5.00	5.01		ug/L		100	70 - 130
1,1-Dichloropropene	5.00	5.16		ug/L		103	70 - 130
1,2,3-Trichlorobenzene	5.00	5.90		ug/L		118	70 - 130
1,2,3-Trichloropropane	5.00	5.66		ug/L		113	70 - 130
1,2,4-Trichlorobenzene	5.00	5.62		ug/L		112	70 - 130
1,2,4-Trimethyl benzene	5.00	6.02		ug/L		120	70 - 130
1,2-Dichloroethane	5.00	5.32		ug/L		106	70 - 130
1,2-Dichloropropane	5.00	5.19		ug/L		104	70 - 130
1,3,5-Trimethyl benzene	5.00	5.70		ug/L		114	70 - 130
1,3-Dichloropropane	5.00	5.29		ug/L		106	70 - 130
2,2-Dichloropropane	5.00	4.30		ug/L		86	70 - 130
2-Butanone (MEK)	50.0	52.3		ug/L		105	70 - 130
4-Methyl-2-pentanone (MIBK)	50.0	52.6		ug/L		105	70 - 130
Acetone	50.0	45.1 J		ug/L		90	70 - 130
Benzene	5.00	5.41		ug/L		108	70 - 130
Bromobenzene	5.00	5.69		ug/L		114	70 - 130
Bromochloromethane	5.00	5.21		ug/L		104	70 - 130
Bromodichloromethane	5.00	5.53		ug/L		111	70 - 130
Bromoform	5.00	5.84		ug/L		117	70 - 130
Bromomethane (Methyl Bromide)	5.00	5.54		ug/L		111	70 - 130
Carbon disulfide	5.00	5.23		ug/L		105	70 - 130
Carbon tetrachloride	5.00	5.21		ug/L		104	70 - 130
Chlorobenzene	5.00	5.54		ug/L		111	70 - 130
Chlorodibromomethane	5.00	5.48		ug/L		110	70 - 130
cis-1,3-Dichloropropene	5.00	5.37		ug/L		107	70 - 130
Dichloromethane	5.00	5.52		ug/L		110	70 - 130
Ethylbenzene	5.00	5.48		ug/L		110	70 - 130
Hexachlorobutadiene	5.00	5.64		ug/L		113	70 - 130
Isopropyl benzene	5.00	6.17		ug/L		123	70 - 130
m,p-Xylenes	10.0	11.5		ug/L		115	70 - 130
m-Dichlorobenzene (1,3-DCB)	5.00	5.91		ug/L		118	70 - 130

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-30675/11

Matrix: Water

Analysis Batch: 30675

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Methyl-tert-butyl Ether (MTBE)	5.00	5.34		ug/L		107	70 - 130
Naphthalene	5.00	6.31		ug/L		126	70 - 130
n-Butylbenzene	5.00	5.47		ug/L		109	70 - 130
N-Propylbenzene	5.00	5.70		ug/L		114	70 - 130
o-Chlorotoluene	5.00	6.10		ug/L		122	70 - 130
o-Dichlorobenzene (1,2-DCB)	5.00	5.49		ug/L		110	70 - 130
o-Xylene	5.00	5.39		ug/L		108	70 - 130
p-Chlorotoluene	5.00	5.65		ug/L		113	70 - 130
p-Dichlorobenzene (1,4-DCB)	5.00	6.04		ug/L		121	70 - 130
p-Isopropyltoluene	5.00	5.73		ug/L		115	70 - 130
sec-Butylbenzene	5.00	5.71		ug/L		114	70 - 130
Styrene	5.00	5.20		ug/L		104	70 - 130
Tert-amyl methyl ether	5.00	5.43		ug/L		109	70 - 130
1,3-Dichloropropene, Total	10.0	10.6		ug/L		106	70 - 130
Tert-butyl ethyl ether	5.00	5.33		ug/L		107	70 - 130
tert-Butylbenzene	5.00	6.09		ug/L		122	70 - 130
Tetrachloroethylene (PCE)	5.00	5.13		ug/L		103	70 - 130
Toluene	5.00	5.43		ug/L		109	70 - 130
trans-1,2-Dichloroethylene	5.00	5.50		ug/L		110	70 - 130
trans-1,3-Dichloropropene	5.00	5.25		ug/L		105	70 - 130
Trichloroethylene (TCE)	5.00	5.08		ug/L		102	70 - 130
Bromoethane	5.00	5.13		ug/L		103	70 - 130
Trichlorofluoromethane (Freon 11)	5.00	6.02		ug/L		120	70 - 130
Trichlorotrifluoroethane	5.00	5.41		ug/L		108	70 - 130
Diisopropyl ether	5.00	5.08		ug/L		102	70 - 130
Vinyl Chloride (VC)	5.00	5.20		ug/L		104	70 - 130
Xylenes, Total	15.0	16.9		ug/L		113	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	98		70 - 130
4-Bromofluorobenzene (Surr)	108		70 - 130
Toluene-d8 (Surr)	99		70 - 130

Lab Sample ID: LCSD 380-30675/12

Matrix: Water

Analysis Batch: 30675

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD Limit
1,1,1,2-Tetrachloroethane	5.00	5.46		ug/L		109	70 - 130	1	20
1,1,1-Trichloroethane	5.00	5.35		ug/L		107	70 - 130	2	20
1,1,2,2-Tetrachloroethane	5.00	6.20		ug/L		124	70 - 130	11	20
1,1,2-Trichloroethane	5.00	5.22		ug/L		104	70 - 130	3	20
1,1-Dichloroethane	5.00	5.47		ug/L		109	70 - 130	6	20
1,1-Dichlorethylene	5.00	5.19		ug/L		104	70 - 130	3	20
1,1-Dichloropropene	5.00	5.33		ug/L		107	70 - 130	3	20
1,2,3-Trichlorobenzene	5.00	6.74 *+		ug/L		135	70 - 130	13	20
1,2,3-Trichloropropane	5.00	5.98		ug/L		120	70 - 130	6	20
1,2,4-Trichlorobenzene	5.00	6.29		ug/L		126	70 - 130	11	20

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 380-30675/12

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Matrix: Water

Analysis Batch: 30675

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD Limit
1,2,4-Trimethyl benzene	5.00	6.50		ug/L		130	70 - 130	8	20
1,2-Dichloroethane	5.00	5.53		ug/L		111	70 - 130	4	20
1,2-Dichloropropane	5.00	5.79		ug/L		116	70 - 130	11	20
1,3,5-Trimethyl benzene	5.00	6.03		ug/L		121	70 - 130	6	20
1,3-Dichloropropane	5.00	5.43		ug/L		109	70 - 130	2	20
2,2-Dichloropropane	5.00	4.23		ug/L		85	70 - 130	2	20
2-Butanone (MEK)	50.0	54.0		ug/L		108	70 - 130	3	20
4-Methyl-2-pentanone (MIBK)	50.0	54.7		ug/L		109	70 - 130	4	20
Acetone	50.0	55.6 J *1		ug/L		111	70 - 130	21	20
Benzene	5.00	5.73		ug/L		115	70 - 130	6	20
Bromobenzene	5.00	6.02		ug/L		120	70 - 130	6	20
Bromochloromethane	5.00	5.66		ug/L		113	70 - 130	8	20
Bromodichloromethane	5.00	5.65		ug/L		113	70 - 130	2	20
Bromoform	5.00	6.47		ug/L		129	70 - 130	10	20
Bromomethane (Methyl Bromide)	5.00	5.33		ug/L		107	70 - 130	4	20
Carbon disulfide	5.00	5.73		ug/L		115	70 - 130	9	20
Carbon tetrachloride	5.00	5.36		ug/L		107	70 - 130	3	20
Chlorobenzene	5.00	5.57		ug/L		111	70 - 130	1	20
Chlorodibromomethane	5.00	5.64		ug/L		113	70 - 130	3	20
cis-1,3-Dichloropropene	5.00	5.35		ug/L		107	70 - 130	0	20
Dichloromethane	5.00	5.68		ug/L		114	70 - 130	3	20
Ethylbenzene	5.00	5.35		ug/L		107	70 - 130	2	20
Hexachlorobutadiene	5.00	5.81		ug/L		116	70 - 130	3	20
Isopropyl benzene	5.00	6.29		ug/L		126	70 - 130	2	20
m,p-Xylenes	10.0	11.7		ug/L		117	70 - 130	2	20
m-Dichlorobenzene (1,3-DCB)	5.00	6.32		ug/L		126	70 - 130	7	20
Methyl-tert-butyl Ether (MTBE)	5.00	5.64		ug/L		113	70 - 130	5	20
Naphthalene	5.00	6.98 *+		ug/L		140	70 - 130	10	20
n-Butylbenzene	5.00	6.22		ug/L		124	70 - 130	13	20
N-Propylbenzene	5.00	5.64		ug/L		113	70 - 130	1	20
o-Chlorotoluene	5.00	6.27		ug/L		125	70 - 130	3	20
o-Dichlorobenzene (1,2-DCB)	5.00	6.11		ug/L		122	70 - 130	11	20
o-Xylene	5.00	5.45		ug/L		109	70 - 130	1	20
p-Chlorotoluene	5.00	5.86		ug/L		117	70 - 130	4	20
p-Dichlorobenzene (1,4-DCB)	5.00	6.46		ug/L		129	70 - 130	7	20
p-Isopropyltoluene	5.00	5.89		ug/L		118	70 - 130	3	20
sec-Butylbenzene	5.00	5.91		ug/L		118	70 - 130	3	20
Styrene	5.00	5.17		ug/L		103	70 - 130	1	20
Tert-amyl methyl ether	5.00	5.84		ug/L		117	70 - 130	7	20
1,3-Dichloropropene, Total	10.0	10.7		ug/L		107	70 - 130	0	20
Tert-butyl ethyl ether	5.00	5.72		ug/L		114	70 - 130	7	20
tert-Butylbenzene	5.00	6.48		ug/L		130	70 - 130	6	20
Tetrachloroethylene (PCE)	5.00	5.43		ug/L		109	70 - 130	6	20
Toluene	5.00	5.45		ug/L		109	70 - 130	0	20
trans-1,2-Dichloroethylene	5.00	5.59		ug/L		112	70 - 130	1	20
trans-1,3-Dichloropropene	5.00	5.31		ug/L		106	70 - 130	1	20
Trichloroethylene (TCE)	5.00	5.59		ug/L		112	70 - 130	10	20
Bromoethane	5.00	5.92		ug/L		118	70 - 130	14	20

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 380-30675/12

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Matrix: Water
Analysis Batch: 30675

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	RPD	RPD Limit
Trichlorofluoromethane (Freon 11)	5.00	6.21		ug/L	124	70 - 130	3	20
Trichlorotrifluoroethane	5.00	5.26		ug/L	105	70 - 130	3	20
Diisopropyl ether	5.00	5.48		ug/L	110	70 - 130	7	20
Vinyl Chloride (VC)	5.00	5.20		ug/L	104	70 - 130	0	20
Xylenes, Total	15.0	17.2		ug/L	114	70 - 130	1	20

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	96		70 - 130
4-Bromofluorobenzene (Surr)	101		70 - 130
Toluene-d8 (Surr)	100		70 - 130

Lab Sample ID: MRL 380-30675/10

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Matrix: Water
Analysis Batch: 30675

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	RPD	RPD Limit
m,p-Xylenes	0.500	0.556		ug/L	111	50 - 150		
Vinyl Chloride (VC)	0.250	0.295	J	ug/L	118	50 - 150		
Surrogate	MRL %Recovery	MRL Qualifier	Limits					
1,2-Dichloroethane-d4 (Surr)	97		70 - 130					
4-Bromofluorobenzene (Surr)	99		70 - 130					
Toluene-d8 (Surr)	92		70 - 130					

Lab Sample ID: MRL 380-30675/14

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Matrix: Water
Analysis Batch: 30675

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	RPD	RPD Limit
1,1,1,2-Tetrachloroethane	0.500	0.652		ug/L	130	50 - 150		
1,1,1-Trichloroethane	0.500	0.473	J	ug/L	95	50 - 150		
1,1,2,2-Tetrachloroethane	0.500	0.422	J	ug/L	84	50 - 150		
1,1,2-Trichloroethane	0.500	0.437	J	ug/L	87	50 - 150		
1,1-Dichloroethane	0.500	0.576		ug/L	115	50 - 150		
1,1-Dichlorethylene	0.500	0.622		ug/L	124	50 - 150		
1,1-Dichloropropene	0.500	0.512		ug/L	102	50 - 150		
1,2,3-Trichlorobenzene	0.500	0.511		ug/L	102	50 - 150		
1,2,3-Trichloropropane	0.500	0.425	J	ug/L	85	50 - 150		
1,2,4-Trichlorobenzene	0.500	0.540		ug/L	108	50 - 150		
1,2,4-Trimethyl benzene	0.500	0.477	J	ug/L	95	50 - 150		
1,2-Dichloroethane	0.500	0.527		ug/L	105	50 - 150		
1,2-Dichloropropane	0.500	0.555		ug/L	111	50 - 150		
1,3,5-Trimethyl benzene	0.500	0.624		ug/L	125	50 - 150		
1,3-Dichloropropane	0.500	0.383	J	ug/L	77	50 - 150		
2,2-Dichloropropane	0.500	0.420	J	ug/L	84	50 - 150		
2-Butanone (MEK)	5.00	3.32	J	ug/L	66	50 - 150		
4-Methyl-2-pentanone (MIBK)	5.00	4.36	J	ug/L	87	50 - 150		

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-30675/14

Matrix: Water

Analysis Batch: 30675

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
Acetone	5.00	ND	^3-	ug/L	0	50 - 150	
Benzene	0.500	0.505		ug/L	101	50 - 150	
Bromobenzene	0.500	0.576		ug/L	115	50 - 150	
Bromochloromethane	0.500	0.546		ug/L	109	50 - 150	
Bromodichloromethane	0.500	0.628		ug/L	126	50 - 150	
Bromoform	0.500	0.498	J	ug/L	100	50 - 150	
Bromomethane (Methyl Bromide)	0.500	0.505		ug/L	101	50 - 150	
Carbon disulfide	0.500	0.568		ug/L	114	50 - 150	
Carbon tetrachloride	0.500	0.526		ug/L	105	50 - 150	
Chlorobenzene	0.500	0.496	J	ug/L	99	50 - 150	
Chlorodibromomethane	0.500	0.642		ug/L	128	50 - 150	
cis-1,3-Dichloropropene	0.500	0.586		ug/L	117	50 - 150	
Dichloromethane	0.500	0.744		ug/L	149	50 - 150	
Ethylbenzene	0.500	0.631		ug/L	126	50 - 150	
Hexachlorobutadiene	0.500	0.589		ug/L	118	50 - 150	
Isopropyl benzene	0.500	0.584		ug/L	117	50 - 150	
m,p-Xylenes	1.00	0.798		ug/L	80	50 - 150	
m-Dichlorobenzene (1,3-DCB)	0.500	0.648		ug/L	130	50 - 150	
Methyl-tert-butyl Ether (MTBE)	0.500	0.443	J	ug/L	89	50 - 150	
Naphthalene	0.500	0.398	J	ug/L	80	50 - 150	
n-Butylbenzene	0.500	0.497	J	ug/L	99	50 - 150	
N-Propylbenzene	0.500	0.450	J	ug/L	90	50 - 150	
o-Chlorotoluene	0.500	0.612		ug/L	122	50 - 150	
o-Dichlorobenzene (1,2-DCB)	0.500	0.519		ug/L	104	50 - 150	
o-Xylene	0.500	0.605		ug/L	121	50 - 150	
p-Chlorotoluene	0.500	0.449	J	ug/L	90	50 - 150	
p-Dichlorobenzene (1,4-DCB)	0.500	0.671		ug/L	134	50 - 150	
p-Isopropyltoluene	0.500	0.667		ug/L	133	50 - 150	
sec-Butylbenzene	0.500	0.717		ug/L	143	50 - 150	
Styrene	0.500	0.566		ug/L	113	50 - 150	
Tert-amyl methyl ether	0.500	0.383	J	ug/L	77	50 - 150	
1,3-Dichloropropene, Total	1.00	1.18		ug/L	118	50 - 150	
Tert-butyl ethyl ether	0.500	0.491	J	ug/L	98	50 - 150	
tert-Butylbenzene	0.500	0.547		ug/L	109	50 - 150	
Tetrachloroethylene (PCE)	0.500	0.524		ug/L	105	50 - 150	
Toluene	0.500	0.614		ug/L	123	50 - 150	
trans-1,2-Dichloroethylene	0.500	0.564		ug/L	113	50 - 150	
trans-1,3-Dichloropropene	0.500	0.589		ug/L	118	50 - 150	
Trichloroethylene (TCE)	0.500	0.479	J	ug/L	96	50 - 150	
Bromoethane	0.500	0.695		ug/L	139	50 - 150	
Trichlorofluoromethane (Freon 11)	0.500	0.545		ug/L	109	50 - 150	
Trichlorotrifluoroethane	0.500	0.507		ug/L	101	50 - 150	
Diisopropyl ether	0.500	0.516	J	ug/L	103	50 - 150	
Vinyl Chloride (VC)	0.500	0.489		ug/L	98	50 - 150	
Xylenes, Total	1.50	1.40		ug/L	94	50 - 150	

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-30675/14

Matrix: Water

Analysis Batch: 30675

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Surrogate	MRL %Recovery	MRL Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	96		70 - 130
4-Bromofluorobenzene (Surr)	130		70 - 130
Toluene-d8 (Surr)	97		70 - 130

Lab Sample ID: MB 380-30695/5

Matrix: Water

Analysis Batch: 30695

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	ug/L			01/26/23 04:53	1
1,1,1-Trichloroethane	ND		0.50	ug/L			01/26/23 04:53	1
1,1,2,2-Tetrachloroethane	ND		0.50	ug/L			01/26/23 04:53	1
1,1,2-Trichloroethane	ND		0.50	ug/L			01/26/23 04:53	1
1,1-Dichloroethane	ND		0.50	ug/L			01/26/23 04:53	1
1,1-Dichlorethylene	ND		0.50	ug/L			01/26/23 04:53	1
1,1-Dichloropropene	ND		0.50	ug/L			01/26/23 04:53	1
1,2,3-Trichlorobenzene	0.721	B	0.50	ug/L			01/26/23 04:53	1
1,2,3-Trichloropropane	ND		0.50	ug/L			01/26/23 04:53	1
1,2,4-Trichlorobenzene	ND		0.50	ug/L			01/26/23 04:53	1
1,2,4-Trimethyl benzene	ND		0.50	ug/L			01/26/23 04:53	1
1,2-Dichloroethane	ND		0.50	ug/L			01/26/23 04:53	1
1,2-Dichloropropane	ND		0.50	ug/L			01/26/23 04:53	1
1,3,5-Trimethyl benzene	ND		0.50	ug/L			01/26/23 04:53	1
1,3-Dichloropropane	ND		0.50	ug/L			01/26/23 04:53	1
2,2-Dichloropropane	ND		0.50	ug/L			01/26/23 04:53	1
2-Butanone (MEK)	ND		5.0	ug/L			01/26/23 04:53	1
4-Methyl-2-pentanone (MIBK)	ND		5.0	ug/L			01/26/23 04:53	1
Acetone	ND		500	ug/L			01/26/23 04:53	1
Benzene	ND		0.50	ug/L			01/26/23 04:53	1
Bromobenzene	ND		0.50	ug/L			01/26/23 04:53	1
Bromochloromethane	ND		0.50	ug/L			01/26/23 04:53	1
Bromodichloromethane	ND		0.50	ug/L			01/26/23 04:53	1
Bromoform	ND		0.50	ug/L			01/26/23 04:53	1
Bromomethane (Methyl Bromide)	ND		0.50	ug/L			01/26/23 04:53	1
Carbon disulfide	ND		0.50	ug/L			01/26/23 04:53	1
Carbon tetrachloride	ND		0.50	ug/L			01/26/23 04:53	1
Chlorobenzene	ND		0.50	ug/L			01/26/23 04:53	1
Chlorodibromomethane	ND		0.50	ug/L			01/26/23 04:53	1
Chloroethane	ND		0.50	ug/L			01/26/23 04:53	1
Chloroform (Trichloromethane)	ND		0.50	ug/L			01/26/23 04:53	1
cis-1,2-Dichloroethylene	ND		0.50	ug/L			01/26/23 04:53	1
cis-1,3-Dichloropropene	ND		0.50	ug/L			01/26/23 04:53	1
Dibromomethane	ND		0.50	ug/L			01/26/23 04:53	1
Dichlorodifluoromethane	ND		0.50	ug/L			01/26/23 04:53	1
Dichlormethane	ND		0.50	ug/L			01/26/23 04:53	1
Ethylbenzene	ND		0.50	ug/L			01/26/23 04:53	1
Hexachlorobutadiene	ND		0.50	ug/L			01/26/23 04:53	1
Isopropyl benzene	ND		0.50	ug/L			01/26/23 04:53	1

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-30695/5

Matrix: Water

Analysis Batch: 30695

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
m,p-Xylenes	ND		0.50	ug/L		01/26/23 04:53		1
m-Dichlorobenzene (1,3-DCB)	ND		0.50	ug/L		01/26/23 04:53		1
Methyl-tert-butyl Ether (MTBE)	ND		0.50	ug/L		01/26/23 04:53		1
Naphthalene	0.629	B	0.50	ug/L		01/26/23 04:53		1
n-Butylbenzene	ND		0.50	ug/L		01/26/23 04:53		1
N-Propylbenzene	ND		0.50	ug/L		01/26/23 04:53		1
o-Chlorotoluene	ND		0.50	ug/L		01/26/23 04:53		1
o-Dichlorobenzene (1,2-DCB)	ND		0.50	ug/L		01/26/23 04:53		1
o-Xylene	ND		0.50	ug/L		01/26/23 04:53		1
p-Chlorotoluene	ND		0.50	ug/L		01/26/23 04:53		1
p-Dichlorobenzene (1,4-DCB)	ND		0.50	ug/L		01/26/23 04:53		1
p-Isopropyltoluene	ND		0.50	ug/L		01/26/23 04:53		1
sec-Butylbenzene	ND		0.50	ug/L		01/26/23 04:53		1
Styrene	ND		0.50	ug/L		01/26/23 04:53		1
Tert-amyl methyl ether	ND		3.0	ug/L		01/26/23 04:53		1
1,3-Dichloropropene, Total	ND		0.50	ug/L		01/26/23 04:53		1
Tert-butyl ethyl ether	ND		3.0	ug/L		01/26/23 04:53		1
tert-Butylbenzene	ND		0.50	ug/L		01/26/23 04:53		1
Tetrachloroethylene (PCE)	ND		0.50	ug/L		01/26/23 04:53		1
Toluene	ND		0.50	ug/L		01/26/23 04:53		1
trans-1,2-Dichloroethylene	ND		0.50	ug/L		01/26/23 04:53		1
trans-1,3-Dichloropropene	ND		0.50	ug/L		01/26/23 04:53		1
Trichloroethylene (TCE)	ND		0.50	ug/L		01/26/23 04:53		1
Bromoethane	ND		0.50	ug/L		01/26/23 04:53		1
Trichlorofluoromethane (Freon 11)	ND		0.50	ug/L		01/26/23 04:53		1
Chloromethane (methyl chloride)	ND		0.50	ug/L		01/26/23 04:53		1
Trichlorotrifluoroethane	ND		0.50	ug/L		01/26/23 04:53		1
Diisopropyl ether	ND		3.0	ug/L		01/26/23 04:53		1
Vinyl Chloride (VC)	ND		0.30	ug/L		01/26/23 04:53		1
Xylenes, Total	ND		0.50	ug/L		01/26/23 04:53		1

MB Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A		01/26/23 04:53	1

MB Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		70 - 130		01/26/23 04:53	1
4-Bromofluorobenzene (Surr)	129		70 - 130		01/26/23 04:53	1
Toluene-d8 (Surr)	95		70 - 130		01/26/23 04:53	1

Lab Sample ID: LCS 380-30695/3

Matrix: Water

Analysis Batch: 30695

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
1,1,1,2-Tetrachloroethane	5.00	5.70		ug/L		114	70 - 130
1,1,1-Trichloroethane	5.00	5.95		ug/L		119	70 - 130
1,1,2,2-Tetrachloroethane	5.00	4.40		ug/L		88	70 - 130
1,1,2-Trichloroethane	5.00	4.53		ug/L		91	70 - 130

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-30695/3

Matrix: Water

Analysis Batch: 30695

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
1,1-Dichloroethane	5.00	5.81		ug/L		116	70 - 130
1,1-Dichlorethylene	5.00	5.60		ug/L		112	70 - 130
1,1-Dichloropropene	5.00	4.86		ug/L		97	70 - 130
1,2,3-Trichlorobenzene	5.00	4.64		ug/L		93	70 - 130
1,2,3-Trichloropropane	5.00	4.32		ug/L		86	70 - 130
1,2,4-Trichlorobenzene	5.00	4.84		ug/L		97	70 - 130
1,2,4-Trimethyl benzene	5.00	6.98 *+		ug/L		140	70 - 130
1,2-Dichloroethane	5.00	4.98		ug/L		100	70 - 130
1,2-Dichloropropane	5.00	5.37		ug/L		107	70 - 130
1,3,5-Trimethyl benzene	5.00	6.59 *+		ug/L		132	70 - 130
1,3-Dichloropropane	5.00	4.61		ug/L		92	70 - 130
2,2-Dichloropropane	5.00	5.13		ug/L		103	70 - 130
2-Butanone (MEK)	50.0	30.6 *-		ug/L		61	70 - 130
4-Methyl-2-pentanone (MIBK)	50.0	31.0 *-		ug/L		62	70 - 130
Acetone	50.0	36.7 J		ug/L		73	70 - 130
Benzene	5.00	5.37		ug/L		107	70 - 130
Bromobenzene	5.00	6.29		ug/L		126	70 - 130
Bromoform	5.00	5.32		ug/L		106	70 - 130
Bromochloromethane	5.00	6.07		ug/L		121	70 - 130
Bromodichloromethane	5.00	6.13		ug/L		123	70 - 130
Bromoform	5.00	5.71		ug/L		114	70 - 130
Carbon disulfide	5.00	7.38 *+		ug/L		148	70 - 130
Carbon tetrachloride	5.00	5.91		ug/L		118	70 - 130
Chlorobenzene	5.00	5.54		ug/L		111	70 - 130
Chlorodibromomethane	5.00	5.59		ug/L		112	70 - 130
cis-1,3-Dichloropropene	5.00	5.26		ug/L		105	70 - 130
Dichloromethane	5.00	5.98		ug/L		120	70 - 130
Ethylbenzene	5.00	5.37		ug/L		107	70 - 130
Hexachlorobutadiene	5.00	5.23		ug/L		105	70 - 130
Isopropyl benzene	5.00	6.97 *+		ug/L		139	70 - 130
m,p-Xylenes	10.0	11.8		ug/L		118	70 - 130
m-Dichlorobenzene (1,3-DCB)	5.00	6.61 *+		ug/L		132	70 - 130
Methyl-tert-butyl Ether (MTBE)	5.00	4.45		ug/L		89	70 - 130
Naphthalene	5.00	4.03		ug/L		81	70 - 130
n-Butylbenzene	5.00	5.46		ug/L		109	70 - 130
N-Propylbenzene	5.00	5.74		ug/L		115	70 - 130
o-Chlorotoluene	5.00	6.75 *+		ug/L		135	70 - 130
o-Dichlorobenzene (1,2-DCB)	5.00	5.16		ug/L		103	70 - 130
o-Xylene	5.00	5.66		ug/L		113	70 - 130
p-Chlorotoluene	5.00	5.77		ug/L		115	70 - 130
p-Dichlorobenzene (1,4-DCB)	5.00	6.73 *+		ug/L		135	70 - 130
p-Isopropyltoluene	5.00	6.32		ug/L		126	70 - 130
sec-Butylbenzene	5.00	6.24		ug/L		125	70 - 130
Styrene	5.00	5.32		ug/L		106	70 - 130
Tert-amyl methyl ether	5.00	4.17		ug/L		83	70 - 130
1,3-Dichloropropene, Total	10.0	10.2		ug/L		102	70 - 130
Tert-butyl ethyl ether	5.00	5.09		ug/L		102	70 - 130
tert-Butylbenzene	5.00	6.79 *+		ug/L		136	70 - 130
Tetrachloroethylene (PCE)	5.00	5.33		ug/L		107	70 - 130

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-30695/3

Matrix: Water

Analysis Batch: 30695

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Toluene	5.00	5.32		ug/L		106	70 - 130
trans-1,2-Dichloroethylene	5.00	5.87		ug/L		117	70 - 130
trans-1,3-Dichloropropene	5.00	4.95		ug/L		99	70 - 130
Trichloroethylene (TCE)	5.00	5.18		ug/L		104	70 - 130
Bromoethane	5.00	7.38	*+	ug/L		148	70 - 130
Trichlorofluoromethane (Freon 11)	5.00	5.73		ug/L		115	70 - 130
Trichlorotrifluoroethane	5.00	6.10		ug/L		122	70 - 130
Diisopropyl ether	5.00	5.54		ug/L		111	70 - 130
Vinyl Chloride (VC)	5.00	5.77		ug/L		115	70 - 130
Xylenes, Total	15.0	17.4		ug/L		116	70 - 130

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	96		70 - 130
4-Bromofluorobenzene (Surr)	129		70 - 130
Toluene-d8 (Surr)	107		70 - 130

Lab Sample ID: LCSD 380-30695/4

Matrix: Water

Analysis Batch: 30695

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD Limit
1,1,1,2-Tetrachloroethane	5.00	5.81		ug/L		116	70 - 130	2	20
1,1,1-Trichloroethane	5.00	6.33		ug/L		127	70 - 130	6	20
1,1,2,2-Tetrachloroethane	5.00	4.72		ug/L		94	70 - 130	7	20
1,1,2-Trichloroethane	5.00	4.55		ug/L		91	70 - 130	0	20
1,1-Dichloroethane	5.00	6.02		ug/L		120	70 - 130	4	20
1,1-Dichlorethylene	5.00	5.95		ug/L		119	70 - 130	6	20
1,1-Dichloropropene	5.00	5.19		ug/L		104	70 - 130	7	20
1,2,3-Trichlorobenzene	5.00	4.95		ug/L		99	70 - 130	6	20
1,2,3-Trichloropropane	5.00	4.59		ug/L		92	70 - 130	6	20
1,2,4-Trichlorobenzene	5.00	5.51		ug/L		110	70 - 130	13	20
1,2,4-Trimethyl benzene	5.00	7.59	*+	ug/L		152	70 - 130	8	20
1,2-Dichloroethane	5.00	5.40		ug/L		108	70 - 130	8	20
1,2-Dichloropropane	5.00	5.44		ug/L		109	70 - 130	1	20
1,3,5-Trimethyl benzene	5.00	7.19	*+	ug/L		144	70 - 130	9	20
1,3-Dichloropropane	5.00	4.64		ug/L		93	70 - 130	1	20
2,2-Dichloropropane	5.00	5.90		ug/L		118	70 - 130	14	20
2-Butanone (MEK)	50.0	30.5	*-	ug/L		61	70 - 130	0	20
4-Methyl-2-pentanone (MIBK)	50.0	31.0	*-	ug/L		62	70 - 130	0	20
Acetone	50.0	35.7	J	ug/L		71	70 - 130	3	20
Benzene	5.00	5.63		ug/L		113	70 - 130	5	20
Bromobenzene	5.00	6.99	*+	ug/L		140	70 - 130	11	20
Bromochloromethane	5.00	5.68		ug/L		114	70 - 130	7	20
Bromodichloromethane	5.00	6.41		ug/L		128	70 - 130	5	20
Bromoform	5.00	6.19		ug/L		124	70 - 130	1	20
Bromomethane (Methyl Bromide)	5.00	6.13		ug/L		123	70 - 130	7	20
Carbon disulfide	5.00	7.99	*+	ug/L		160	70 - 130	8	20
Carbon tetrachloride	5.00	6.23		ug/L		125	70 - 130	5	20

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 380-30695/4

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Matrix: Water

Analysis Batch: 30695

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD RPD	RPD Limit
Chlorobenzene	5.00	5.70		ug/L	114	70 - 130	3	20	
Chlorodibromomethane	5.00	5.67		ug/L	113	70 - 130	1	20	
cis-1,3-Dichloropropene	5.00	5.60		ug/L	112	70 - 130	6	20	
Dichloromethane	5.00	6.35		ug/L	127	70 - 130	6	20	
Ethylbenzene	5.00	5.59		ug/L	112	70 - 130	4	20	
Hexachlorobutadiene	5.00	5.43		ug/L	109	70 - 130	4	20	
Isopropyl benzene	5.00	7.78 *+		ug/L	156	70 - 130	11	20	
m,p-Xylenes	10.0	12.2		ug/L	122	70 - 130	4	20	
m-Dichlorobenzene (1,3-DCB)	5.00	7.38 *+		ug/L	148	70 - 130	11	20	
Methyl-tert-butyl Ether (MTBE)	5.00	4.67		ug/L	93	70 - 130	5	20	
Naphthalene	5.00	4.07		ug/L	81	70 - 130	1	20	
n-Butylbenzene	5.00	6.41		ug/L	128	70 - 130	16	20	
N-Propylbenzene	5.00	6.02		ug/L	120	70 - 130	5	20	
o-Chlorotoluene	5.00	7.69 *+		ug/L	154	70 - 130	13	20	
o-Dichlorobenzene (1,2-DCB)	5.00	5.95		ug/L	119	70 - 130	14	20	
o-Xylene	5.00	5.83		ug/L	117	70 - 130	3	20	
p-Chlorotoluene	5.00	5.93		ug/L	119	70 - 130	3	20	
p-Dichlorobenzene (1,4-DCB)	5.00	7.28 *+		ug/L	146	70 - 130	8	20	
p-Isopropyltoluene	5.00	7.01 *+		ug/L	140	70 - 130	10	20	
sec-Butylbenzene	5.00	6.98 *+		ug/L	140	70 - 130	11	20	
Styrene	5.00	5.43		ug/L	109	70 - 130	2	20	
Tert-amyl methyl ether	5.00	4.32		ug/L	86	70 - 130	4	20	
1,3-Dichloropropene, Total	10.0	10.5		ug/L	105	70 - 130	3	20	
Tert-butyl ethyl ether	5.00	5.27		ug/L	105	70 - 130	3	20	
tert-Butylbenzene	5.00	7.58 *+		ug/L	152	70 - 130	11	20	
Tetrachloroethylene (PCE)	5.00	5.47		ug/L	109	70 - 130	3	20	
Toluene	5.00	5.66		ug/L	113	70 - 130	6	20	
trans-1,2-Dichloroethylene	5.00	6.27		ug/L	125	70 - 130	7	20	
trans-1,3-Dichloropropene	5.00	4.93		ug/L	99	70 - 130	0	20	
Trichloroethylene (TCE)	5.00	5.51		ug/L	110	70 - 130	6	20	
Bromoethane	5.00	7.81 *+		ug/L	156	70 - 130	6	20	
Trichlorofluoromethane (Freon 11)	5.00	6.14		ug/L	123	70 - 130	7	20	
Trichlorotrifluoroethane	5.00	6.19		ug/L	124	70 - 130	2	20	
Diisopropyl ether	5.00	5.75		ug/L	115	70 - 130	4	20	
Vinyl Chloride (VC)	5.00	6.27		ug/L	125	70 - 130	8	20	
Xylenes, Total	15.0	18.1		ug/L	120	70 - 130	4	20	

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	99		70 - 130
4-Bromofluorobenzene (Surr)	120		70 - 130
Toluene-d8 (Surr)	101		70 - 130

Lab Sample ID: MB 380-30956/8

Client Sample ID: Method Blank
Prep Type: Total/NA

Matrix: Water

Analysis Batch: 30956

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	ug/L		01/30/23 14:05		1

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-30956/8

Matrix: Water

Analysis Batch: 30956

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1-Trichloroethane	ND		0.50	ug/L		01/30/23 14:05		1
1,1,2,2-Tetrachloroethane	ND		0.50	ug/L		01/30/23 14:05		1
1,1,2-Trichloroethane	ND		0.50	ug/L		01/30/23 14:05		1
1,1-Dichloroethane	ND		0.50	ug/L		01/30/23 14:05		1
1,1-Dichlorethylene	ND		0.50	ug/L		01/30/23 14:05		1
1,1-Dichloropropene	ND		0.50	ug/L		01/30/23 14:05		1
1,2,3-Trichlorobenzene	ND		0.50	ug/L		01/30/23 14:05		1
1,2,3-Trichloropropane	ND		0.50	ug/L		01/30/23 14:05		1
1,2,4-Trichlorobenzene	ND		0.50	ug/L		01/30/23 14:05		1
1,2,4-Trimethyl benzene	ND		0.50	ug/L		01/30/23 14:05		1
1,2-Dichloroethane	ND		0.50	ug/L		01/30/23 14:05		1
1,2-Dichloropropane	ND		0.50	ug/L		01/30/23 14:05		1
1,3,5-Trimethyl benzene	ND		0.50	ug/L		01/30/23 14:05		1
1,3-Dichloropropane	ND		0.50	ug/L		01/30/23 14:05		1
2,2-Dichloropropane	ND		0.50	ug/L		01/30/23 14:05		1
2-Butanone (MEK)	ND		5.0	ug/L		01/30/23 14:05		1
4-Methyl-2-pentanone (MIBK)	ND		5.0	ug/L		01/30/23 14:05		1
Acetone	ND		500	ug/L		01/30/23 14:05		1
Benzene	ND		0.50	ug/L		01/30/23 14:05		1
Bromobenzene	ND		0.50	ug/L		01/30/23 14:05		1
Bromochloromethane	ND		0.50	ug/L		01/30/23 14:05		1
Bromodichloromethane	ND		0.50	ug/L		01/30/23 14:05		1
Bromoform	ND		0.50	ug/L		01/30/23 14:05		1
Bromomethane (Methyl Bromide)	ND		0.50	ug/L		01/30/23 14:05		1
Carbon disulfide	ND		0.50	ug/L		01/30/23 14:05		1
Carbon tetrachloride	ND		0.50	ug/L		01/30/23 14:05		1
Chlorobenzene	ND		0.50	ug/L		01/30/23 14:05		1
Chlorodibromomethane	ND		0.50	ug/L		01/30/23 14:05		1
Chloroethane	ND		0.50	ug/L		01/30/23 14:05		1
Chloroform (Trichloromethane)	ND		0.50	ug/L		01/30/23 14:05		1
cis-1,2-Dichloroethylene	ND		0.50	ug/L		01/30/23 14:05		1
cis-1,3-Dichloropropene	ND		0.50	ug/L		01/30/23 14:05		1
Dibromomethane	ND		0.50	ug/L		01/30/23 14:05		1
Dichlorodifluoromethane	ND		0.50	ug/L		01/30/23 14:05		1
Dichloromethane	ND		0.50	ug/L		01/30/23 14:05		1
Ethylbenzene	ND		0.50	ug/L		01/30/23 14:05		1
Hexachlorobutadiene	ND		0.50	ug/L		01/30/23 14:05		1
Isopropyl benzene	ND		0.50	ug/L		01/30/23 14:05		1
m,p-Xylenes	ND		0.50	ug/L		01/30/23 14:05		1
m-Dichlorobenzene (1,3-DCB)	ND		0.50	ug/L		01/30/23 14:05		1
Methyl-tert-butyl Ether (MTBE)	ND		0.50	ug/L		01/30/23 14:05		1
Naphthalene	ND		0.50	ug/L		01/30/23 14:05		1
n-Butylbenzene	ND		0.50	ug/L		01/30/23 14:05		1
N-Propylbenzene	ND		0.50	ug/L		01/30/23 14:05		1
o-Chlorotoluene	ND		0.50	ug/L		01/30/23 14:05		1
o-Dichlorobenzene (1,2-DCB)	ND		0.50	ug/L		01/30/23 14:05		1
o-Xylene	ND		0.50	ug/L		01/30/23 14:05		1
p-Chlorotoluene	ND		0.50	ug/L		01/30/23 14:05		1
p-Dichlorobenzene (1,4-DCB)	ND		0.50	ug/L		01/30/23 14:05		1

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-30956/8

Matrix: Water

Analysis Batch: 30956

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
p-Isopropyltoluene	ND		0.50	ug/L		01/30/23 14:05		1
sec-Butylbenzene	ND		0.50	ug/L		01/30/23 14:05		1
Styrene	ND		0.50	ug/L		01/30/23 14:05		1
Tert-amyl methyl ether	ND		3.0	ug/L		01/30/23 14:05		1
1,3-Dichloropropene, Total	ND		0.50	ug/L		01/30/23 14:05		1
Tert-butyl ethyl ether	ND		3.0	ug/L		01/30/23 14:05		1
tert-Butylbenzene	ND		0.50	ug/L		01/30/23 14:05		1
Tetrachloroethylene (PCE)	ND		0.50	ug/L		01/30/23 14:05		1
Toluene	ND		0.50	ug/L		01/30/23 14:05		1
trans-1,2-Dichloroethylene	ND		0.50	ug/L		01/30/23 14:05		1
trans-1,3-Dichloropropene	ND		0.50	ug/L		01/30/23 14:05		1
Trichloroethylene (TCE)	ND		0.50	ug/L		01/30/23 14:05		1
Bromoethane	ND		0.50	ug/L		01/30/23 14:05		1
Trichlorofluoromethane (Freon 11)	ND		0.50	ug/L		01/30/23 14:05		1
Chloromethane (methyl chloride)	ND		0.50	ug/L		01/30/23 14:05		1
Trichlorotrifluoroethane	ND		0.50	ug/L		01/30/23 14:05		1
Diisopropyl ether	ND		3.0	ug/L		01/30/23 14:05		1
Vinyl Chloride (VC)	ND		0.30	ug/L		01/30/23 14:05		1
Xylenes, Total	ND		0.50	ug/L		01/30/23 14:05		1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A		01/30/23 14:05	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		70 - 130		01/30/23 14:05	1
4-Bromofluorobenzene (Surr)	92		70 - 130		01/30/23 14:05	1
Toluene-d8 (Surr)	79		70 - 130		01/30/23 14:05	1

Lab Sample ID: LCS 380-30956/4

Matrix: Water

Analysis Batch: 30956

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,1,1,2-Tetrachloroethane	5.00	5.10		ug/L		102	70 - 130
1,1,1-Trichloroethane	5.00	5.15		ug/L		103	70 - 130
1,1,2,2-Tetrachloroethane	5.00	4.99		ug/L		100	70 - 130
1,1,2-Trichloroethane	5.00	4.80		ug/L		96	70 - 130
1,1-Dichloroethane	5.00	4.97		ug/L		99	70 - 130
1,1-Dichlorethylene	5.00	4.83		ug/L		97	70 - 130
1,1-Dichloropropene	5.00	4.90		ug/L		98	70 - 130
1,2,3-Trichlorobenzene	5.00	4.81		ug/L		96	70 - 130
1,2,3-Trichloropropane	5.00	4.83		ug/L		97	70 - 130
1,2,4-Trichlorobenzene	5.00	4.61		ug/L		92	70 - 130
1,2,4-Trimethyl benzene	5.00	5.31		ug/L		106	70 - 130
1,2-Dichloroethane	5.00	5.11		ug/L		102	70 - 130
1,2-Dichloropropane	5.00	4.99		ug/L		100	70 - 130
1,3,5-Trimethyl benzene	5.00	5.25		ug/L		105	70 - 130
1,3-Dichloropropane	5.00	5.00		ug/L		100	70 - 130

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-30956/4

Matrix: Water

Analysis Batch: 30956

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
2,2-Dichloropropane	5.00	6.19		ug/L	124	70 - 130	
2-Butanone (MEK)	50.0	41.6		ug/L	83	70 - 130	
4-Methyl-2-pentanone (MIBK)	50.0	51.4		ug/L	103	70 - 130	
Acetone	50.0	45.4	J	ug/L	91	70 - 130	
Benzene	5.00	5.10		ug/L	102	70 - 130	
Bromobenzene	5.00	4.94		ug/L	99	70 - 130	
Bromochloromethane	5.00	5.19		ug/L	104	70 - 130	
Bromodichloromethane	5.00	5.19		ug/L	104	70 - 130	
Bromoform	5.00	5.65		ug/L	113	70 - 130	
Bromomethane (Methyl Bromide)	5.00	5.03		ug/L	101	70 - 130	
Carbon disulfide	5.00	4.90		ug/L	98	70 - 130	
Carbon tetrachloride	5.00	5.12		ug/L	102	70 - 130	
Chlorobenzene	5.00	5.06		ug/L	101	70 - 130	
Chlorodibromomethane	5.00	5.25		ug/L	105	70 - 130	
cis-1,3-Dichloropropene	5.00	4.99		ug/L	100	70 - 130	
Dichloromethane	5.00	4.90		ug/L	98	70 - 130	
Ethylbenzene	5.00	5.11		ug/L	102	70 - 130	
Hexachlorobutadiene	5.00	5.02		ug/L	100	70 - 130	
Isopropyl benzene	5.00	5.01		ug/L	100	70 - 130	
m,p-Xylenes	10.0	11.0		ug/L	110	70 - 130	
m-Dichlorobenzene (1,3-DCB)	5.00	5.09		ug/L	102	70 - 130	
Methyl-tert-butyl Ether (MTBE)	5.00	5.54		ug/L	111	70 - 130	
Naphthalene	5.00	4.43		ug/L	89	70 - 130	
n-Butylbenzene	5.00	5.05		ug/L	101	70 - 130	
N-Propylbenzene	5.00	5.24		ug/L	105	70 - 130	
o-Chlorotoluene	5.00	5.17		ug/L	103	70 - 130	
o-Dichlorobenzene (1,2-DCB)	5.00	4.86		ug/L	97	70 - 130	
o-Xylene	5.00	5.13		ug/L	103	70 - 130	
p-Chlorotoluene	5.00	5.38		ug/L	108	70 - 130	
p-Dichlorobenzene (1,4-DCB)	5.00	5.18		ug/L	104	70 - 130	
p-Isopropyltoluene	5.00	5.40		ug/L	108	70 - 130	
sec-Butylbenzene	5.00	5.32		ug/L	106	70 - 130	
Styrene	5.00	5.28		ug/L	106	70 - 130	
Tert-amyl methyl ether	5.00	5.90		ug/L	118	70 - 130	
1,3-Dichloropropene, Total	10.0	10.8		ug/L	108	70 - 130	
Tert-butyl ethyl ether	5.00	5.65		ug/L	113	70 - 130	
tert-Butylbenzene	5.00	5.10		ug/L	102	70 - 130	
Tetrachloroethylene (PCE)	5.00	4.98		ug/L	100	70 - 130	
Toluene	5.00	5.16		ug/L	103	70 - 130	
trans-1,2-Dichloroethylene	5.00	5.01		ug/L	100	70 - 130	
trans-1,3-Dichloropropene	5.00	5.79		ug/L	116	70 - 130	
Trichloroethylene (TCE)	5.00	5.23		ug/L	105	70 - 130	
Bromoethane	5.00	4.72		ug/L	94	70 - 130	
Trichlorofluoromethane (Freon 11)	5.00	5.18		ug/L	104	70 - 130	
Trichlorotrifluoroethane	5.00	4.73		ug/L	95	70 - 130	
Diisopropyl ether	5.00	4.95		ug/L	99	70 - 130	
Vinyl Chloride (VC)	5.00	4.78		ug/L	96	70 - 130	
Xylenes, Total	15.0	16.1		ug/L	108	70 - 130	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Surrogate	LCS	LCS	
	%Recovery	Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	99		70 - 130
4-Bromofluorobenzene (Surr)	99		70 - 130
Toluene-d8 (Surr)	102		70 - 130

Lab Sample ID: LCSD 380-30956/5

Matrix: Water

Analysis Batch: 30956

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte		Spike	LCSD	LCSD	Unit	D	%Rec	%Rec	RPD	RPD	Limit
		Added	Result	Qualifier							
1,1,1,2-Tetrachloroethane		5.00	4.76		ug/L		95	70 - 130	7	20	
1,1,1-Trichloroethane		5.00	4.59		ug/L		92	70 - 130	11	20	
1,1,2,2-Tetrachloroethane		5.00	4.98		ug/L		100	70 - 130	0	20	
1,1,2-Trichloroethane		5.00	4.74		ug/L		95	70 - 130	1	20	
1,1-Dichloroethane		5.00	4.48		ug/L		90	70 - 130	10	20	
1,1-Dichlorethylene		5.00	4.48		ug/L		90	70 - 130	8	20	
1,1-Dichloropropene		5.00	4.54		ug/L		91	70 - 130	8	20	
1,2,3-Trichlorobenzene		5.00	5.15		ug/L		103	70 - 130	7	20	
1,2,3-Trichloropropane		5.00	4.86		ug/L		97	70 - 130	1	20	
1,2,4-Trichlorobenzene		5.00	4.91		ug/L		98	70 - 130	6	20	
1,2,4-Trimethyl benzene		5.00	5.16		ug/L		103	70 - 130	3	20	
1,2-Dichloroethane		5.00	4.74		ug/L		95	70 - 130	7	20	
1,2-Dichloropropane		5.00	4.61		ug/L		92	70 - 130	8	20	
1,3,5-Trimethyl benzene		5.00	5.11		ug/L		102	70 - 130	3	20	
1,3-Dichloropropane		5.00	4.68		ug/L		94	70 - 130	7	20	
2,2-Dichloropropane		5.00	5.44		ug/L		109	70 - 130	13	20	
2-Butanone (MEK)		50.0	39.2		ug/L		78	70 - 130	6	20	
4-Methyl-2-pentanone (MIBK)		50.0	48.8		ug/L		98	70 - 130	5	20	
Acetone		50.0	42.7 J		ug/L		85	70 - 130	6	20	
Benzene		5.00	4.83		ug/L		97	70 - 130	5	20	
Bromobenzene		5.00	4.84		ug/L		97	70 - 130	2	20	
Bromochloromethane		5.00	4.95		ug/L		99	70 - 130	5	20	
Bromodichloromethane		5.00	4.73		ug/L		95	70 - 130	9	20	
Bromoform		5.00	5.53		ug/L		111	70 - 130	2	20	
Bromomethane (Methyl Bromide)		5.00	4.14		ug/L		83	70 - 130	19	20	
Carbon disulfide		5.00	4.54		ug/L		91	70 - 130	8	20	
Carbon tetrachloride		5.00	4.76		ug/L		95	70 - 130	7	20	
Chlorobenzene		5.00	4.66		ug/L		93	70 - 130	8	20	
Chlorodibromomethane		5.00	4.83		ug/L		97	70 - 130	8	20	
cis-1,3-Dichloropropene		5.00	4.88		ug/L		98	70 - 130	2	20	
Dichloromethane		5.00	4.57		ug/L		91	70 - 130	7	20	
Ethylbenzene		5.00	4.77		ug/L		95	70 - 130	7	20	
Hexachlorobutadiene		5.00	4.84		ug/L		97	70 - 130	4	20	
Isopropyl benzene		5.00	4.94		ug/L		99	70 - 130	1	20	
m,p-Xylenes		10.0	10.3		ug/L		103	70 - 130	7	20	
m-Dichlorobenzene (1,3-DCB)		5.00	4.95		ug/L		99	70 - 130	3	20	
Methyl-tert-butyl Ether (MTBE)		5.00	5.02		ug/L		100	70 - 130	10	20	
Naphthalene		5.00	4.92		ug/L		98	70 - 130	10	20	
n-Butylbenzene		5.00	5.01		ug/L		100	70 - 130	1	20	
N-Propylbenzene		5.00	4.92		ug/L		98	70 - 130	6	20	
o-Chlorotoluene		5.00	5.04		ug/L		101	70 - 130	3	20	
o-Dichlorobenzene (1,2-DCB)		5.00	4.97		ug/L		99	70 - 130	2	20	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 380-30956/5

Matrix: Water

Analysis Batch: 30956

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD RPD	Limit
o-Xylene	5.00	4.87		ug/L	97	70 - 130	5	20	
p-Chlorotoluene	5.00	4.96		ug/L	99	70 - 130	8	20	
p-Dichlorobenzene (1,4-DCB)	5.00	4.96		ug/L	99	70 - 130	4	20	
p-Isopropyltoluene	5.00	5.30		ug/L	106	70 - 130	2	20	
sec-Butylbenzene	5.00	5.14		ug/L	103	70 - 130	4	20	
Styrene	5.00	4.96		ug/L	99	70 - 130	6	20	
Tert-amyl methyl ether	5.00	5.54		ug/L	111	70 - 130	6	20	
1,3-Dichloropropene, Total	10.0	10.2		ug/L	102	70 - 130	5	20	
Tert-butyl ethyl ether	5.00	5.45		ug/L	109	70 - 130	4	20	
tert-Butylbenzene	5.00	5.00		ug/L	100	70 - 130	2	20	
Tetrachloroethylene (PCE)	5.00	4.68		ug/L	94	70 - 130	6	20	
Toluene	5.00	4.82		ug/L	96	70 - 130	7	20	
trans-1,2-Dichloroethylene	5.00	4.58		ug/L	92	70 - 130	9	20	
trans-1,3-Dichloropropene	5.00	5.35		ug/L	107	70 - 130	8	20	
Trichloroethylene (TCE)	5.00	4.83		ug/L	97	70 - 130	8	20	
Bromoethane	5.00	4.24		ug/L	85	70 - 130	11	20	
Trichlorofluoromethane (Freon 11)	5.00	4.78		ug/L	96	70 - 130	8	20	
Trichlorotrifluoroethane	5.00	4.44		ug/L	89	70 - 130	6	20	
Diisopropyl ether	5.00	4.54		ug/L	91	70 - 130	9	20	
Vinyl Chloride (VC)	5.00	4.24		ug/L	85	70 - 130	12	20	
Xylenes, Total	15.0	15.2		ug/L	101	70 - 130	6	20	

Surrogate	LCSD %Recovery	LCSD Qualifier	LCSD Limits
1,2-Dichloroethane-d4 (Surr)	96		70 - 130
4-Bromofluorobenzene (Surr)	98		70 - 130
Toluene-d8 (Surr)	100		70 - 130

Lab Sample ID: MRL 380-30956/3

Matrix: Water

Analysis Batch: 30956

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
m,p-Xylenes	0.500	0.428	J	ug/L	86	50 - 150	
Vinyl Chloride (VC)	0.250	0.272	J	ug/L	109	50 - 150	

Surrogate	MRL %Recovery	MRL Qualifier	MRL Limits
1,2-Dichloroethane-d4 (Surr)	99		70 - 130
4-Bromofluorobenzene (Surr)	104		70 - 130
Toluene-d8 (Surr)	89		70 - 130

Lab Sample ID: MRL 380-30956/7

Matrix: Water

Analysis Batch: 30956

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1,1,1,2-Tetrachloroethane	0.500	0.499	J	ug/L	100	50 - 150	
1,1,1-Trichloroethane	0.500	0.530		ug/L	106	50 - 150	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-30956/7

Matrix: Water

Analysis Batch: 30956

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
1,1,2,2-Tetrachloroethane	0.500	0.593		ug/L	119	50 - 150	
1,1,2-Trichloroethane	0.500	0.536		ug/L	107	50 - 150	
1,1-Dichloroethane	0.500	0.543		ug/L	109	50 - 150	
1,1-Dichlorethylene	0.500	0.592		ug/L	118	50 - 150	
1,1-Dichloropropene	0.500	0.586		ug/L	117	50 - 150	
1,2,3-Trichlorobenzene	0.500	0.572		ug/L	114	50 - 150	
1,2,3-Trichloropropane	0.500	0.570		ug/L	114	50 - 150	
1,2,4-Trichlorobenzene	0.500	0.548		ug/L	110	50 - 150	
1,2,4-Trimethyl benzene	0.500	0.505		ug/L	101	50 - 150	
1,2-Dichloroethane	0.500	0.550		ug/L	110	50 - 150	
1,2-Dichloropropane	0.500	0.532		ug/L	106	50 - 150	
1,3,5-Trimethyl benzene	0.500	0.492 J		ug/L	98	50 - 150	
1,3-Dichloropropane	0.500	0.530		ug/L	106	50 - 150	
2,2-Dichloropropane	0.500	0.706		ug/L	141	50 - 150	
2-Butanone (MEK)	5.00	4.81 J		ug/L	96	50 - 150	
4-Methyl-2-pentanone (MIBK)	5.00	4.59 J		ug/L	92	50 - 150	
Acetone	5.00	ND		ug/L	67	50 - 150	
Benzene	0.500	0.566		ug/L	113	50 - 150	
Bromobenzene	0.500	0.578		ug/L	116	50 - 150	
Bromochloromethane	0.500	0.544		ug/L	109	50 - 150	
Bromodichloromethane	0.500	0.493 J		ug/L	99	50 - 150	
Bromoform	0.500	0.639		ug/L	128	50 - 150	
Bromomethane (Methyl Bromide)	0.500	0.487 J		ug/L	97	50 - 150	
Carbon disulfide	0.500	0.481 J		ug/L	96	50 - 150	
Carbon tetrachloride	0.500	0.498 J		ug/L	100	50 - 150	
Chlorobenzene	0.500	0.511		ug/L	102	50 - 150	
Chlorodibromomethane	0.500	0.469 J		ug/L	94	50 - 150	
cis-1,3-Dichloropropene	0.500	0.499 J		ug/L	100	50 - 150	
Dichloromethane	0.500	0.555		ug/L	111	50 - 150	
Ethylbenzene	0.500	0.456 J		ug/L	91	50 - 150	
Hexachlorobutadiene	0.500	0.615		ug/L	123	50 - 150	
Isopropyl benzene	0.500	0.516		ug/L	103	50 - 150	
m,p-Xylenes	1.00	0.880		ug/L	88	50 - 150	
m-Dichlorobenzene (1,3-DCB)	0.500	0.621		ug/L	124	50 - 150	
Methyl-tert-butyl Ether (MTBE)	0.500	0.577		ug/L	115	50 - 150	
Naphthalene	0.500	0.476 J		ug/L	95	50 - 150	
n-Butylbenzene	0.500	0.529		ug/L	106	50 - 150	
N-Propylbenzene	0.500	0.471 J		ug/L	94	50 - 150	
o-Chlorotoluene	0.500	0.584		ug/L	117	50 - 150	
o-Dichlorobenzene (1,2-DCB)	0.500	0.621		ug/L	124	50 - 150	
o-Xylene	0.500	0.453 J		ug/L	91	50 - 150	
p-Chlorotoluene	0.500	0.472 J		ug/L	94	50 - 150	
p-Dichlorobenzene (1,4-DCB)	0.500	0.580		ug/L	116	50 - 150	
p-Isopropyltoluene	0.500	0.480 J		ug/L	96	50 - 150	
sec-Butylbenzene	0.500	0.512		ug/L	102	50 - 150	
Styrene	0.500	0.407 J		ug/L	81	50 - 150	
Tert-amyl methyl ether	0.500	0.614 J		ug/L	123	50 - 150	
1,3-Dichloropropene, Total	1.00	1.01		ug/L	101	50 - 150	
Tert-butyl ethyl ether	0.500	0.618 J		ug/L	124	50 - 150	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-30956/7

Matrix: Water

Analysis Batch: 30956

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
tert-Butylbenzene	0.500	0.478	J	ug/L	96	50 - 150	
Tetrachloroethene (PCE)	0.500	0.557		ug/L	111	50 - 150	
Toluene	0.500	0.490	J	ug/L	98	50 - 150	
trans-1,2-Dichloroethylene	0.500	0.568		ug/L	114	50 - 150	
trans-1,3-Dichloropropene	0.500	0.510		ug/L	102	50 - 150	
Trichloroethylene (TCE)	0.500	0.572		ug/L	114	50 - 150	
Bromoethane	0.500	0.555		ug/L	111	50 - 150	
Trichlorofluoromethane (Freon 11)	0.500	0.484	J	ug/L	97	50 - 150	
Trichlorotrifluoroethane	0.500	0.554		ug/L	111	50 - 150	
Diisopropyl ether	0.500	0.567	J	ug/L	113	50 - 150	
Vinyl Chloride (VC)	0.500	0.497		ug/L	99	50 - 150	
Xylenes, Total	1.50	1.33		ug/L	89	50 - 150	

Surrogate	MRL	MRL	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	102		70 - 130
4-Bromofluorobenzene (Surr)	97		70 - 130
Toluene-d8 (Surr)	91		70 - 130

Method: 524.2 - Volatile Organic Compounds (GC/MS SIM)

Lab Sample ID: MB 380-30366/5

Matrix: Water

Analysis Batch: 30366

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Tertiary Butyl Alcohol (TBA)	ND		2.0	ug/L			01/20/23 17:45	1
Surrogate	MB	MB				Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier	Limits					
Toluene-d8 (Surr)	98		70 - 130				01/20/23 17:45	1
4-Bromofluorobenzene (Surr)	96		70 - 130				01/20/23 17:45	1
1,2-Dichloroethane-d4 (Surr)	100		70 - 130				01/20/23 17:45	1

Lab Sample ID: LCS 380-30366/2

Matrix: Water

Analysis Batch: 30366

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Tertiary Butyl Alcohol (TBA)	5.00	5.34		ug/L	107	70 - 130	
Surrogate	LCS	LCS					
	%Recovery	Qualifier	Limits				
Toluene-d8 (Surr)	102		70 - 130				
4-Bromofluorobenzene (Surr)	97		70 - 130				
1,2-Dichloroethane-d4 (Surr)	98		70 - 130				

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 524.2 - Volatile Organic Compounds (GC/MS SIM) (Continued)

Lab Sample ID: LCSD 380-30366/3

Matrix: Water

Analysis Batch: 30366

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD RPD	RPD Limit
Tertiary Butyl Alcohol (TBA)	5.00	5.44		ug/L		109	70 - 130	2	20
Surrogate									
<i>Toluene-d8 (Surr)</i> 101 %Recovery Qualifier Limits									
4-Bromofluorobenzene (Surr)	98			70 - 130					
1,2-Dichloroethane-d4 (Surr)	99			70 - 130					

Lab Sample ID: MRL 380-30366/4

Matrix: Water

Analysis Batch: 30366

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Tertiary Butyl Alcohol (TBA)	2.00	1.94	J	ug/L		97	50 - 150
Surrogate							
<i>Toluene-d8 (Surr)</i> 100 %Recovery Qualifier Limits							
4-Bromofluorobenzene (Surr)	98			50 - 150			
1,2-Dichloroethane-d4 (Surr)	99			50 - 150			

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-30258/1-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 30258

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
2,4'-DDD	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
2,4'-DDE	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
2,4'-DDT	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
2,4-Dinitrotoluene	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
2,6-Dinitrotoluene	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
4,4'-DDD	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
4,4'-DDE	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
4,4'-DDT	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
Acenaphthene	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
Acenaphthylene	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
Acetochlor	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
Alachlor	ND		0.049	ug/L		01/20/23 05:58	01/20/23 16:25	1
alpha-BHC	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1
alpha-Chlordane	ND		0.049	ug/L		01/20/23 05:58	01/20/23 16:25	1
Anthracene	ND		0.020	ug/L		01/20/23 05:58	01/20/23 16:25	1
Atrazine	ND		0.049	ug/L		01/20/23 05:58	01/20/23 16:25	1
Benz(a)anthracene	ND		0.049	ug/L		01/20/23 05:58	01/20/23 16:25	1
Benzo[a]pyrene	ND		0.020	ug/L		01/20/23 05:58	01/20/23 16:25	1
Benzo[b]fluoranthene	ND		0.020	ug/L		01/20/23 05:58	01/20/23 16:25	1
Benzo[g,h,i]perylene	ND		0.049	ug/L		01/20/23 05:58	01/20/23 16:25	1
Benzo[k]fluoranthene	ND		0.020	ug/L		01/20/23 05:58	01/20/23 16:25	1
beta-BHC	ND		0.099	ug/L		01/20/23 05:58	01/20/23 16:25	1

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-30258/1-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 30258

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Bis(2-ethylhexyl) phthalate	ND		0.59	ug/L	01/20/23 05:58	01/20/23 16:25		1
Bromacil	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Butachlor	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Butylbenzylphthalate	ND		0.49	ug/L	01/20/23 05:58	01/20/23 16:25		1
Chlorobenzilate	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Chloroneb	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Chlorothalonil (Draconil, Bravo)	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Chlorpyrifos	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Chrysene	ND		0.020	ug/L	01/20/23 05:58	01/20/23 16:25		1
delta-BHC	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Di(2-ethylhexyl)adipate	ND		0.59	ug/L	01/20/23 05:58	01/20/23 16:25		1
Dibenz(a,h)anthracene	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Diclorvos (DDVP)	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Dieldrin	ND		0.20	ug/L	01/20/23 05:58	01/20/23 16:25		1
Diethylphthalate	ND		0.49	ug/L	01/20/23 05:58	01/20/23 16:25		1
Dimethylphthalate	ND		0.49	ug/L	01/20/23 05:58	01/20/23 16:25		1
Di-n-butyl phthalate	ND		0.99	ug/L	01/20/23 05:58	01/20/23 16:25		1
Di-n-octyl phthalate	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Endosulfan I (Alpha)	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Endosulfan II (Beta)	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Endosulfan sulfate	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Endrin	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Endrin aldehyde	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
EPTC	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Fluoranthene	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Fluorene	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
gamma-BHC (Lindane)	ND		0.039	ug/L	01/20/23 05:58	01/20/23 16:25		1
gamma-Chlordane	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Heptachlor	ND		0.039	ug/L	01/20/23 05:58	01/20/23 16:25		1
Heptachlor epoxide (isomer B)	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Hexachlorobenzene	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Hexachlorocyclopentadiene	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Indeno[1,2,3-cd]pyrene	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Isophorone	ND		0.49	ug/L	01/20/23 05:58	01/20/23 16:25		1
Malathion	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Methoxychlor	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Metolachlor	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Metribuzin	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Molinate	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Naphthalene	ND		0.30	ug/L	01/20/23 05:58	01/20/23 16:25		1
Parathion	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Pendimethalin (Penoxaline)	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Phenanthrene	ND		0.039	ug/L	01/20/23 05:58	01/20/23 16:25		1
Propachlor	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Pyrene	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Simazine	ND		0.049	ug/L	01/20/23 05:58	01/20/23 16:25		1
Terbacil	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Terbutylazine	ND		0.099	ug/L	01/20/23 05:58	01/20/23 16:25		1
Thiobencarb	ND		0.20	ug/L	01/20/23 05:58	01/20/23 16:25		1

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-30258/1-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 30258

Analyte	MB		RL	Unit	D	Prepared		Analyzed		Dil Fac
	Result	Qualifier								
Total Permethrin (mixed isomers)	ND		0.20	ug/L		01/20/23 05:58		01/20/23 16:25		1
trans-Nonachlor	ND		0.049	ug/L		01/20/23 05:58		01/20/23 16:25		1
Trifluralin	ND		0.099	ug/L		01/20/23 05:58		01/20/23 16:25		1
1-Methylnaphthalene	ND		0.099	ug/L		01/20/23 05:58		01/20/23 16:25		1
2-Methylnaphthalene	ND		0.099	ug/L		01/20/23 05:58		01/20/23 16:25		1

Tentatively Identified Compound	MB		Unit	D	RT	CAS No.	Prepared		Analyzed		Dil Fac
	Est. Result	Qualifier									
Unknown	0.756	T J	ug/L		2.26	N/A	01/20/23 05:58		01/20/23 16:25		1
Decane	1.40	T J N	ug/L		2.42	124-18-5	01/20/23 05:58		01/20/23 16:25		1
9-Octadecenamide, (Z)-	0.530	T J N	ug/L		7.57	301-02-0	01/20/23 05:58		01/20/23 16:25		1

Surrogate	MB		Limits	Prepared		Analyzed		Dil Fac
	%Recovery	Qualifier						
2-Nitro-m-xylene	101		70 - 130					1
Perylene-d12	93		70 - 130					1
Triphenylphosphate	105		70 - 130					1

Lab Sample ID: LCS 380-30258/3-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Spike Added	LCS		Unit	D	%Rec	%Rec	
		Result	Qualifier				Limits	
2,4'-DDD	1.98	2.32		ug/L		117	70 - 130	
2,4'-DDE	1.98	2.04		ug/L		103	70 - 130	
2,4'-DDT	1.98	2.28		ug/L		115	70 - 130	
2,4-Dinitrotoluene	1.98	1.79		ug/L		90	70 - 130	
2,6-Dinitrotoluene	1.98	1.73		ug/L		87	70 - 130	
4,4'-DDD	1.98	2.26		ug/L		114	70 - 130	
4,4'-DDE	1.98	2.32		ug/L		117	70 - 130	
4,4'-DDT	1.98	2.07		ug/L		104	70 - 130	
Acenaphthene	1.98	1.81		ug/L		92	70 - 130	
Acenaphthylene	1.98	1.75		ug/L		88	70 - 130	
Acetochlor	1.98	2.04		ug/L		103	70 - 130	
Alachlor	1.98	2.16		ug/L		109	70 - 130	
alpha-BHC	1.98	2.06		ug/L		104	70 - 130	
alpha-Chlordane	1.98	2.04		ug/L		103	70 - 130	
Anthracene	1.98	1.84		ug/L		93	70 - 130	
Atrazine	1.98	2.16		ug/L		109	70 - 130	
Benz(a)anthracene	1.98	2.17		ug/L		110	70 - 130	
Benzo[a]pyrene	1.98	1.98		ug/L		100	70 - 130	
Benzo[b]fluoranthene	1.98	2.06		ug/L		104	70 - 130	
Benzo[g,h,i]perylene	1.98	2.04		ug/L		103	70 - 130	
Benzo[k]fluoranthene	1.98	2.09		ug/L		106	70 - 130	
beta-BHC	1.98	2.12		ug/L		107	70 - 130	
Bis(2-ethylhexyl) phthalate	1.98	1.94		ug/L		98	70 - 130	
Bromacil	1.98	2.37		ug/L		120	70 - 130	
Butachlor	1.98	2.31		ug/L		117	70 - 130	
Butylbenzylphthalate	1.98	2.38		ug/L		120	70 - 130	
Chlorobenzilate	1.98	2.27		ug/L		115	70 - 130	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-30258/3-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Chloroneb	1.98	1.91		ug/L	97	70 - 130	
Chlorothalonil (Draconil, Bravo)	1.98	2.24		ug/L	113	70 - 130	
Chlorpyrifos	1.98	2.29		ug/L	116	70 - 130	
Chrysene	1.98	1.99		ug/L	100	70 - 130	
delta-BHC	1.98	2.13		ug/L	107	70 - 130	
Di(2-ethylhexyl)adipate	1.98	2.31		ug/L	117	70 - 130	
Dibenz(a,h)anthracene	1.98	1.98		ug/L	100	70 - 130	
Diclorvos (DDVP)	1.98	1.97		ug/L	99	70 - 130	
Dieldrin	1.98	2.27		ug/L	115	70 - 130	
Diethylphthalate	1.98	1.92		ug/L	97	70 - 130	
Dimethylphthalate	1.98	1.87		ug/L	94	70 - 130	
Di-n-butyl phthalate	3.96	4.32		ug/L	109	70 - 130	
Di-n-octyl phthalate	1.98	1.90		ug/L	96	70 - 130	
Endosulfan I (Alpha)	1.98	2.01		ug/L	101	70 - 130	
Endosulfan II (Beta)	1.98	2.27		ug/L	115	70 - 130	
Endosulfan sulfate	1.98	2.52		ug/L	127	70 - 130	
Endrin	1.98	2.56		ug/L	129	70 - 130	
Endrin aldehyde	1.98	2.00		ug/L	101	70 - 130	
EPTC	1.98	2.07		ug/L	105	70 - 130	
Fluoranthene	1.98	2.07		ug/L	105	70 - 130	
Fluorene	1.98	1.87		ug/L	94	70 - 130	
gamma-BHC (Lindane)	1.98	2.07		ug/L	105	70 - 130	
gamma-Chlordane	1.98	1.88		ug/L	95	70 - 130	
Heptachlor	1.98	2.21		ug/L	112	70 - 130	
Heptachlor epoxide (isomer B)	1.98	2.01		ug/L	101	70 - 130	
Hexachlorobenzene	1.98	1.94		ug/L	98	70 - 130	
Hexachlorocyclopentadiene	1.98	1.96		ug/L	99	70 - 130	
Indeno[1,2,3-cd]pyrene	1.98	1.99		ug/L	101	70 - 130	
Isophorone	1.98	1.78		ug/L	90	70 - 130	
Malathion	1.98	2.26		ug/L	114	70 - 130	
Methoxychlor	1.98	2.37		ug/L	120	70 - 130	
Metolachlor	1.98	2.32		ug/L	117	70 - 130	
Metribuzin	1.98	2.23		ug/L	113	70 - 130	
Molinate	1.98	2.09		ug/L	106	70 - 130	
Naphthalene	1.98	1.80		ug/L	91	70 - 130	
Parathion	1.98	2.24		ug/L	113	70 - 130	
Pendimethalin (Penoxaline)	1.98	2.24		ug/L	113	70 - 130	
Phenanthrene	1.98	1.86		ug/L	94	70 - 130	
Propachlor	1.98	2.07		ug/L	104	70 - 130	
Pyrene	1.98	2.11		ug/L	107	70 - 130	
Simazine	1.98	2.23		ug/L	113	70 - 130	
Terbacil	1.98	2.24		ug/L	113	70 - 130	
Terbutylazine	1.98	2.15		ug/L	109	70 - 130	
Thiobencarb	1.98	2.33		ug/L	118	70 - 130	
trans-Nonachlor	1.98	2.15		ug/L	109	70 - 130	
Trifluralin	1.98	2.11		ug/L	107	70 - 130	
1-Methylnaphthalene	1.98	1.83		ug/L	92	70 - 130	
2-Methylnaphthalene	1.98	1.86		ug/L	94	70 - 130	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-30258/3-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30258

Surrogate	LCS	LCS	%Recovery	Qualifier	Limits
2-Nitro-m-xylene		97			70 - 130
Perylene-d12		95			70 - 130
Triphenylphosphate		108			70 - 130

Lab Sample ID: LCSD 380-30258/4-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
2,4'-DDD	1.97	2.31		ug/L		117	70 - 130	1	20
2,4'-DDE	1.97	2.02		ug/L		103	70 - 130	1	20
2,4'-DDT	1.97	2.25		ug/L		114	70 - 130	1	20
2,4-Dinitrotoluene	1.97	1.83		ug/L		93	70 - 130	2	20
2,6-Dinitrotoluene	1.97	1.79		ug/L		91	70 - 130	4	20
4,4'-DDD	1.97	2.24		ug/L		114	70 - 130	1	20
4,4'-DDE	1.97	2.30		ug/L		117	70 - 130	1	20
4,4'-DDT	1.97	2.11		ug/L		107	70 - 130	2	20
Acenaphthene	1.97	1.86		ug/L		95	70 - 130	3	20
Acenaphthylene	1.97	1.82		ug/L		92	70 - 130	4	20
Acetochlor	1.97	2.05		ug/L		104	70 - 130	1	20
Alachlor	1.97	2.17		ug/L		110	70 - 130	1	20
alpha-BHC	1.97	2.14		ug/L		109	70 - 130	4	20
alpha-Chlordane	1.97	2.00		ug/L		101	70 - 130	2	20
Anthracene	1.97	1.84		ug/L		93	70 - 130	0	20
Atrazine	1.97	2.17		ug/L		110	70 - 130	0	20
Benz(a)anthracene	1.97	2.17		ug/L		110	70 - 130	0	20
Benzo[a]pyrene	1.97	2.06		ug/L		105	70 - 130	4	20
Benzo[b]fluoranthene	1.97	2.15		ug/L		109	70 - 130	4	20
Benzo[g,h,i]perylene	1.97	1.99		ug/L		101	70 - 130	3	20
Benzo[k]fluoranthene	1.97	2.09		ug/L		106	70 - 130	0	20
beta-BHC	1.97	2.14		ug/L		109	70 - 130	1	20
Bis(2-ethylhexyl) phthalate	1.97	1.93		ug/L		98	70 - 130	0	20
Bromacil	1.97	2.35		ug/L		119	70 - 130	1	20
Butachlor	1.97	2.32		ug/L		118	70 - 130	0	20
Butylbenzylphthalate	1.97	2.37		ug/L		120	70 - 130	1	20
Chlorobenzilate	1.97	2.29		ug/L		116	70 - 130	1	20
Chloroneb	1.97	1.94		ug/L		99	70 - 130	1	20
Chlorothalonil (Draconil, Bravo)	1.97	2.22		ug/L		113	70 - 130	1	20
Chlorpyrifos	1.97	2.27		ug/L		116	70 - 130	1	20
Chrysene	1.97	2.01		ug/L		102	70 - 130	1	20
delta-BHC	1.97	2.13		ug/L		108	70 - 130	0	20
Di(2-ethylhexyl)adipate	1.97	2.29		ug/L		116	70 - 130	1	20
Dibenz(a,h)anthracene	1.97	2.04		ug/L		103	70 - 130	3	20
Diclorvos (DDVP)	1.97	2.01		ug/L		102	70 - 130	2	20
Dieldrin	1.97	2.27		ug/L		115	70 - 130	0	20
Diethylphthalate	1.97	1.94		ug/L		99	70 - 130	1	20
Dimethylphthalate	1.97	1.94		ug/L		99	70 - 130	4	20
Di-n-butyl phthalate		3.94	4.36	ug/L		111	70 - 130	1	20

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCSD 380-30258/4-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD RPD	RPD Limit
Di-n-octyl phthalate	1.97	1.87		ug/L	95	70 - 130	1	20	
Endosulfan I (Alpha)	1.97	1.98		ug/L	101	70 - 130	1	20	
Endosulfan II (Beta)	1.97	2.32		ug/L	118	70 - 130	2	20	
Endosulfan sulfate	1.97	2.56		ug/L	130	70 - 130	2	20	
Endrin	1.97	2.56		ug/L	130	70 - 130	0	20	
Endrin aldehyde	1.97	1.90		ug/L	97	70 - 130	5	20	
EPTC	1.97	2.17		ug/L	110	70 - 130	5	20	
Fluoranthene	1.97	2.05		ug/L	104	70 - 130	1	20	
Fluorene	1.97	1.92		ug/L	98	70 - 130	3	20	
gamma-BHC (Lindane)	1.97	2.07		ug/L	105	70 - 130	0	20	
gamma-Chlordane	1.97	1.89		ug/L	96	70 - 130	1	20	
Heptachlor	1.97	2.21		ug/L	112	70 - 130	0	20	
Heptachlor epoxide (isomer B)	1.97	1.98		ug/L	101	70 - 130	1	20	
Hexachlorobenzene	1.97	1.94		ug/L	98	70 - 130	0	20	
Hexachlorocyclopentadiene	1.97	2.00		ug/L	102	70 - 130	2	20	
Indeno[1,2,3-cd]pyrene	1.97	2.03		ug/L	103	70 - 130	2	20	
Isophorone	1.97	1.89		ug/L	96	70 - 130	7	20	
Malathion	1.97	2.26		ug/L	115	70 - 130	0	20	
Methoxychlor	1.97	2.45		ug/L	125	70 - 130	3	20	
Metolachlor	1.97	2.29		ug/L	116	70 - 130	1	20	
Metribuzin	1.97	2.22		ug/L	113	70 - 130	1	20	
Molinate	1.97	2.15		ug/L	109	70 - 130	3	20	
Naphthalene	1.97	1.84		ug/L	94	70 - 130	2	20	
Parathion	1.97	2.19		ug/L	111	70 - 130	2	20	
Pendimethalin (Penoxaline)	1.97	2.25		ug/L	114	70 - 130	0	20	
Phenanthrene	1.97	1.85		ug/L	94	70 - 130	1	20	
Propachlor	1.97	2.12		ug/L	108	70 - 130	2	20	
Pyrene	1.97	2.06		ug/L	105	70 - 130	2	20	
Simazine	1.97	2.25		ug/L	115	70 - 130	1	20	
Terbacil	1.97	2.19		ug/L	111	70 - 130	2	20	
Terbutylazine	1.97	2.19		ug/L	111	70 - 130	2	20	
Thiobencarb	1.97	2.26		ug/L	115	70 - 130	3	20	
trans-Nonachlor	1.97	2.10		ug/L	107	70 - 130	2	20	
Trifluralin	1.97	2.13		ug/L	108	70 - 130	1	20	
1-Methylnaphthalene	1.97	1.89		ug/L	96	70 - 130	4	20	
2-Methylnaphthalene	1.97	1.92		ug/L	97	70 - 130	3	20	

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
2-Nitro-m-xylene	99		70 - 130
Perylene-d12	97		70 - 130
Triphenylphosphate	107		70 - 130

Lab Sample ID: MRL 380-30258/2-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
2,4'-DDD	0.0984	0.128		ug/L	130	50 - 150	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-30258/2-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
2,4'-DDE	0.0984	0.0953	J	ug/L	97	50 - 150	
2,4'-DDT	0.0984	0.0975	J	ug/L	99	50 - 150	
2,4-Dinitrotoluene	0.0984	0.0687	J	ug/L	70	50 - 150	
2,6-Dinitrotoluene	0.0984	0.0799	J	ug/L	81	50 - 150	
4,4'-DDD	0.0984	0.0992		ug/L	101	50 - 150	
4,4'-DDE	0.0984	0.111		ug/L	112	50 - 150	
4,4'-DDT	0.0984	0.111		ug/L	113	50 - 150	
Acenaphthene	0.0984	0.0999		ug/L	102	50 - 150	
Acenaphthylene	0.0984	0.0954	J	ug/L	97	50 - 150	
Acetochlor	0.0492	0.0490	J	ug/L	100	50 - 150	
Alachlor	0.0492	0.0648		ug/L	132	50 - 150	
alpha-BHC	0.0984	0.0932	J	ug/L	95	50 - 150	
alpha-Chlordane	0.0246	ND		ug/L	108	50 - 150	
Anthracene	0.0197	ND		ug/L	89	50 - 150	
Atrazine	0.0492	0.0488	J	ug/L	99	50 - 150	
Benz(a)anthracene	0.0492	0.0518		ug/L	105	50 - 150	
Benzo[a]pyrene	0.0197	0.0164	J	ug/L	83	50 - 150	
Benzo[b]fluoranthene	0.0197	0.0186	J	ug/L	95	50 - 150	
Benzo[g,h,i]perylene	0.0492	0.0498		ug/L	101	50 - 150	
Benzo[k]fluoranthene	0.0197	0.0176	J	ug/L	89	50 - 150	
beta-BHC	0.0984	0.0990		ug/L	101	50 - 150	
Bis(2-ethylhexyl) phthalate	0.591	0.695		ug/L	118	50 - 150	
Bromacil	0.0984	0.114		ug/L	116	50 - 150	
Butachlor	0.0492	0.0628		ug/L	128	50 - 150	
Butylbenzylphthalate	0.148	0.204	J	ug/L	138	50 - 150	
Chlorobenzilate	0.0984	0.145		ug/L	147	50 - 150	
Chloroneb	0.0984	0.108		ug/L	110	50 - 150	
Chlorothalonil (Draconil, Bravo)	0.0984	0.146		ug/L	148	50 - 150	
Chlorpyrifos	0.0492	0.0542		ug/L	110	50 - 150	
Chrysene	0.0197	0.0206		ug/L	105	50 - 150	
delta-BHC	0.0984	0.118		ug/L	120	50 - 150	
Di(2-ethylhexyl)adipate	0.295	0.472	J ^3+	ug/L	160	50 - 150	
Dibenz(a,h)anthracene	0.0492	0.0547		ug/L	111	50 - 150	
Diclorvos (DDVP)	0.0492	0.0574		ug/L	117	50 - 150	
Dieldrin	0.0984	0.105	J	ug/L	107	50 - 150	
Diethylphthalate	0.148	0.168	J	ug/L	114	50 - 150	
Dimethylphthalate	0.295	0.261	J	ug/L	89	50 - 150	
Di-n-butyl phthalate	0.295	0.344	J	ug/L	117	49 - 243	
Di-n-octyl phthalate	0.0984	0.123		ug/L	125	50 - 150	
Endosulfan I (Alpha)	0.0984	0.0890	J	ug/L	90	50 - 150	
Endosulfan II (Beta)	0.0984	0.137		ug/L	139	50 - 150	
Endosulfan sulfate	0.0984	0.0840	J	ug/L	85	50 - 150	
Endrin	0.0984	0.145		ug/L	147	50 - 150	
Endrin aldehyde	0.0984	0.172	^3+	ug/L	174	50 - 150	
EPTC	0.0984	0.114		ug/L	116	50 - 150	
Fluoranthene	0.0492	0.0481	J	ug/L	98	50 - 150	
Fluorene	0.0492	ND		ug/L	88	50 - 150	
gamma-BHC (Lindane)	0.0394	0.0375	J	ug/L	95	50 - 150	
gamma-Chlordane	0.0246	0.0374	J ^3+	ug/L	152	50 - 150	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-30258/2-A

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
Heptachlor	0.0394	0.0445		ug/L	113	50 - 150	
Heptachlor epoxide (isomer B)	0.0492	0.0864	^3+	ug/L	176	50 - 150	
Hexachlorobenzene	0.0492	0.0451	J	ug/L	92	50 - 150	
Hexachlorocyclopentadiene	0.0492	0.0402	J	ug/L	82	50 - 150	
Indeno[1,2,3-cd]pyrene	0.0492	0.0491		ug/L	100	50 - 150	
Isophorone	0.0984	0.0936	J	ug/L	95	50 - 150	
Malathion	0.0984	0.105		ug/L	106	50 - 150	
Methoxychlor	0.0984	0.0930	J	ug/L	95	50 - 150	
Metolachlor	0.0492	0.0607		ug/L	123	50 - 150	
Metribuzin	0.0492	0.0678		ug/L	138	50 - 150	
Molinate	0.0984	0.108		ug/L	110	50 - 150	
Naphthalene	0.0984	0.109	J	ug/L	111	50 - 150	
Parathion	0.0984	0.137		ug/L	140	50 - 150	
Pendimethalin (Penoxaline)	0.0984	0.102		ug/L	104	50 - 150	
Phenanthrene	0.0197	0.0197	J	ug/L	100	50 - 150	
Propachlor	0.0492	0.0519		ug/L	105	50 - 150	
Pyrene	0.0492	0.0493		ug/L	100	50 - 150	
Simazine	0.0492	0.0512		ug/L	104	50 - 150	
Terbacil	0.0984	0.117		ug/L	119	50 - 150	
Terbutylazine	0.0984	0.0941	J	ug/L	96	50 - 150	
Thiobencarb	0.0984	0.114	J	ug/L	116	50 - 150	
trans-Nonachlor	0.0246	ND		ug/L	82	50 - 150	
Trifluralin	0.0984	0.0944	J	ug/L	96	50 - 150	
1-Methylnaphthalene	0.0984	0.117		ug/L	119	50 - 150	
2-Methylnaphthalene	0.0984	0.115		ug/L	117	50 - 150	

Surrogate	MRL %Recovery	MRL Qualifier	Limits
2-Nitro-m-xylene	100		70 - 130
Perlylene-d12	91		70 - 130
Triphenylphosphate	109		70 - 130

Lab Sample ID: 380-34654-R-1-A MS

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
2,4'-DDD	ND		1.98	2.35		ug/L	118	70 - 130	
2,4'-DDE	ND		1.98	2.03		ug/L	102	70 - 130	
2,4'-DDT	ND		1.98	2.30		ug/L	116	70 - 130	
2,4-Dinitrotoluene	ND		1.98	1.84		ug/L	93	70 - 130	
2,6-Dinitrotoluene	ND		1.98	1.84		ug/L	93	70 - 130	
4,4'-DDD	ND		1.98	2.31		ug/L	116	70 - 130	
4,4'-DDE	ND		1.98	2.30		ug/L	116	70 - 130	
4,4'-DDT	ND		1.98	2.15		ug/L	109	70 - 130	
Acenaphthene	ND		1.98	1.89		ug/L	95	70 - 130	
Acenaphthylene	ND		1.98	1.87		ug/L	94	70 - 130	
Acetochlor	ND		1.98	2.11		ug/L	106	70 - 130	
Alachlor	ND		1.98	2.20		ug/L	111	70 - 130	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-34654-R-1-A MS

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
alpha-BHC	ND		1.98	2.17		ug/L	109	70 - 130	
alpha-Chlordane	ND		1.98	2.06		ug/L	102	70 - 130	
Anthracene	ND	F1	1.98	1.34	F1	ug/L	68	70 - 130	
Atrazine	ND		1.98	2.19		ug/L	110	70 - 130	
Benz(a)anthracene	ND		1.98	2.13		ug/L	107	70 - 130	
Benzo[a]pyrene	ND		1.98	1.88		ug/L	95	70 - 130	
Benzo[b]fluoranthene	ND		1.98	2.11		ug/L	107	70 - 130	
Benzo[g,h,i]perylene	ND		1.98	2.11		ug/L	106	70 - 130	
Benzo[k]fluoranthene	ND		1.98	2.18		ug/L	110	70 - 130	
beta-BHC	ND		1.98	2.16		ug/L	109	70 - 130	
Bis(2-ethylhexyl) phthalate	ND		1.98	1.97		ug/L	99	70 - 130	
Bromacil	ND		1.98	2.51		ug/L	127	70 - 130	
Butachlor	ND		1.98	2.35		ug/L	119	70 - 130	
Butylbenzylphthalate	ND		1.98	2.41		ug/L	121	70 - 130	
Chlorobenzilate	ND		1.98	2.32		ug/L	117	70 - 130	
Chloroneb	ND		1.98	1.95		ug/L	99	70 - 130	
Chlorothalonil (Draconil, Bravo)	ND		1.98	2.22		ug/L	112	70 - 130	
Chlorpyrifos	ND		1.98	2.29		ug/L	116	70 - 130	
Chrysene	ND		1.98	2.06		ug/L	104	70 - 130	
delta-BHC	ND		1.98	2.16		ug/L	109	70 - 130	
Di(2-ethylhexyl)adipate	ND	^3+	1.98	2.30		ug/L	116	70 - 130	
Dibenz(a,h)anthracene	ND		1.98	2.06		ug/L	104	70 - 130	
Diclorvos (DDVP)	ND		1.98	2.04		ug/L	103	70 - 130	
Dieldrin	ND		1.98	2.33		ug/L	115	70 - 130	
Diethylphthalate	ND		1.98	1.96		ug/L	99	70 - 130	
Dimethylphthalate	ND		1.98	1.98		ug/L	100	70 - 130	
Di-n-butyl phthalate	ND		3.96	4.35		ug/L	110	70 - 130	
Di-n-octyl phthalate	ND		1.98	1.90		ug/L	96	70 - 130	
Endosulfan I (Alpha)	ND		1.98	2.01		ug/L	101	70 - 130	
Endosulfan II (Beta)	ND		1.98	2.34		ug/L	118	70 - 130	
Endosulfan sulfate	ND	F1	1.98	2.59	F1	ug/L	131	70 - 130	
Endrin	ND		1.98	2.55		ug/L	128	70 - 130	
Endrin aldehyde	ND	^3+	1.98	1.87		ug/L	94	70 - 130	
EPTC	ND		1.98	2.22		ug/L	112	70 - 130	
Fluoranthene	ND		1.98	2.06		ug/L	104	70 - 130	
Fluorene	ND		1.98	1.96		ug/L	99	70 - 130	
gamma-BHC (Lindane)	ND		1.98	2.15		ug/L	109	70 - 130	
gamma-Chlordane	ND	^3+	1.98	1.97		ug/L	97	70 - 130	
Heptachlor	ND		1.98	2.20		ug/L	111	70 - 130	
Heptachlor epoxide (isomer B)	ND	^3+	1.98	2.09		ug/L	105	70 - 130	
Hexachlorobenzene	ND		1.98	1.95		ug/L	98	70 - 130	
Hexachlorocyclopentadiene	ND		1.98	2.00		ug/L	101	70 - 130	
Indeno[1,2,3-cd]pyrene	ND		1.98	2.09		ug/L	105	70 - 130	
Isophorone	ND		1.98	1.87		ug/L	95	70 - 130	
Malathion	ND		1.98	2.32		ug/L	117	70 - 130	
Methoxychlor	ND		1.98	2.49		ug/L	126	70 - 130	
Metolachlor	ND		1.98	2.32		ug/L	117	70 - 130	
Metribuzin	ND		1.98	2.30		ug/L	116	70 - 130	
Molinate	ND		1.98	2.21		ug/L	112	70 - 130	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-34654-R-1-A MS

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Naphthalene	ND		1.98	1.85		ug/L	94	70 - 130	
Parathion	ND		1.98	2.22		ug/L	112	70 - 130	
Pendimethalin (Penoxaline)	ND		1.98	2.30		ug/L	116	70 - 130	
Phenanthrene	ND		1.98	1.89		ug/L	96	70 - 130	
Propachlor	ND		1.98	2.12		ug/L	107	70 - 130	
Pyrene	ND		1.98	2.11		ug/L	107	70 - 130	
Simazine	ND		1.98	2.28		ug/L	115	70 - 130	
Terbacil	ND		1.98	2.24		ug/L	113	70 - 130	
Terbutylazine	ND		1.98	2.26		ug/L	114	70 - 130	
Thiobencarb	ND		1.98	2.28		ug/L	115	70 - 130	
trans-Nonachlor	ND		1.98	2.24		ug/L	113	70 - 130	
Trifluralin	ND		1.98	2.18		ug/L	110	70 - 130	
1-Methylnaphthalene	ND		1.98	1.87		ug/L	95	70 - 130	
2-Methylnaphthalene	ND		1.98	1.92		ug/L	97	70 - 130	
<hr/>									
Surrogate	MS %Recovery		MS Qualifier	Limits					
2-Nitro-m-xylene	100			70 - 130					
Perylene-d12	99			70 - 130					
Triphenylphosphate	108			70 - 130					

Lab Sample ID: 380-34720-V-2-A DU

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Duplicate

Prep Type: Total/NA

Prep Batch: 30258

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	Limit
2,4'-DDD	ND		ND		ug/L		NC	20
2,4'-DDE	ND		ND		ug/L		NC	20
2,4'-DDT	ND		ND		ug/L		NC	20
2,4-Dinitrotoluene	ND		ND		ug/L		NC	20
2,6-Dinitrotoluene	ND		ND		ug/L		NC	20
4,4'-DDD	ND		ND		ug/L		NC	20
4,4'-DDE	ND		ND		ug/L		NC	20
4,4'-DDT	ND		ND		ug/L		NC	20
Acenaphthene	ND		ND		ug/L		NC	20
Acenaphthylene	ND		ND		ug/L		NC	20
Acetochlor	ND		ND		ug/L		NC	20
Alachlor	ND		ND		ug/L		NC	20
alpha-BHC	ND		ND		ug/L		NC	20
alpha-Chlordane	ND		ND		ug/L		NC	20
Anthracene	ND		ND		ug/L		NC	20
Atrazine	ND		ND		ug/L		NC	20
Benz(a)anthracene	ND		ND		ug/L		NC	20
Benzo[a]pyrene	ND		ND		ug/L		NC	20
Benzo[b]fluoranthene	ND		ND		ug/L		NC	20
Benzo[g,h,i]perylene	ND		ND		ug/L		NC	20
Benzo[k]fluoranthene	ND		ND		ug/L		NC	20
beta-BHC	ND		ND		ug/L		NC	20
Bis(2-ethylhexyl) phthalate	ND		ND		ug/L		NC	20

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-34720-V-2-A DU

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Duplicate
Prep Type: Total/NA
Prep Batch: 30258

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
Bromacil	ND		ND		ug/L		NC	20
Butachlor	ND		ND		ug/L		NC	20
Butylbenzylphthalate	ND		ND		ug/L		NC	20
Chlorobenzilate	ND		ND		ug/L		NC	20
Chloroneb	ND		ND		ug/L		NC	20
Chlorothalonil (Draconil, Bravo)	ND		ND		ug/L		NC	20
Chlorpyrifos	ND		ND		ug/L		NC	20
Chrysene	ND		ND		ug/L		NC	20
delta-BHC	ND		ND		ug/L		NC	20
Di(2-ethylhexyl)adipate	ND ^3+		ND		ug/L		NC	20
Dibenz(a,h)anthracene	ND		ND		ug/L		NC	20
Diclorvos (DDVP)	ND		ND		ug/L		NC	20
Dieldrin	ND		ND		ug/L		NC	20
Diethylphthalate	ND		ND		ug/L		NC	20
Dimethylphthalate	ND		ND		ug/L		NC	20
Di-n-butyl phthalate	ND		ND		ug/L		NC	20
Di-n-octyl phthalate	ND		ND		ug/L		NC	20
Endosulfan I (Alpha)	ND		ND		ug/L		NC	20
Endosulfan II (Beta)	ND		ND		ug/L		NC	20
Endosulfan sulfate	ND		ND		ug/L		NC	20
Endrin	ND		ND		ug/L		NC	20
Endrin aldehyde	ND ^3+		ND		ug/L		NC	20
EPTC	ND		ND		ug/L		NC	20
Fluoranthene	ND		ND		ug/L		NC	20
Fluorene	ND		ND		ug/L		NC	20
gamma-BHC (Lindane)	ND		ND		ug/L		NC	20
gamma-Chlordane	ND ^3+		ND		ug/L		NC	20
Heptachlor	ND		ND		ug/L		NC	20
Heptachlor epoxide (isomer B)	ND ^3+		ND		ug/L		NC	20
Hexachlorobenzene	ND		ND		ug/L		NC	20
Hexachlorocyclopentadiene	ND		ND		ug/L		NC	20
Indeno[1,2,3-cd]pyrene	ND		ND		ug/L		NC	20
Isophorone	ND		ND		ug/L		NC	20
Malathion	ND		ND		ug/L		NC	20
Methoxychlor	ND		ND		ug/L		NC	20
Metolachlor	ND		ND		ug/L		NC	20
Metribuzin	ND		ND		ug/L		NC	20
Molinate	ND		ND		ug/L		NC	20
Naphthalene	ND		ND		ug/L		NC	20
Parathion	ND		ND		ug/L		NC	20
Pendimethalin (Penoxaline)	ND		ND		ug/L		NC	20
Phenanthrene	ND		ND		ug/L		NC	20
Propachlor	ND		ND		ug/L		NC	20
Pyrene	ND		ND		ug/L		NC	20
Simazine	ND		ND		ug/L		NC	20
Terbacil	ND		ND		ug/L		NC	20
Terbutylazine	ND		ND		ug/L		NC	20
Thiobencarb	ND		ND		ug/L		NC	20
Total Permethrin (mixed isomers)	ND		ND		ug/L		NC	20

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-34720-V-2-A DU

Matrix: Water

Analysis Batch: 30320

Client Sample ID: Duplicate
Prep Type: Total/NA
Prep Batch: 30258

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
trans-Nonachlor	ND		ND		ug/L		NC	20
Trifluralin	ND		ND		ug/L		NC	20
1-Methylnaphthalene	ND		ND		ug/L		NC	20
2-Methylnaphthalene	ND		ND		ug/L		NC	20

Surrogate	DU		Limits
	%Recovery	Qualifier	
2-Nitro-m-xylene	99		70 - 130
Perylene-d12	97		70 - 130
Triphenylphosphate	112		70 - 130

Method: 504.1 - EDB, DBCP and 1,2,3-TCP (GC)

Lab Sample ID: MBL 380-30432/4-A

Matrix: Water

Analysis Batch: 30502

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 30432

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,3-Trichloropropane	ND		0.040	ug/L		01/23/23 14:25	01/23/23 18:36	1
1,2-D bromo-3-Chloropropane	ND		0.010	ug/L		01/23/23 14:25	01/23/23 18:36	1
1,2-D bromoethane	ND		0.010	ug/L		01/23/23 14:25	01/23/23 18:36	1
Surrogate	MBL %Recovery	MBL Qualifier	Limits			Prepared	Analyzed	Dil Fac
1,2-Dibromopropane (Surrogate)	105		60 - 140			01/23/23 14:25	01/23/23 18:36	1

Lab Sample ID: LCS 380-30432/3-A

Matrix: Water

Analysis Batch: 30502

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 30432

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limts
1,2,3-Trichloropropane	0.200	0.209		ug/L		104	70 - 130
1,2-D bromo-3-Chloropropane	0.200	0.207		ug/L		103	70 - 130
1,2-D bromoethane	0.200	0.217		ug/L		108	70 - 130
Surrogate	LCS %Recovery	LCS Qualifier	Limits				
1,2-Dibromopropane (Surrogate)	110		60 - 140				

Lab Sample ID: MRL 380-30432/1-A

Matrix: Water

Analysis Batch: 30502

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 30432

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limts
1,2,3-Trichloropropane	0.0400	0.0406		ug/L		101	60 - 140
Surrogate	MRL %Recovery	MRL Qualifier	Limits				
1,2-Dibromopropane (Surrogate)	113		60 - 140				

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 504.1 - EDB, DBCP and 1,2,3-TCP (GC) (Continued)

Lab Sample ID: MRL 380-30432/2-A

Matrix: Water

Analysis Batch: 30502

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30432

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1,2,3-Trichloropropane	0.0500	0.0497		ug/L		99	60 - 140
1,2-D bromo-3-Chloropropane	0.0100	0.0103		ug/L		103	60 - 140
1,2-D bromoethane	0.0100	0.00924	J	ug/L		92	60 - 140
Surrogate	MRL %Recovery	MRL Qualifier	Limits				
1,2-Dibromopropane (Surr)	112			60 - 140			

Lab Sample ID: 380-34654-B-1-A MS

Matrix: Water

Analysis Batch: 30502

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 30432

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1,2,3-Trichloropropane	ND		1.26	1.41		ug/L		112	65 - 135
1,2-D bromo-3-Chloropropane	ND		0.253	0.282		ug/L		112	65 - 135
1,2-D bromoethane	ND		0.253	0.280		ug/L		111	65 - 135
Surrogate	MS %Recovery	MS Qualifier	Limits						
1,2-Dibromopropane (Surr)	109			60 - 140					

Lab Sample ID: 380-34654-J-2-A DU

Matrix: Water

Analysis Batch: 30502

Client Sample ID: Duplicate

Prep Type: Total/NA

Prep Batch: 30432

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	Limit
1,2,3-Trichloropropane	ND		ND		ug/L		NC	20
1,2-D bromo-3-Chloropropane	ND		ND		ug/L		NC	20
1,2-D bromoethane	ND		ND		ug/L		NC	20
Surrogate	DU %Recovery	DU Qualifier	Limits					
1,2-Dibromopropane (Surr)	111		60 - 140					

Method: 505 - Organochlorine Pesticides/PCBs (GC)

Lab Sample ID: MB 380-30329/7-A

Matrix: Water

Analysis Batch: 30452

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 30329

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Alachlor	ND		0.10	ug/L		01/20/23 14:15	01/20/23 19:10	1
Aldrin	ND		0.0020	ug/L		01/20/23 14:15	01/20/23 19:10	1
Chlordane (n.o.s.)	ND		0.10	ug/L		01/20/23 14:15	01/20/23 19:10	1
Dieldrin	ND		0.0020	ug/L		01/20/23 14:15	01/20/23 19:10	1
Endrin	ND		0.010	ug/L		01/20/23 14:15	01/20/23 19:10	1
gamma-BHC (Lindane)	ND		0.010	ug/L		01/20/23 14:15	01/20/23 19:10	1
Heptachlor	ND		0.010	ug/L		01/20/23 14:15	01/20/23 19:10	1
Heptachlor epoxide	ND		0.010	ug/L		01/20/23 14:15	01/20/23 19:10	1
Methoxychlor	ND		0.051	ug/L		01/20/23 14:15	01/20/23 19:10	1
PCB-1016	ND		0.071	ug/L		01/20/23 14:15	01/20/23 19:10	1

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 505 - Organochlorine Pesticides/PCBs (GC) (Continued)

Lab Sample ID: MB 380-30329/7-A

Matrix: Water

Analysis Batch: 30452

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 30329

Analyte	MB	MB	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						Prepared	Analyzed	Dil Fac
PCB-1221	ND		0.10		ug/L		01/20/23 14:15	01/20/23 19:10		1
PCB-1232	ND		0.10		ug/L		01/20/23 14:15	01/20/23 19:10		1
PCB-1242	ND		0.10		ug/L		01/20/23 14:15	01/20/23 19:10		1
PCB-1248	ND		0.10		ug/L		01/20/23 14:15	01/20/23 19:10		1
PCB-1254	ND		0.10		ug/L		01/20/23 14:15	01/20/23 19:10		1
PCB-1260	ND		0.071		ug/L		01/20/23 14:15	01/20/23 19:10		1
Polychlorinated biphenyls, Total	ND		0.10		ug/L		01/20/23 14:15	01/20/23 19:10		1
Toxaphene	ND		0.10		ug/L		01/20/23 14:15	01/20/23 19:10		1
Surrogate	MB	MB								
Tetrachloro-m-xylene	%Recovery	Qualifier	Limits							
	101		70 - 130							

Lab Sample ID: MRL 380-30329/2-A

Matrix: Water

Analysis Batch: 30452

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30329

Analyte	Spike Added	MRL	MRL	Result	Qualifier	Unit	D	%Rec	%Rec
		Result	Qualifier						
Aldrin	0.00200	ND				ug/L		94	50 - 150
Dieldrin	0.00200	0.00221				ug/L		110	50 - 150
Surrogate	MRL	MRL							
Tetrachloro-m-xylene	%Recovery	Qualifier	Limits						
	94		70 - 130						

Lab Sample ID: MRL 380-30329/3-A

Matrix: Water

Analysis Batch: 30452

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30329

Analyte	Spike Added	MRL	MRL	Result	Qualifier	Unit	D	%Rec	%Rec
		Result	Qualifier						
Alachlor	0.100	0.112				ug/L		112	50 - 150
Aldrin	0.0100	0.00927				ug/L		93	50 - 150
Dieldrin	0.0100	0.0106				ug/L		106	50 - 150
Endrin	0.0100	0.0109				ug/L		109	50 - 150
gamma-BHC (Lindane)	0.0100	0.00940	J			ug/L		94	50 - 150
Heptachlor	0.0100	0.0108				ug/L		108	50 - 150
Heptachlor epoxide	0.0100	0.0116				ug/L		116	50 - 150
Methoxychlor	0.0500	0.0505				ug/L		101	50 - 150
Surrogate	MRL	MRL							
Tetrachloro-m-xylene	%Recovery	Qualifier	Limits						
	100		70 - 130						

Lab Sample ID: MRL 380-30329/4-A

Matrix: Water

Analysis Batch: 30452

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30329

Analyte	Spike Added	MRL	MRL	Result	Qualifier	Unit	D	%Rec	%Rec
		Result	Qualifier						
Toxaphene	0.500	0.464				ug/L		93	50 - 150

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 505 - Organochlorine Pesticides/PCBs (GC) (Continued)

Lab Sample ID: MRL 380-30329/4-A

Matrix: Water

Analysis Batch: 30452

Surrogate	MRL	MRL	
	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene	99		70 - 130

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30329

Lab Sample ID: MRL 380-30329/5-A

Matrix: Water

Analysis Batch: 30452

Analyte	Spike	MRL	MRL	
	Added	Result	Qualifier	Unit
Toxaphene	0.100	0.112		ug/L

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 30329

Surrogate	%Recovery	Qualifier	Limits	
Tetrachloro-m-xylene	94		70 - 130	

Lab Sample ID: MRL 380-30329/6-A

Matrix: Water

Analysis Batch: 30452

Analyte	Spike	MRL	MRL	
	Added	Result	Qualifier	Unit
Chlordane (n.o.s.)	0.0997	0.0936	J	ug/L

Surrogate	MRL	MRL	
	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene	93		70 - 130

Lab Sample ID: 380-34454-P-1-A MS

Matrix: Water

Analysis Batch: 30452

Analyte	Sample	Sample	Spike	MS	MS	
	Result	Qualifier	Added	Result	Qualifier	Unit
Alachlor	ND		1.02	1.11		ug/L
Aldrin	ND		0.102	0.108		ug/L
Dieldrin	ND		0.102	0.107		ug/L
Endrin	ND		0.102	0.107		ug/L
gamma-BHC (Lindane)	ND		0.102	0.0871		ug/L
Heptachlor	ND		0.102	0.110		ug/L
Heptachlor epoxide	ND		0.102	0.109		ug/L
Methoxychlor	ND		0.509	0.530		ug/L

Surrogate	MS	MS	
	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene	99		70 - 130

Analyte	Sample	Sample	Spike	MS	MS	
	Result	Qualifier	Added	Result	Qualifier	Unit
Chlordane (n.o.s.)	ND		0.506	0.474		ug/L

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 30329

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 30329

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 505 - Organochlorine Pesticides/PCBs (GC) (Continued)

Lab Sample ID: 380-34454-Q-1-A MS

Matrix: Water

Analysis Batch: 30452

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 30329

Surrogate	MS	MS	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene			91		70 - 130

Lab Sample ID: 380-34654-E-1-A MS

Matrix: Water

Analysis Batch: 30452

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 30329

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec
	Result	Qualifier	Added	Result	Qualifier				
Alachlor	ND		0.200	0.204		ug/L	102	65 - 135	
Aldrin	ND		0.0200	0.0260		ug/L	130	65 - 135	
Dieldrin	0.058		0.0200	0.0715		ug/L	68	65 - 135	
Endrin	ND		0.0200	0.0192		ug/L	96	65 - 135	
gamma-BHC (Lindane)	ND		0.0200	0.0151		ug/L	76	65 - 135	
Heptachlor	ND		0.0200	0.0205		ug/L	103	65 - 135	
Heptachlor epoxide	0.018		0.0200	0.0370		ug/L	95	65 - 135	
Methoxychlor	ND		0.100	0.0849		ug/L	85	65 - 135	
Surrogate	MS	MS							
Tetrachloro-m-xylene	99	%Recovery	Qualifier	Limits					
				70 - 130					

Lab Sample ID: 380-34654-F-1-A MS

Matrix: Water

Analysis Batch: 30452

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 30329

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec
	Result	Qualifier	Added	Result	Qualifier				
Toxaphene	ND		2.51	2.14		ug/L	86	65 - 135	
Surrogate	MS	MS							
Tetrachloro-m-xylene	94	%Recovery	Qualifier	Limits					
				70 - 130					

Method: 300.0 - Anions, Ion Chromatography

Lab Sample ID: MB 380-30150/4

Matrix: Water

Analysis Batch: 30150

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Nitrate as N	ND		0.050	mg/L			01/18/23 13:41	1
Nitrate Nitrite as N	ND		0.050	mg/L			01/18/23 13:41	1
Nitrite as N	ND		0.050	mg/L			01/18/23 13:41	1

Lab Sample ID: LCS 380-30150/7

Matrix: Water

Analysis Batch: 30150

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike	LCS	LCS	Unit	D	%Rec	%Rec
	Added	Result	Qualifier				
Nitrate as N	2.50	2.47		mg/L		99	90 - 110
Nitrate Nitrite as N	3.50	3.47		mg/L		99	90 - 110
Nitrite as N	1.00	0.995		mg/L		100	90 - 110

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 300.0 - Anions, Ion Chromatography (Continued)

Lab Sample ID: LCSD 380-30150/8

Matrix: Water

Analysis Batch: 30150

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Nitrate as N	2.50	2.54		mg/L		101	90 - 110	3	20
Nitrate Nitrite as N	3.50	3.56		mg/L		102	90 - 110	3	20
Nitrite as N	1.00	1.02		mg/L		102	90 - 110	2	20

Lab Sample ID: MRL 380-30150/5

Matrix: Water

Analysis Batch: 30150

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Nitrate as N	0.0125	0.0127	J	mg/L		101	50 - 150
Nitrate Nitrite as N	0.0250	0.0234	J	mg/L		94	50 - 150
Nitrite as N	0.0125	0.0107	J	mg/L		86	50 - 150

Lab Sample ID: MRL 380-30150/6

Matrix: Water

Analysis Batch: 30150

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Nitrate as N	0.0500	0.0456	J	mg/L		91	50 - 150
Nitrate Nitrite as N	0.100	0.0957		mg/L		96	50 - 150
Nitrite as N	0.0500	0.0501		mg/L		100	50 - 150

Lab Sample ID: 380-34715-T-1 MS

Matrix: Water

Analysis Batch: 30150

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Nitrate as N	6.9		2.50	9.32		mg/L		97	80 - 120
Nitrate Nitrite as N	6.9		3.50	10.3		mg/L		97	80 - 120
Nitrite as N	ND		1.00	0.970		mg/L		97	80 - 120

Lab Sample ID: 380-34715-T-1 MSD

Matrix: Water

Analysis Batch: 30150

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Nitrate as N	6.9		2.50	9.34		mg/L		98	80 - 120	0	20
Nitrate Nitrite as N	6.9		3.50	10.3		mg/L		97	80 - 120	0	20
Nitrite as N	ND		1.00	0.956		mg/L		96	80 - 120	1	20

Lab Sample ID: MB 380-30151/4

Matrix: Water

Analysis Batch: 30151

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	ND		0.50	mg/L			01/18/23 13:41	1
Sulfate	ND		0.25	mg/L			01/18/23 13:41	1

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 300.0 - Anions, Ion Chromatography (Continued)

Lab Sample ID: LCS 380-30151/7

Matrix: Water

Analysis Batch: 30151

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	25.0	26.0		mg/L		104	90 - 110
Sulfate	50.0	51.2		mg/L		102	90 - 110

Lab Sample ID: LCSD 380-30151/8

Matrix: Water

Analysis Batch: 30151

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	RPD	RPD Limit
Chloride	25.0	26.9		mg/L		108	90 - 110	3 20
Sulfate	50.0	52.9		mg/L		106	90 - 110	3 20

Lab Sample ID: MRL 380-30151/5

Matrix: Water

Analysis Batch: 30151

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	0.125	0.122	J	mg/L		98	50 - 150
Sulfate	0.250	0.213	J	mg/L		85	50 - 150

Lab Sample ID: MRL 380-30151/6

Matrix: Water

Analysis Batch: 30151

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	0.500	0.465	J	mg/L		93	50 - 150
Sulfate	1.00	0.868		mg/L		87	50 - 150

Lab Sample ID: 380-34715-T-1 MS

Matrix: Water

Analysis Batch: 30151

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	53		25.0	76.7		mg/L		96	80 - 120
Sulfate	100		50.0	153		mg/L		101	80 - 120

Lab Sample ID: 380-34715-T-1 MSD

Matrix: Water

Analysis Batch: 30151

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	RPD	RPD Limit
Chloride	53		25.0	76.8		mg/L		97	80 - 120	0 20
Sulfate	100		50.0	153		mg/L		101	80 - 120	0 20

Lab Sample ID: MB 380-30464/4

Matrix: Water

Analysis Batch: 30464

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Bromide	ND		5.0	ug/L			01/23/23 13:47	1

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 300.0 - Anions, Ion Chromatography (Continued)

Lab Sample ID: LCS 380-30464/5

Matrix: Water

Analysis Batch: 30464

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	
Bromide	100	99.4		ug/L	99	99	90 - 110	

Lab Sample ID: LCSD 380-30464/6

Matrix: Water

Analysis Batch: 30464

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Bromide	100	98.8		ug/L	99	99	90 - 110	1	10

Lab Sample ID: MRL 380-30464/3

Matrix: Water

Analysis Batch: 30464

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits	
Bromide	5.00	5.59		ug/L	112	112	75 - 125	

Lab Sample ID: 380-34768-A-4 MS

Matrix: Water

Analysis Batch: 30464

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits	
Bromide	ND		50.0	51.6		ug/L	96	96	80 - 120	

Lab Sample ID: 380-34768-A-4 MSD

Matrix: Water

Analysis Batch: 30464

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Bromide	ND		50.0	53.7		ug/L	100	100	80 - 120	4	20

Method: 245.1 - Mercury (CVAA)

Lab Sample ID: MB 810-45189/1-A

Matrix: Water

Analysis Batch: 45205

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 45189

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	ND		0.10	ug/L		01/20/23 16:44	01/20/23 19:02	1

Lab Sample ID: LCS 810-45189/3-A

Matrix: Water

Analysis Batch: 45205

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 45189

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	
Mercury	1.00	0.982		ug/L	98	98	85 - 115	

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 245.1 - Mercury (CVAA) (Continued)

Lab Sample ID: 810-50806-C-1-B MS

Matrix: Water

Analysis Batch: 45205

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 45189

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Mercury	ND		1.00	1.01		ug/L	101		70 - 130

Lab Sample ID: 810-50806-C-1-C MSD

Matrix: Water

Analysis Batch: 45205

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 45189

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	RPD	Limit
Mercury	ND		1.00	1.06		ug/L	106		70 - 130	4 20

Method: SM 2320B - Alkalinity

Lab Sample ID: MB 380-30308/39

Matrix: Water

Analysis Batch: 30308

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
A alkalinity	ND		2.0	mg/L			01/19/23 17:39	1
Bicarbonate Alkalinity as CaCO3	ND		2.0	mg/L			01/19/23 17:39	1
Carbonate Alkalinity as CaCO3	ND		2.0	mg/L			01/19/23 17:39	1

Lab Sample ID: MB 380-30308/7

Matrix: Water

Analysis Batch: 30308

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
A alkalinity	ND		2.0	mg/L			01/19/23 12:56	1
Bicarbonate Alkalinity as CaCO3	2.05	B	2.0	mg/L			01/19/23 12:56	1
Carbonate Alkalinity as CaCO3	ND		2.0	mg/L			01/19/23 12:56	1

Lab Sample ID: LCS 380-30308/37

Matrix: Water

Analysis Batch: 30308

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
A alkalinity	100	99.8		mg/L	100		90 - 110

Lab Sample ID: LCSD 380-30308/22

Matrix: Water

Analysis Batch: 30308

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
A alkalinity	100	97.3		mg/L	97		90 - 110	0	20

Lab Sample ID: LCSD 380-30308/54

Matrix: Water

Analysis Batch: 30308

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
A alkalinity	100	99.1		mg/L	99		90 - 110	1	20

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: SM 2320B - Alkalinity (Continued)

Lab Sample ID: LLCS 380-30308/38

Matrix: Water

Analysis Batch: 30308

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits	
A alkalinity	20.0	20.7		mg/L	104		90 - 110	

Lab Sample ID: MRL 380-30308/40

Matrix: Water

Analysis Batch: 30308

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits	
A alkalinity	2.00	1.93	J	mg/L	97		50 - 150	

Lab Sample ID: 380-34715-E-1 MS

Matrix: Water

Analysis Batch: 30308

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits	
A alkalinity	220	F1	100	282	F1	mg/L	63		80 - 120	

Lab Sample ID: 380-34715-E-1 MSD

Matrix: Water

Analysis Batch: 30308

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD RPD Limit
A alkalinity	220	F1	100	283	F1	mg/L	64		80 - 120	0 20

Lab Sample ID: 380-34715-E-1 DU

Matrix: Water

Analysis Batch: 30308

Client Sample ID: Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier		DU Result	DU Qualifier	Unit	D			RPD RPD Limit
A alkalinity	220	F1		221		mg/L				1 20
Bicarbonate Alkalinity as CaCO ₃	220	^2		221		mg/L				1 20
Carbonate Alkalinity as CaCO ₃	ND			ND		mg/L				NC 20

Method: SM 2510B - Conductivity, Specific Conductance

Lab Sample ID: MB 380-30309/35

Matrix: Water

Analysis Batch: 30309

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier		RL		Unit	D	Prepared	Analyzed	Dil Fac
Specific Conductance	ND			2.0		umhos/cm			01/19/23 17:39	1

Lab Sample ID: LCS 380-30309/38

Matrix: Water

Analysis Batch: 30309

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	
Specific Conductance	1000	990		umhos/cm	99		90 - 110	

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: SM 2510B - Conductivity, Specific Conductance (Continued)

Lab Sample ID: LCS 380-30309/58

Matrix: Water

Analysis Batch: 30309

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Specific Conductance	1000	978		umhos/cm		98	90 - 110		

Lab Sample ID: LCSD 380-30309/22

Matrix: Water

Analysis Batch: 30309

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Specific Conductance	1000	995		umhos/cm		99	90 - 110	1	10

Lab Sample ID: LCSD 380-30309/50

Matrix: Water

Analysis Batch: 30309

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Specific Conductance	1000	985		umhos/cm		99	90 - 110	0	10

Lab Sample ID: MRL 380-30309/36

Matrix: Water

Analysis Batch: 30309

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Specific Conductance	2.00	2.60		umhos/cm		130	50 - 150		

Lab Sample ID: MRL 380-30309/8

Matrix: Water

Analysis Batch: 30309

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Specific Conductance	2.00	2.60		umhos/cm		130	50 - 150		

Lab Sample ID: 380-34715-E-1 DU

Matrix: Water

Analysis Batch: 30309

Client Sample ID: Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
Specific Conductance	790	^2	809		umhos/cm		2	20

Method: SM 4500 F C - Fluoride

Lab Sample ID: MB 380-30237/6

Matrix: Water

Analysis Batch: 30237

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoride	ND		0.050	mg/L			01/19/23 13:42	1

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: SM 4500 F C - Fluoride (Continued)

Lab Sample ID: LCS 380-30237/8

Matrix: Water

Analysis Batch: 30237

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	
Fluoride	1.00	0.996		mg/L	100		90 - 110	

Lab Sample ID: LCSD 380-30237/9

Matrix: Water

Analysis Batch: 30237

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Fluoride	1.00	0.999		mg/L	100		90 - 110	0	10

Lab Sample ID: MRL 380-30237/7

Matrix: Water

Analysis Batch: 30237

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits	
Fluoride	0.0500	0.0484	J	mg/L	97		50 - 150	

Method: SM 4500 H+ B - pH

Lab Sample ID: MB 380-30310/35

Matrix: Water

Analysis Batch: 30310

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
pH	5.8			SU			01/19/23 17:39	1

Lab Sample ID: LCS 380-30310/36

Matrix: Water

Analysis Batch: 30310

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	
pH	6.00	6.0		SU	100		98 - 102	

Lab Sample ID: LCSD 380-30310/23

Matrix: Water

Analysis Batch: 30310

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
pH	6.00	6.0		SU	100		98 - 102	0	2

Lab Sample ID: LCSD 380-30310/49

Matrix: Water

Analysis Batch: 30310

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
pH	6.00	6.0		SU	100		98 - 102	0	2

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: SM 4500 H+ B - pH (Continued)

Lab Sample ID: 380-34715-E-1 DU

Matrix: Water

Analysis Batch: 30310

Client Sample ID: Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
pH	8.0		8.0		SU		0.5	2

Method: SM 4500 S2 D - Sulfide, Total

Lab Sample ID: MB 380-30546/1

Matrix: Water

Analysis Batch: 30546

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Sulfide	ND		0.050	mg/L			01/24/23 12:17	1

Lab Sample ID: LCS 380-30546/4

Matrix: Water

Analysis Batch: 30546

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Sulfide	0.250	0.240		mg/L		96	90 - 110

Lab Sample ID: LCSD 380-30546/16

Matrix: Water

Analysis Batch: 30546

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Sulfide	0.250	0.241		mg/L		96	90 - 110	0	20

Lab Sample ID: MRL 380-30546/15

Matrix: Water

Analysis Batch: 30546

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Sulfide	0.0500	0.0460	J	mg/L		92	50 - 150

Lab Sample ID: MRL 380-30546/2

Matrix: Water

Analysis Batch: 30546

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Sulfide	0.0500	0.0460	J	mg/L		92	50 - 150

Lab Sample ID: 380-34727-1 MS

Matrix: Drinking Water

Analysis Batch: 30546

Client Sample ID: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400)
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Sulfide	ND		0.250	0.235		mg/L		94	80 - 120

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: SM 4500 S2 D - Sulfide, Total (Continued)

Lab Sample ID: 380-34727-1 MSD
Matrix: Drinking Water
Analysis Batch: 30546

Client Sample ID: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400)
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Sulfide	ND		0.250	0.252		mg/L	101	80 - 120	7	20	

Method: 625 Acid/Base/PAH + TICs - EPA 625 Base/Neutral and Acid Organics i

Lab Sample ID: 103732-B1
Matrix: BlankMatrix
Analysis Batch: O-40114

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: O-40114_P

Analyte	Blank Result	Blank Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
1-Methylphenanthrene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
2,3,5-Trimethylnaphthalene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
2,4,5-Trichlorophenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
2,4,6-Trichlorophenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
2,4-Dichlorophenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
2,4-Dinitrophenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/13/23 18:32		1
2,6-Dichlorophenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
2,6-Dimethylnaphthalene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
2,6-Di-tert-butyl-4-methylphenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
2,6-Di-tert-butylphenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
2-Chloronaphthalene	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
2-Chlorophenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
2-Methyl-4,6-dinitrophenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/13/23 18:32		1
2-Methylnaphthalene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
2-Methylphenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/13/23 18:32		1
2-Nitroaniline	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
2-Nitrophenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/13/23 18:32		1
3+4-Methylphenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/13/23 18:32		1
3-Nitroaniline	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
4-Bromophenylphenyl ether	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
4-Chloro-3-methylphenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/13/23 18:32		1
4-Chloroaniline	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
4-Chlorophenylphenyl ether	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
4-Nitroaniline	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
4-Nitrophenol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/13/23 18:32		1
6-tert-butyl-2,4-dimethylphenol	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
Acenaphthene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
Acenaphthylene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
Aniline	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
Anthracene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
Benz[a]anthracene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
Benzidine	ND		0.1	0.05	µg/L	01/20/23 00:00	02/13/23 18:32		1
Benzo[a]pyrene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
Benzo[b]fluoranthene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
Benzo[e]pyrene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
Benzo[g,h,i]perylene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
Benzo[k]fluoranthene	ND		0.005	0.001	µg/L	01/20/23 00:00	02/13/23 18:32		1
Benzoic Acid	ND		0.2	0.1	µg/L	01/20/23 00:00	02/13/23 18:32		1
Benzyl Alcohol	ND		0.2	0.1	µg/L	01/20/23 00:00	02/13/23 18:32		1

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 625 Acid/Base/PAH + TICs - EPA 625 Base/Neutral and Acid Organics i (Continued)

Lab Sample ID: 103732-B1

Matrix: BlankMatrix

Analysis Batch: O-40114

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: O-40114_P

Analyte	Blank Result	Blank Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Biphenyl	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Bis(2-Chloroethoxy) methane	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
Bis(2-Chloroethyl) ether	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
Bis(2-Chloroisopropyl) ether	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
Chrysene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Dibenz[a,h]anthracene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Dibenzo[a,l]pyrene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Dibenzofuran	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
Dibenzothiophene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Disalicylidene propanediamine	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
Fluoranthene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Fluorene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Hexachloroethane	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
Indeno[1,2,3-cd]pyrene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Naphthalene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Nitrobenzene	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
N-Nitrosodi-n-propylamine	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
N-Nitrosodiphenylamine	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
Pentachlorophenol	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
Perylene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Phenanthrene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1
Phenol	ND		0.2	0.1	µg/L		01/20/23 00:00	02/13/23 18:32	1
p-tert-Butylphenol	ND		0.1	0.05	µg/L		01/20/23 00:00	02/13/23 18:32	1
Pyrene	ND		0.005	0.001	µg/L		01/20/23 00:00	02/13/23 18:32	1

Surrogate	Blank %Recovery	Blank Qualifier	Limits	Prepared	Analyzed	Dil Fac	
(2,4,6-Tribromophenol)	93		30 - 130		01/20/23 00:00	02/13/23 18:32	1
(d10-Acenaphthene)	98		27 - 133		01/20/23 00:00	02/13/23 18:32	1
(d10-Phenanthrene)	97		43 - 129		01/20/23 00:00	02/13/23 18:32	1
(d12-Chrysene)	104		52 - 144		01/20/23 00:00	02/13/23 18:32	1
(d12-Perylene)	96		36 - 161		01/20/23 00:00	02/13/23 18:32	1
(d5-Phenol)	76		0 - 130		01/20/23 00:00	02/13/23 18:32	1
(d8-Naphthalene)	86		25 - 125		01/20/23 00:00	02/13/23 18:32	1

Lab Sample ID: 103732-BS1

Matrix: BlankMatrix

Analysis Batch: O-40114

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: O-40114_P

Analyte	Spike Added	LCS		Unit	D	%Rec	Limits
		Result	Qualifier				
1-Methylnaphthalene	0.5	0.454		µg/L		91	31 - 128
1-Methylphenanthrene	0.5	0.454		µg/L		91	66 - 127
2,3,5-Trimethylnaphthalene	0.5	0.482		µg/L		96	55 - 122
2,4,5-Trichlorophenol	1	0.923		µg/L		92	30 - 130
2,4,6-Trichlorophenol	1	0.791		µg/L		79	30 - 130
2,4-Dichlorophenol	1	0.74		µg/L		74	51 - 117
2,4-Dinitrophenol	1	1.13		µg/L		113	0 - 152
2,6-Dichlorophenol	0.5	0.355		µg/L		71	30 - 130
2,6-Dimethylnaphthalene	0.5	0.459		µg/L		92	48 - 120

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 625 Acid/Base/PAH + TICs - EPA 625 Base/Neutral and Acid Organics i (Continued)

Lab Sample ID: 103732-BS1

Matrix: BlankMatrix

Analysis Batch: O-40114

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: O-40114_P

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
2,6-Di-tert-butyl-4-methylphenol	1	0.724		µg/L	72	50 - 150	
2,6-Di-tert-butylphenol	1	0.821		µg/L	82	50 - 150	
2-Chloronaphthalene	1	0.849		µg/L	85	53 - 130	
2-Chlorophenol	1	0.661		µg/L	66	41 - 120	
2-Methyl-4,6-dinitrophenol	1	1.08		µg/L	108	0 - 141	
2-Methylnaphthalene	1.5	1.4		µg/L	93	47 - 130	
2-Methylphenol	1	0.761		µg/L	76	40 - 117	
2-Nitroaniline	1	0.771		µg/L	77	69 - 114	
2-Nitrophenol	1	0.632		µg/L	63	40 - 117	
3+4-Methylphenol	1	0.784		µg/L	78	0 - 130	
3-Nitroaniline	1	0.794		µg/L	79	23 - 137	
4-Bromophenylphenyl ether	1	0.824		µg/L	82	61 - 132	
4-Chloro-3-methylphenol	1	0.839		µg/L	84	51 - 128	
4-Chloroaniline	1	0.639		µg/L	64	50 - 150	
4-Chlorophenylphenyl ether	1	0.862		µg/L	86	63 - 130	
4-Nitroaniline	1	0.851		µg/L	85	10 - 159	
4-Nitrophenol	1	0.824		µg/L	82	10 - 164	
6-tert-butyl-2,4-dimethylphenol	1	0.721		µg/L	72	50 - 150	
Acenaphthene	1.5	1.49		µg/L	99	53 - 131	
Acenaphthylene	1.5	1.47		µg/L	98	43 - 140	
Aniline	1	0.571		µg/L	57	50 - 150	
Anthracene	1.5	1.49		µg/L	99	58 - 135	
Benz[a]anthracene	1.5	1.6		µg/L	107	55 - 145	
Benzidine	1	0.0145		µg/L	1	0 - 125	
Benzo[a]pyrene	1.5	1.57		µg/L	105	51 - 143	
Benzo[b]fluoranthene	1.5	1.65		µg/L	110	46 - 165	
Benzo[e]pyrene	0.5	0.49		µg/L	98	42 - 152	
Benzo[g,h,i]perylene	1.5	1.54		µg/L	103	63 - 133	
Benzo[k]fluoranthene	1.5	1.59		µg/L	106	56 - 145	
Benzoic Acid	1	0.63		µg/L	63	2 - 145	
Benzyl Alcohol	1	0.783		µg/L	78	43 - 148	
Biphenyl	0.5	0.478		µg/L	96	56 - 119	
Bis(2-Chloroethoxy) methane	1	0.835		µg/L	83	66 - 122	
Bis(2-Chloroethyl) ether	1	0.78		µg/L	78	43 - 127	
Bis(2-Chloroisopropyl) ether	1	0.765		µg/L	76	49 - 128	
Chrysene	1.5	1.65		µg/L	110	56 - 141	
Dibenz[a,h]anthracene	1.5	1.76		µg/L	117	55 - 150	
Dibenz[a,l]pyrene	0.5	0.456		µg/L	91	50 - 150	
Dibenzofuran	1	0.824		µg/L	82	50 - 150	
Dibenzothiophene	0.5	0.475		µg/L	95	46 - 126	
Disalicylidene propanediamine	50	51.7		µg/L	103	50 - 150	
Fluoranthene	1.5	1.53		µg/L	102	60 - 146	
Fluorene	1.5	1.55		µg/L	103	58 - 131	
Hexachloroethane	1	0.621		µg/L	62	27 - 130	
Indeno[1,2,3-cd]pyrene	1.5	1.77		µg/L	118	50 - 151	
Naphthalene	1.5	1.3		µg/L	87	41 - 126	
Nitrobenzene	1	0.708		µg/L	71	54 - 111	
N-Nitrosodi-n-propylamine	1	0.771		µg/L	77	61 - 152	
N-Nitrosodiphenylamine	1	0.864		µg/L	86	49 - 142	

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 625 Acid/Base/PAH + TICs - EPA 625 Base/Neutral and Acid Organics i (Continued)

Lab Sample ID: 103732-BS1

Matrix: BlankMatrix

Analysis Batch: O-40114

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: O-40114_P

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Pentachlorophenol	1	1.1		µg/L		110	36 - 111
Perylene	0.5	0.463		µg/L		93	48 - 141
Phenanthrene	1.5	1.5		µg/L		100	67 - 127
Phenol	1	0.693		µg/L		69	29 - 114
p-tert-Butylphenol	1	0.865		µg/L		87	50 - 150
Pyrene	1.5	1.53		µg/L		102	54 - 156

LCS LCS

Surrogate	%Recovery	Qualifier	Limits
(2,4,6-Tribromophenol)	108		30 - 130
(d10-Acenaphthene)	93		27 - 133
(d10-Phenanthrene)	93		43 - 129
(d12-Chrysene)	102		52 - 144
(d12-Perylene)	95		36 - 161
(d5-Phenol)	82		0 - 130
(d8-Naphthalene)	80		25 - 125

Lab Sample ID: 103732-BS2

Matrix: BlankMatrix

Analysis Batch: O-40114

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: O-40114_P

Analyte	Spike Added	LCS DUP Result	LCS DUP Qualifier	Unit	D	%Rec	Limits	RPD	Limit
1-Methylnaphthalene	0.5	0.49		µg/L		98	31 - 128	7	30
1-Methylphenanthrene	0.5	0.484		µg/L		97	66 - 127	6	30
2,3,5-Trimethylnaphthalene	0.5	0.499		µg/L		100	55 - 122	4	30
2,4,5-Trichlorophenol	1	0.827		µg/L		83	30 - 130	10	30
2,4,6-Trichlorophenol	1	0.809		µg/L		81	30 - 130	2	30
2,4-Dichlorophenol	1	0.832		µg/L		83	51 - 117	11	30
2,4-Dinitrophenol	1	0.955		µg/L		95	0 - 152	16	30
2,6-Dichlorophenol	0.5	0.404		µg/L		81	30 - 130	13	30
2,6-Dimethylnaphthalene	0.5	0.475		µg/L		95	48 - 120	3	30
2,6-Di-tert-butyl-4-methylphenol	1	0.774		µg/L		77	50 - 150	7	30
2,6-Di-tert-butylphenol	1	0.854		µg/L		85	50 - 150	4	30
2-Chloronaphthalene	1	0.889		µg/L		89	53 - 130	5	30
2-Chlorophenol	1	0.788		µg/L		79	41 - 120	18	30
2-Methyl-4,6-dinitrophenol	1	0.869		µg/L		87	0 - 141	22	30
2-Methylnaphthalene	1.5	1.52		µg/L		101	47 - 130	8	30
2-Methylphenol	1	0.853		µg/L		85	40 - 117	11	30
2-Nitroaniline	1	0.859		µg/L		86	69 - 114	11	30
2-Nitrophenol	1	0.759		µg/L		76	40 - 117	19	30
3+4-Methylphenol	1	0.841		µg/L		84	0 - 130	7	30
3-Nitroaniline	1	0.852		µg/L		85	23 - 137	7	30
4-Bromophenylphenyl ether	1	0.871		µg/L		87	61 - 132	6	30
4-Chloro-3-methylphenol	1	0.903		µg/L		90	51 - 128	7	30
4-Chloroaniline	1	0.666		µg/L		67	50 - 150	5	30
4-Chlorophenylphenyl ether	1	0.883		µg/L		88	63 - 130	2	30
4-Nitroaniline	1	0.919		µg/L		92	10 - 159	8	30
4-Nitrophenol	1	0.871		µg/L		87	10 - 164	6	30
6-tert-butyl-2,4-dimethylphenol	1	0.778		µg/L		78	50 - 150	8	30

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 625 Acid/Base/PAH + TICs - EPA 625 Base/Neutral and Acid Organics i (Continued)

Lab Sample ID: 103732-BS2

Matrix: BlankMatrix

Analysis Batch: O-40114

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: O-40114_P

Analyte	Spike Added	LCS DUP Result	LCS DUP Qualifier	Unit	D	%Rec	Limits	RPD	RPD Limit
Acenaphthene	1.5	1.57		µg/L	105	53 - 131	6	30	
Acenaphthylene	1.5	1.52		µg/L	101	43 - 140	3	30	
Aniline	1	0.635		µg/L	63	50 - 150	12	30	
Anthracene	1.5	1.51		µg/L	101	58 - 135	2	30	
Benz[a]anthracene	1.5	1.62		µg/L	108	55 - 145	1	30	
Benzidine	1	0.00615		µg/L	1	0 - 125	0	30	
Benzo[a]pyrene	1.5	1.57		µg/L	105	51 - 143	0	30	
Benzo[b]fluoranthene	1.5	1.7		µg/L	113	46 - 165	3	30	
Benzo[e]pyrene	0.5	0.455		µg/L	91	42 - 152	7	30	
Benzo[g,h,i]perylene	1.5	1.55		µg/L	103	63 - 133	0	30	
Benzo[k]fluoranthene	1.5	1.6		µg/L	107	56 - 145	1	30	
Benzoic Acid	1	0.619		µg/L	62	2 - 145	2	30	
Benzyl Alcohol	1	0.862		µg/L	86	43 - 148	10	30	
Biphenyl	0.5	0.497		µg/L	99	56 - 119	3	30	
Bis(2-Chloroethoxy) methane	1	0.951		µg/L	95	66 - 122	12	30	
Bis(2-Chloroethyl) ether	1	0.943		µg/L	94	43 - 127	19	30	
Bis(2-Chloroisopropyl) ether	1	0.899		µg/L	90	49 - 128	17	30	
Chrysene	1.5	1.65		µg/L	110	56 - 141	0	30	
Dibenz[a,h]anthracene	1.5	1.76		µg/L	117	55 - 150	0	30	
Dibenzo[a,l]pyrene	0.5	0.462		µg/L	92	50 - 150	1	30	
Dibenzofuran	1	0.881		µg/L	88	50 - 150	7	30	
Dibenzothiophene	0.5	0.5		µg/L	100	46 - 126	5	30	
Disalicylidene propanediamine	50	59.8		µg/L	120	50 - 150	15	30	
Fluoranthene	1.5	1.58		µg/L	105	60 - 146	3	30	
Fluorene	1.5	1.58		µg/L	105	58 - 131	2	30	
Hexachloroethane	1	0.704		µg/L	70	27 - 130	12	30	
Indeno[1,2,3-cd]pyrene	1.5	1.85		µg/L	123	50 - 151	4	30	
Naphthalene	1.5	1.49		µg/L	99	41 - 126	13	30	
Nitrobenzene	1	0.819		µg/L	82	54 - 111	14	30	
N-Nitrosodi-n-propylamine	1	0.84		µg/L	84	61 - 152	9	30	
N-Nitrosodiphenylamine	1	0.887		µg/L	89	49 - 142	3	30	
Pentachlorophenol	1	0.949		µg/L	95	36 - 111	15	30	
Perylene	0.5	0.487		µg/L	97	48 - 141	4	30	
Phenanthrene	1.5	1.54		µg/L	103	67 - 127	3	30	
Phenol	1	0.808		µg/L	81	29 - 114	16	30	
p-tert-Butylphenol	1	0.937		µg/L	94	50 - 150	9	30	
Pyrene	1.5	1.58		µg/L	105	54 - 156	3	30	

Surrogate	LCS DUP	LCS DUP	Limits
	%Recovery	Qualifier	
(2,4,6-Tribromophenol)	107		30 - 130
(d10-Acenaphthene)	96		27 - 133
(d10-Phenanthrene)	96		43 - 129
(d12-Chrysene)	105		52 - 144
(d12-Perylene)	92		36 - 161
(d5-Phenol)	95		0 - 130
(d8-Naphthalene)	93		25 - 125

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 8015 Ethanol - SW846 8015B Gasoline Range Organics

Lab Sample ID: 23MEA003WB
Matrix: WATER
Analysis Batch: 23MEA003W

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
ETHANOL	ND	U	2000		ug/L			01/20/23 12:21	1

Lab Sample ID: 23MEA003WL
Matrix: WATER
Analysis Batch: 23MEA003W

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
ETHANOL	10000	9730		ug/L		97	60 - 130

Lab Sample ID: 23A194-01M
Matrix: WATER
Analysis Batch: 23MEA003W

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
ETHANOL	ND		10000	9420		ug/L		94	60 - 130

Lab Sample ID: 23A194-01S
Matrix: WATER
Analysis Batch: 23MEA003W

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD Limit
ETHANOL	ND		10000	9260		ug/L		93	60 - 130	2	30

Method: 8015 Gas (Purgeable) LL (EAL) - SW846 8015B Gasoline Range Organics

Lab Sample ID: 23VG39A08B
Matrix: WATER
Analysis Batch: 23VG39A08

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
GASOLINE	ND	U	0.02		mg/L			01/19/23 13:12	1

Surrogate
BROMOFLUOROBENZENE

Prepared
Analyzed
Dil Fac

01/19/23 13:12

Lab Sample ID: 23VG39A08L
Matrix: WATER
Analysis Batch: 23VG39A08

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
GASOLINE	0.5	0.437		mg/L		87	60 - 130

Surrogate
BROMOFLUOROBENZENE

**LCS
Result**
%Recovery
102

Limits
70 - 130

Eurofins Drinking Water Testing Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Method: 8015 LL DRO/MRO/JP5/JP8 - 8015 - TPH DRO/ORO

Lab Sample ID: 23DSA029WB

Matrix: WATER

Analysis Batch: 23DSA029W

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
DIESEL	ND	U	0.025		mg/L			01/24/23 18:24	1
JP5	ND	U	0.05		mg/L			01/24/23 18:24	1
JP8	ND	U	0.05		mg/L			01/24/23 18:24	1
MOTOR OIL	ND	U	0.05		mg/L			01/24/23 18:24	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
BROMOBENZENE					01/24/23 18:24	1
HEXACOSANE					01/24/23 18:24	1

Lab Sample ID: 23DSA029WL

Matrix: WATER

Analysis Batch: 23DSA029W

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
DIESEL	2.5	2.43		mg/L		97	50 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
BROMOBENZENE	102		60 - 130
HEXACOSANE	115		60 - 130

Lab Sample ID: 23J5A029WL

Matrix: WATER

Analysis Batch: 23DSA029W

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
JP5	2.5	2.51		mg/L		100	30 - 160

Surrogate	LCS %Recovery	LCS Qualifier	Limits
BROMOBENZENE	103		60 - 130
HEXACOSANE	115		60 - 130

Lab Sample ID: 23J8A029WL

Matrix: WATER

Analysis Batch: 23DSA029W

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
JP8	2.5	2.1		mg/L		84	30 - 160

Surrogate	LCS %Recovery	LCS Qualifier	Limits
BROMOBENZENE	105		60 - 130
HEXACOSANE	120		60 - 130

Eurofins Drinking Water Testing Pomona

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

GC/MS VOA

Analysis Batch: 30366

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	524.2	
380-34727-2	TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TF	Total/NA	Water	524.2	
MB 380-30366/5	Method Blank	Total/NA	Water	524.2	
LCS 380-30366/2	Lab Control Sample	Total/NA	Water	524.2	
LCSD 380-30366/3	Lab Control Sample Dup	Total/NA	Water	524.2	
MRL 380-30366/4	Lab Control Sample	Total/NA	Water	524.2	

Analysis Batch: 30382

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-2	TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TF	Total/NA	Water	524.2	
MB 380-30382/15	Method Blank	Total/NA	Water	524.2	
LCS 380-30382/11	Lab Control Sample	Total/NA	Water	524.2	
LCSD 380-30382/12	Lab Control Sample Dup	Total/NA	Water	524.2	
MRL 380-30382/10	Lab Control Sample	Total/NA	Water	524.2	
MRL 380-30382/14	Lab Control Sample	Total/NA	Water	524.2	

Analysis Batch: 30675

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 380-30675/15	Method Blank	Total/NA	Water	524.2	
LCS 380-30675/11	Lab Control Sample	Total/NA	Water	524.2	
LCSD 380-30675/12	Lab Control Sample Dup	Total/NA	Water	524.2	
MRL 380-30675/10	Lab Control Sample	Total/NA	Water	524.2	
MRL 380-30675/14	Lab Control Sample	Total/NA	Water	524.2	

Analysis Batch: 30695

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	524.2	
MB 380-30695/5	Method Blank	Total/NA	Water	524.2	
LCS 380-30695/3	Lab Control Sample	Total/NA	Water	524.2	
LCSD 380-30695/4	Lab Control Sample Dup	Total/NA	Water	524.2	

Analysis Batch: 30956

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	524.2	
MB 380-30956/8	Method Blank	Total/NA	Water	524.2	
LCS 380-30956/4	Lab Control Sample	Total/NA	Water	524.2	
LCSD 380-30956/5	Lab Control Sample Dup	Total/NA	Water	524.2	
MRL 380-30956/3	Lab Control Sample	Total/NA	Water	524.2	
MRL 380-30956/7	Lab Control Sample	Total/NA	Water	524.2	

GC/MS Semi VOA

Prep Batch: 30258

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	525.2	
MB 380-30258/1-A	Method Blank	Total/NA	Water	525.2	
LCS 380-30258/3-A	Lab Control Sample	Total/NA	Water	525.2	
LCSD 380-30258/4-A	Lab Control Sample Dup	Total/NA	Water	525.2	
MRL 380-30258/2-A	Lab Control Sample	Total/NA	Water	525.2	
380-34654-R-1-A MS	Matrix Spike	Total/NA	Water	525.2	
380-34720-V-2-A DU	Duplicate	Total/NA	Water	525.2	

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

GC/MS Semi VOA

Analysis Batch: 30320

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	525.2	30258
MB 380-30258/1-A	Method Blank	Total/NA	Water	525.2	30258
LCS 380-30258/3-A	Lab Control Sample	Total/NA	Water	525.2	30258
LCSD 380-30258/4-A	Lab Control Sample Dup	Total/NA	Water	525.2	30258
MRL 380-30258/2-A	Lab Control Sample	Total/NA	Water	525.2	30258
380-34654-R-1-A MS	Matrix Spike	Total/NA	Water	525.2	30258
380-34720-V-2-A DU	Duplicate	Total/NA	Water	525.2	30258

GC Semi VOA

Prep Batch: 30329

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	505	10
MB 380-30329/7-A	Method Blank	Total/NA	Water	505	11
MRL 380-30329/2-A	Lab Control Sample	Total/NA	Water	505	12
MRL 380-30329/3-A	Lab Control Sample	Total/NA	Water	505	13
MRL 380-30329/4-A	Lab Control Sample	Total/NA	Water	505	14
MRL 380-30329/5-A	Lab Control Sample	Total/NA	Water	505	15
MRL 380-30329/6-A	Lab Control Sample	Total/NA	Water	505	16
380-34454-P-1-A MS	Matrix Spike	Total/NA	Water	505	17
380-34454-Q-1-A MS	Matrix Spike	Total/NA	Water	505	
380-34654-E-1-A MS	Matrix Spike	Total/NA	Water	505	
380-34654-F-1-A MS	Matrix Spike	Total/NA	Water	505	

Prep Batch: 30432

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	504.1	
380-34727-2	TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TF	Total/NA	Water	504.1	
MBL 380-30432/4-A	Method Blank	Total/NA	Water	504.1	
LCS 380-30432/3-A	Lab Control Sample	Total/NA	Water	504.1	
MRL 380-30432/1-A	Lab Control Sample	Total/NA	Water	504.1	
MRL 380-30432/2-A	Lab Control Sample	Total/NA	Water	504.1	
380-34654-B-1-A MS	Matrix Spike	Total/NA	Water	504.1	
380-34654-J-2-A DU	Duplicate	Total/NA	Water	504.1	

Analysis Batch: 30452

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	505	30329
MB 380-30329/7-A	Method Blank	Total/NA	Water	505	30329
MRL 380-30329/2-A	Lab Control Sample	Total/NA	Water	505	30329
MRL 380-30329/3-A	Lab Control Sample	Total/NA	Water	505	30329
MRL 380-30329/4-A	Lab Control Sample	Total/NA	Water	505	30329
MRL 380-30329/5-A	Lab Control Sample	Total/NA	Water	505	30329
MRL 380-30329/6-A	Lab Control Sample	Total/NA	Water	505	30329
380-34454-P-1-A MS	Matrix Spike	Total/NA	Water	505	30329
380-34454-Q-1-A MS	Matrix Spike	Total/NA	Water	505	30329
380-34654-E-1-A MS	Matrix Spike	Total/NA	Water	505	30329
380-34654-F-1-A MS	Matrix Spike	Total/NA	Water	505	30329

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

GC Semi VOA

Analysis Batch: 30502

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	504.1	30432
380-34727-2	TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TF	Total/NA	Water	504.1	30432
MBL 380-30432/4-A	Method Blank	Total/NA	Water	504.1	30432
LCS 380-30432/3-A	Lab Control Sample	Total/NA	Water	504.1	30432
MRL 380-30432/1-A	Lab Control Sample	Total/NA	Water	504.1	30432
MRL 380-30432/2-A	Lab Control Sample	Total/NA	Water	504.1	30432
380-34654-B-1-A MS	Matrix Spike	Total/NA	Water	504.1	30432
380-34654-J-2-A DU	Duplicate	Total/NA	Water	504.1	30432

HPLC/IC

Analysis Batch: 30150

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	300.0	10
MB 380-30150/4	Method Blank	Total/NA	Water	300.0	11
LCS 380-30150/7	Lab Control Sample	Total/NA	Water	300.0	12
LCSD 380-30150/8	Lab Control Sample Dup	Total/NA	Water	300.0	13
MRL 380-30150/5	Lab Control Sample	Total/NA	Water	300.0	14
MRL 380-30150/6	Lab Control Sample	Total/NA	Water	300.0	15
380-34715-T-1 MS	Matrix Spike	Total/NA	Water	300.0	16
380-34715-T-1 MSD	Matrix Spike Duplicate	Total/NA	Water	300.0	17

Analysis Batch: 30151

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	300.0	15
MB 380-30151/4	Method Blank	Total/NA	Water	300.0	16
LCS 380-30151/7	Lab Control Sample	Total/NA	Water	300.0	17
LCSD 380-30151/8	Lab Control Sample Dup	Total/NA	Water	300.0	
MRL 380-30151/5	Lab Control Sample	Total/NA	Water	300.0	
MRL 380-30151/6	Lab Control Sample	Total/NA	Water	300.0	
380-34715-T-1 MS	Matrix Spike	Total/NA	Water	300.0	
380-34715-T-1 MSD	Matrix Spike Duplicate	Total/NA	Water	300.0	

Analysis Batch: 30464

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	300.0	
MB 380-30464/4	Method Blank	Total/NA	Water	300.0	
LCS 380-30464/5	Lab Control Sample	Total/NA	Water	300.0	
LCSD 380-30464/6	Lab Control Sample Dup	Total/NA	Water	300.0	
MRL 380-30464/3	Lab Control Sample	Total/NA	Water	300.0	
380-34768-A-4 MS	Matrix Spike	Total/NA	Water	300.0	
380-34768-A-4 MSD	Matrix Spike Duplicate	Total/NA	Water	300.0	

Metals

Prep Batch: 45189

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	245.1	
MB 810-45189/1-A	Method Blank	Total/NA	Water	245.1	
LCS 810-45189/3-A	Lab Control Sample	Total/NA	Water	245.1	
810-50806-C-1-B MS	Matrix Spike	Total/NA	Water	245.1	
810-50806-C-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	245.1	

Eurofins Drinking Water Testing Pomona

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Metals

Analysis Batch: 45205

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	245.1	45189
MB 810-45189/1-A	Method Blank	Total/NA	Water	245.1	45189
LCS 810-45189/3-A	Lab Control Sample	Total/NA	Water	245.1	45189
810-50806-C-1-B MS	Matrix Spike	Total/NA	Water	245.1	45189
810-50806-C-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	245.1	45189

General Chemistry

Analysis Batch: 30237

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	SM 4500 F C	9
MB 380-30237/6	Method Blank	Total/NA	Water	SM 4500 F C	10
LCS 380-30237/8	Lab Control Sample	Total/NA	Water	SM 4500 F C	11
LCSD 380-30237/9	Lab Control Sample Dup	Total/NA	Water	SM 4500 F C	12
MRL 380-30237/7	Lab Control Sample	Total/NA	Water	SM 4500 F C	13
380-34727-1 MS	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	SM 4500 F C	14
380-34727-1 MSD	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	SM 4500 F C	15

Analysis Batch: 30308

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	SM 2320B	14
MB 380-30308/39	Method Blank	Total/NA	Water	SM 2320B	15
MB 380-30308/7	Method Blank	Total/NA	Water	SM 2320B	16
LCS 380-30308/37	Lab Control Sample	Total/NA	Water	SM 2320B	17
LCSD 380-30308/22	Lab Control Sample Dup	Total/NA	Water	SM 2320B	
LCSD 380-30308/54	Lab Control Sample Dup	Total/NA	Water	SM 2320B	
LLCS 380-30308/38	Lab Control Sample	Total/NA	Water	SM 2320B	
MRL 380-30308/40	Lab Control Sample	Total/NA	Water	SM 2320B	
380-34715-E-1 MS	Matrix Spike	Total/NA	Water	SM 2320B	
380-34715-E-1 MSD	Matrix Spike Duplicate	Total/NA	Water	SM 2320B	
380-34715-E-1 DU	Duplicate	Total/NA	Water	SM 2320B	

Analysis Batch: 30309

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	SM 2510B	
MB 380-30309/35	Method Blank	Total/NA	Water	SM 2510B	
LCS 380-30309/38	Lab Control Sample	Total/NA	Water	SM 2510B	
LCS 380-30309/58	Lab Control Sample	Total/NA	Water	SM 2510B	
LCSD 380-30309/22	Lab Control Sample Dup	Total/NA	Water	SM 2510B	
LCSD 380-30309/50	Lab Control Sample Dup	Total/NA	Water	SM 2510B	
MRL 380-30309/36	Lab Control Sample	Total/NA	Water	SM 2510B	
MRL 380-30309/8	Lab Control Sample	Total/NA	Water	SM 2510B	
380-34715-E-1 DU	Duplicate	Total/NA	Water	SM 2510B	

Analysis Batch: 30310

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	SM 4500 H+ B	
MB 380-30310/35	Method Blank	Total/NA	Water	SM 4500 H+ B	
LCS 380-30310/36	Lab Control Sample	Total/NA	Water	SM 4500 H+ B	
LCSD 380-30310/23	Lab Control Sample Dup	Total/NA	Water	SM 4500 H+ B	
LCSD 380-30310/49	Lab Control Sample Dup	Total/NA	Water	SM 4500 H+ B	

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

General Chemistry (Continued)

Analysis Batch: 30310 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34715-E-1 DU	Duplicate	Total/NA	Water	SM 4500 H+ B	

Analysis Batch: 30546

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	SM 4500 S2 D	
MB 380-30546/1	Method Blank	Total/NA	Water	SM 4500 S2 D	
LCS 380-30546/4	Lab Control Sample	Total/NA	Water	SM 4500 S2 D	
LCSD 380-30546/16	Lab Control Sample Dup	Total/NA	Water	SM 4500 S2 D	
MRL 380-30546/15	Lab Control Sample	Total/NA	Water	SM 4500 S2 D	
MRL 380-30546/2	Lab Control Sample	Total/NA	Water	SM 4500 S2 D	
380-34727-1 MS	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	SM 4500 S2 D	
380-34727-1 MSD	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	SM 4500 S2 D	

Subcontract

Analysis Batch: O-40114

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	625 Acid/Base/PAH + TICs	O-40114_P
103732-B1	Method Blank	Total/NA	BlankMatrix	625 Acid/Base/PAH + TICs	O-40114_P
103732-BS1	Lab Control Sample	Total/NA	BlankMatrix	625 Acid/Base/PAH + TICs	O-40114_P
103732-BS2	Lab Control Sample Dup	Total/NA	BlankMatrix	625 Acid/Base/PAH + TICs	O-40114_P

Analysis Batch: 23DSA029W

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	8015 LL DRO/MRO/JP5/J P8	
23DSA029WB	Method Blank	Total/NA	WATER	8015 LL DRO/MRO/JP5/J P8	
23DSA029WL	Lab Control Sample	Total/NA	WATER	8015 LL DRO/MRO/JP5/J P8	
23J5A029WL	Lab Control Sample	Total/NA	WATER	8015 LL DRO/MRO/JP5/J P8	
23J8A029WL	Lab Control Sample	Total/NA	WATER	8015 LL DRO/MRO/JP5/J P8	

Analysis Batch: 23MEA003W

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	8015 Ethanol	
23MEA003WB	Method Blank	Total/NA	WATER	8015 Ethanol	
23MEA003WL	Lab Control Sample	Total/NA	WATER	8015 Ethanol	
23A194-01M	Matrix Spike	Total/NA	WATER	8015 Ethanol	
23A194-01S	Matrix Spike Duplicate	Total/NA	WATER	8015 Ethanol	

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Subcontract

Analysis Batch: 23VG39A08

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	8015 Gas (Purgeable) LL (EAL)	5
380-34727-2	TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TF	Total/NA	Water	8015 Gas (Purgeable) LL (EAL)	6
23VG39A08B	Method Blank	Total/NA	WATER	8015 Gas (Purgeable) LL (EAL)	7
23VG39A08L	Lab Control Sample	Total/NA	WATER	8015 Gas (Purgeable) LL (EAL)	8

Prep Batch: O-40114_P

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP40C	Total/NA	Drinking Water	EPA_625	11
103732-B1	Method Blank	Total/NA	BlankMatrix	EPA_625	12
103732-BS1	Lab Control Sample	Total/NA	BlankMatrix	EPA_625	13
103732-BS2	Lab Control Sample Dup	Total/NA	BlankMatrix	EPA_625	14

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

**Client Sample ID: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-1

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	30695	AAE8	EA MON	01/26/23 07:21
Total/NA	Analysis	524.2		1	30956	AAE8	EA MON	01/30/23 17:31
Total/NA	Analysis	524.2		1	30366	P3EE	EA MON	01/20/23 18:10
Total/NA	Prep	525.2			30258	G9MN	EA MON	01/20/23 05:58
Total/NA	Analysis	525.2		1	30320	UPAC	EA MON	01/20/23 18:06
Total/NA	Prep	504.1			30432	K9GY	EA MON	01/23/23 14:25 - 01/23/23 15:15 ¹
Total/NA	Analysis	504.1		1	30502	K9GY	EA MON	01/23/23 22:49
Total/NA	Prep	505			30329	DR5R	EA MON	01/20/23 14:15 - 01/20/23 15:50 ¹
Total/NA	Analysis	505		1	30452	ULRL	EA MON	01/20/23 20:41
Total/NA	Analysis	300.0		1	30464	UNJR	EA MON	01/23/23 22:46
Total/NA	Analysis	300.0		2	30150	VB9B	EA MON	01/18/23 22:43
Total/NA	Analysis	300.0		2	30151	VB9B	EA MON	01/18/23 22:43
Total/NA	Prep	245.1			45189	AC	EA SB	01/20/23 16:44
Total/NA	Analysis	245.1		1	45205	AC	EA SB	01/20/23 20:01
Total/NA	Analysis	SM 2320B		1	30308	D5MQ	EA MON	01/19/23 19:07
Total/NA	Analysis	SM 2510B		1	30309	D5MQ	EA MON	01/19/23 19:07
Total/NA	Analysis	SM 4500 F C		1	30237	D5MQ	EA MON	01/19/23 14:57
Total/NA	Analysis	SM 4500 H+ B		1	30310	D5MQ	EA MON	01/19/23 19:07
Total/NA	Analysis	SM 4500 S2 D		1	30546	MH2L	EA MON	01/24/23 12:17
Total/NA	Prep	EPA_625		1	O-40114_P			01/20/23 00:00
Total/NA	Analysis	625 Acid/Base/PAH + TICs		1	O-40114	YC		02/14/23 01:30
Total/NA	Analysis	8015 Ethanol		1	23MEA003W	ASitu		01/20/23 13:35
Total/NA	Analysis	8015 Gas (Purgeable) LL (EAL)		1	23VG39A08	SCerva		01/20/23 01:52
Total/NA	Analysis	8015 LL DRO/MRO/JP5/JP8		1	23DSA029W	SDees		01/24/23 22:04

**Client Sample ID: TB: AIEA WELLS PUMPS 1&2 (260)
(331-203-TP400)**

Date Collected: 01/17/23 09:20
Date Received: 01/18/23 10:00

Lab Sample ID: 380-34727-2

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	30382	AAE8	EA MON	01/21/23 06:44
Total/NA	Analysis	524.2		1	30366	P3EE	EA MON	01/20/23 18:34
Total/NA	Prep	504.1			30432	K9GY	EA MON	01/23/23 14:25 - 01/23/23 15:15 ¹
Total/NA	Analysis	504.1		1	30502	K9GY	EA MON	01/23/23 23:24
Total/NA	Analysis	8015 Gas (Purgeable) LL (EAL)		1	23VG39A08	SCerva		01/20/23 02:29

¹ Completion dates and times are reported or not reported per method requirements or individual lab discretion.

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Laboratory References:

= Physis Environmental Laboratories, 1904 Wright Circle, Anaheim, CA 92806

EA MON = Eurofins Drinking Water Testing Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EA SB = Eurofins Eaton South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

Accreditation/Certification Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Laboratory: Eurofins Drinking Water Testing Pomona

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	02-28-23

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
300.0		Drinking Water	Nitrate Nitrite as N
505	505	Drinking Water	Polychlorinated biphenyls, Total
524.2		Drinking Water	1,3-Dichloropropene, Total
524.2		Drinking Water	2-Butanone (MEK)
524.2		Drinking Water	4-Methyl-2-pentanone (MIBK)
524.2		Drinking Water	Acetone
524.2		Drinking Water	Bromoethane
524.2		Drinking Water	m,p-Xylenes
524.2		Drinking Water	o-Xylene
524.2		Water	1,3-Dichloropropene, Total
524.2		Water	2-Butanone (MEK)
524.2		Water	4-Methyl-2-pentanone (MIBK)
524.2		Water	Acetone
524.2		Water	Bromoethane
524.2		Water	m,p-Xylenes
524.2		Water	o-Xylene
525.2	525.2	Drinking Water	1-Methylnaphthalene
525.2	525.2	Drinking Water	2,4'-DDD
525.2	525.2	Drinking Water	2,4'-DDE
525.2	525.2	Drinking Water	2,4'-DDT
525.2	525.2	Drinking Water	2,4-Dinitrotoluene
525.2	525.2	Drinking Water	2,6-Dinitrotoluene
525.2	525.2	Drinking Water	2-Methylnaphthalene
525.2	525.2	Drinking Water	4,4'-DDD
525.2	525.2	Drinking Water	4,4'-DDE
525.2	525.2	Drinking Water	4,4'-DDT
525.2	525.2	Drinking Water	Acenaphthene
525.2	525.2	Drinking Water	Acenaphthylene
525.2	525.2	Drinking Water	Acetochlor
525.2	525.2	Drinking Water	alpha-BHC
525.2	525.2	Drinking Water	alpha-Chlordane
525.2	525.2	Drinking Water	Anthracene
525.2	525.2	Drinking Water	Benz(a)anthracene
525.2	525.2	Drinking Water	Benzo[b]fluoranthene
525.2	525.2	Drinking Water	Benzo[g,h,i]perylene
525.2	525.2	Drinking Water	Benzo[k]fluoranthene
525.2	525.2	Drinking Water	beta-BHC
525.2	525.2	Drinking Water	Bromacil
525.2	525.2	Drinking Water	Butylbenzylphthalate
525.2	525.2	Drinking Water	Chlorobenzilate
525.2	525.2	Drinking Water	Chloroneb
525.2	525.2	Drinking Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Drinking Water	Chlorpyrifos
525.2	525.2	Drinking Water	Chrysene
525.2	525.2	Drinking Water	delta-BHC

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Laboratory: Eurofins Drinking Water Testing Pomona (Continued)

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.			
Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Drinking Water	Dibenz(a,h)anthracene
525.2	525.2	Drinking Water	Diclorvos (DDVP)
525.2	525.2	Drinking Water	Diethylphthalate
525.2	525.2	Drinking Water	Dimethylphthalate
525.2	525.2	Drinking Water	Di-n-butyl phthalate
525.2	525.2	Drinking Water	Di-n-octyl phthalate
525.2	525.2	Drinking Water	Endosulfan I (Alpha)
525.2	525.2	Drinking Water	Endosulfan II (Beta)
525.2	525.2	Drinking Water	Endosulfan sulfate
525.2	525.2	Drinking Water	Endrin aldehyde
525.2	525.2	Drinking Water	EPTC
525.2	525.2	Drinking Water	Fluoranthene
525.2	525.2	Drinking Water	Fluorene
525.2	525.2	Drinking Water	gamma-Chlordane
525.2	525.2	Drinking Water	Indeno[1,2,3-cd]pyrene
525.2	525.2	Drinking Water	Isophorone
525.2	525.2	Drinking Water	Malathion
525.2	525.2	Drinking Water	Molinate
525.2	525.2	Drinking Water	Naphthalene
525.2	525.2	Drinking Water	Parathion
525.2	525.2	Drinking Water	Pendimethalin (Penoxaline)
525.2	525.2	Drinking Water	Phenanthrene
525.2	525.2	Drinking Water	Pyrene
525.2	525.2	Drinking Water	Terbacil
525.2	525.2	Drinking Water	Terbutylazine
525.2	525.2	Drinking Water	Thiobencarb
525.2	525.2	Drinking Water	Total Permethrin (mixed isomers)
525.2	525.2	Drinking Water	trans-Nonachlor
525.2	525.2	Drinking Water	Trifluralin
SM 4500 S2 D		Drinking Water	Sulfide

Laboratory: Eurofins Eaton South Bend

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	ISO/IEC 17025	5794.01	07-31-24
Alabama	State	40700	06-30-23
Alaska	State	IN00035	06-30-23
Arizona	State	AZ0432	07-26-23
Arkansas (DW)	State	EPA IN00035	06-30-23
California	State	2920	06-30-23
Colorado	State	IN00035	02-28-23
Connecticut	State	PH-0132	03-31-22 *
Delaware (DW)	State	IN00035	06-30-23
Florida	NELAP	E87775	06-30-23
Georgia (DW)	State	929	06-30-23
Hawaii	State	IN035	06-30-23

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Eurofins Drinking Water Testing Pomona

Accreditation/Certification Summary

Client: City & County of Honolulu

Project/Site: RED-HILL

Job ID: 380-34727-1

Laboratory: Eurofins Eaton South Bend (Continued)

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Idaho (DW)	State	IN00035	12-31-23
IL Dept. of Public Health (Micro)	State	17767	12-31-22 *
Illinois	NELAP	200001	09-30-23
Indiana	State	C-71-01	12-31-25
Indiana (Micro)	State	M-76-07	12-31-25
Iowa	State	IA Lab #098	11-01-23
Kansas	NELAP	E-10233	10-31-23
Kentucky (DW)	State	KY90056	12-31-22 *
Louisiana (DW)	State	LA014	12-31-23
Maine	State	IN00035	05-01-23
Maryland	State	209	03-31-23
Massachusetts	State	M-IN035	06-30-23
MI - RadChem Recognition	State	9926	06-30-23
Michigan	State	9926	03-31-23
Minnesota	NELAP	1989807	12-31-23
Mississippi	State	IN00035	06-30-22 *
Missouri	State	880	09-30-24
Montana (DW)	State	CERT0026	01-02-24
Nebraska	State	NE-OS-05-04	06-30-23
Nevada	State	IN000352021-2	07-31-23
New Hampshire	NELAP	2124	11-05-23
New Jersey	NELAP	IN598	06-30-23
New Mexico	State	IN00035	06-30-23
New York	NELAP	11398	04-01-23
North Carolina (DW)	State	18700	07-31-23
North Dakota	State	R-035	06-30-23
Ohio	State	87775	06-30-23
Oklahoma	NELAP	D9508	08-31-23
Oregon	NELAP	4156	09-16-23
Pennsylvania	NELAP	68-00466	04-30-23
Puerto Rico	State	IN00035	04-01-23
Rhode Island	State	LAO00343	12-30-23
South Carolina	State	95005001	06-30-23
South Dakota (DW)	State	IN00035	12-31-22 *
Tennessee	State	TN02973	06-30-23
Texas	NELAP	T104704187-22-16	12-31-23
Texas	TCEQ Water Supply	TX207	06-30-23
USEPA Reg X SDWA	US Federal Programs	IN00035	08-20-22 *
USEPA UCMR 5	US Federal Programs	IN00035	12-31-25
Utah	NELAP	IN00035	07-31-23
Vermont	State	VT-8775	11-15-23
Virginia	NELAP	460275	03-14-23
Washington	State	C837	01-01-23 *
West Virginia (DW)	State	9927 C	12-31-23
Wisconsin	State	999766900	08-31-23
Wisconsin (Micro)	State	10121	12-31-22 *
Wyoming	State	8TMS-L	06-30-23

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Eurofins Drinking Water Testing Pomona

Method Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-34727-1

Method	Method Description	Protocol	Laboratory
524.2	Volatile Organic Compounds (GC/MS SIM)	EPA-DW	EA MON
524.2	Volatile Organic Compounds (GC/MS)	EPA-DW	EA MON
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA MON
504.1	EDB, DBCP and 1,2,3-TCP (GC)	EPA-DW2	EA MON
505	Organochlorine Pesticides/PCBs (GC)	EPA	EA MON
300.0	Anions, Ion Chromatography	EPA	EA MON
245.1	Mercury (CVAA)	EPA	EA SB
SM 2320B	Alkalinity	SM	EA MON
SM 2510B	Conductivity, Specific Conductance	SM	EA MON
SM 4500 F C	Fluoride	SM	EA MON
SM 4500 H+ B	pH	SM	EA MON
SM 4500 S2 D	Sulfide, Total	SM	EA MON
625	EPA 625 Base/Neutral and Acid Organics i	EPA	
8015	8015 - TPH DRO/ORO	EPA	
8015B	SW846 8015B Gasoline Range Organics	SW846	
245.1	Preparation, Mercury	EPA	EA SB
504.1	Microextraction	EPA-DW	EA MON
505	Extraction, Organochlorine Pesticides/PCBs	EPA	EA MON
525.2	Extraction of Semivolatile Compounds	EPA	EA MON

Protocol References:

EPA = US Environmental Protection Agency

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

EPA-DW2 = "Methods For The Determination of Organic Compounds in Drinking Water - Supplement III ", EPA/600/R-95-131, August 1995

SM = "Standard Methods For The Examination Of Water And Wastewater"

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

= Physis Environmental Laboratories, 1904 Wright Circle, Anaheim, CA 92806

EA MON = Eurofins Drinking Water Testing Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EA SB = Eurofins Eaton South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-34727-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
380-34727-1	AIEA WELLS PUMPS 1&2 (260) (331-203-TP400)	Drinking Water	01/17/23 09:20	01/18/23 10:00
380-34727-2	TB: AIEA WELLS PUMPS 1&2 (260) (331-203-TP400)	Water	01/17/23 09:20	01/18/23 10:00



3051 Fujita Street
Torrance, CA 90505
Tel: (310)-618-8889

Date: 02-07-2023
EMAX Batch No.: 23A194

Attn: Jackie Contreras

Eurofins Eaton Analytical
750 Royal Oaks Dr., Suite 100
Monrovia, CA 91016-3629

Subject: Laboratory Report
Project: 380-34727

.....
Enclosed is the Laboratory report for samples received on 01/19/23.
The data reported relate only to samples listed below :

Sample ID	Control #	Col Date	Matrix	Analysis
380-34727-1	A194-01	01/17/23	WATER	TPH GASOLINE TPH ETHANOL
380-34727-2	A194-02	01/17/23	WATER	TPH GASOLINE
380-34727-1MS	A194-01M	01/17/23	WATER	ETHANOL
380-34727-1MSD	A194-01S	01/17/23	WATER	ETHANOL

The results are summarized on the following pages.

Please feel free to call if you have any questions concerning
these results.

Sincerely yours,

Caspar J. Pang
Laboratory Director

This report is confidential and intended solely for the use of the individual or entity to whom it is addressed. This report shall not be reproduced except in full or without the written approval of EMAX.

EMAX certifies that results included in this report meets all TNI & DOD requirements unless noted in the Case Narrative.

NELAP Accredited Certificate Number CA002912022-22
ANAB Accredited DoD ELAP and ISO/IEC 17025 Certificate Number L2278 Testing
California ELAP Accredited Certificate Number 2672

Monrovia, CA (Suite 10)
750 Royal Oaks Drive Suite 100

Chain of Custody Record 23A1944



eurofins

Environmental Testing

Note: Since laboratory accreditations are subject to change, Eurofins Eaton Analytical, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analytes/test matrix being analyzed, the sample must be shipped back to the Eurofins Eaton Analytical, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Eaton Analytical, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Eaton Analytical, LLC.

Possible Hazard Identification Unconfirmed

Deliverable Re

卷之三

Empty Kit Relinquished by:

Relinquished by:

10 of 10

Relinquished by /bcg

Bismillah ar-Rahman ar-Rahim

卷之三

Custody Seals Intact:

Δ Yes Δ No

REPORT ID: 23A194

08/2021
J44



REFERENCE: EMAX-SM02 Rev. 12

SAMPLE RECEIPT FORM 1

Type of Delivery	Airbill / Tracking Number	ECN 23A194 Recipient Maria Rivera
<input type="checkbox"/> Fedex <input type="checkbox"/> UPS <input type="checkbox"/> GSO <input type="checkbox"/> Others		Date 11/9/23 Time 15:10
<input type="checkbox"/> EMAX Courier <input checked="" type="checkbox"/> Client Delivery		

COC INSPECTION

Client Name Client PM/FC Sampler Name Sampling Date/Time Sample ID
 Address Tel # / Fax # Courier Signature Analysis Required Matrix
Safety Issues (if any) High concentrations expected From Superfund Site Rad screening required Preservative (if any) TAT

Note: _____

PACKAGING INSPECTION

Container Cooler Box Other
 Condition Custody Seal Intact Damaged
 Packaging Bubble Pack Styrofoam Popcorn Sufficient
 factor: -0.2
 Temperatures Cooler 1 25/23 °C Cooler 2 5/6/4 °C Cooler 3 _____ °C Cooler 4 _____ °C Cooler 5 _____ °C
 (Cool, ≤ 6 °C but not frozen)
 Cooler 6 _____ °C Cooler 7 _____ °C Cooler 8 _____ °C Cooler 9 _____ °C Cooler 10 _____ °C
 Thermometer: A - S/N 221052760 B - S/N 210760237 C - S/N D - S/N

Comments: Temperature is out of range. PM was informed IMMEDIATELY.

INDIC. _____

DISCREPANCIES

pH holding time requirement for water samples is 15 mins. Water samples for pH analysis are received beyond 15 minutes from sampling time.

PS 1/2/23

NOTES/OBSERVATIONS:

SAMPLE MATRIX IS DRINKING WATER? YES NO

LEGEND:

- Code Description- Sample Management**

 - D1** Analysis is not indicated in _____
 - D2** Analysis mismatch COC vs label
 - D3** Sample ID mismatch COC vs label
 - D4** Sample ID is not indicated in _____
 - D5** Container -[improper] [leaking] [broken]
 - D6** Date/Time is not indicated in _____
 - D7** Date/Time mismatch COC vs label
 - D8** Sample listed in COC is not received
 - D9** Sample received is not listed in COC
 - D10** No initial/date on corrections in COC/lab
 - D11** Container count mismatch COC vs received
 - D12** Container size mismatch COC vs received

Code Description-Sample Management

- D13 Out of Holding Time
 - D14 Bubble is >6mm
 - D15 No trip blank in cooler
 - D16 Preservation not indicated in _____
 - D17 Preservation mismatch COC vs label
 - D18 Insufficient chemical preservative
 - D19 Insufficient Sample
 - D20 No filtration info for dissolved analysis
 - D21 No sample for moisture determination
 - D22 _____
 - D23 _____
 - D24 _____

Continue to next page.

Code Description-Sample Management

- R1 Proceed as indicated in COC Label

R2 Refer to attached instruction

R3 Cancel the analysis

R4 Use vial with smallest bubble first

R5 Log-in with latest sampling date and time+1 min

R6 Adjust pH as necessary

R7 Filter and preserved as necessary

R8 _____

R9 _____

R10 _____

R11 _____

R12 _____

REVIEWS:

Sample Labeling Rivera Date 01/19/23

SRF JOCENNE SOLIS-RAMOS
Date 01/19/73

REPORT ID: 23A194

REPORTING CONVENTIONS

DATA QUALIFIERS:

Lab Qualifier	AFCEE Qualifier	Description
J	F	Indicates that the analyte is positively identified and the result is less than RL but greater than MDL.
N		Indicates presumptive evidence of a compound.
B	B	Indicates that the analyte is found in the associated method blank as well as in the sample at above QC level.
E	J	Indicates that the result is above the maximum calibration range or estimated value.
*	*	Out of QC limit.

Note: The above qualifiers are used to flag the results unless the project requires a different set of qualification criteria.

ACRONYMS AND ABBREVIATIONS:

CRDL	Contract Required Detection Limit
RL	Reporting Limit
MRL	Method Reporting Limit
PQL	Practical Quantitation Limit
MDL	Method Detection Limit
DO	Diluted out

DATES

The date and time information for leaching and preparation reflect the beginning date and time of the procedure unless the method, protocol, or project specifically requires otherwise.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

380-34727

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

SDG#: 23A194

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 380-34727

SDG : 23A194

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

A total of two(2) water samples were received on 01/19/23 to be analyzed for Total Petroleum Hydrocarbons by Purge and Trap in accordance with Method 5030B/8015B and project specific requirements.

Holding Time

Samples were analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. VG39A08B - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of LCS/LCD was analyzed. VG39A08L/VG39A08C were within LCS limits. Refer to LCS summary form for details.

Matrix QC Sample

No matrix QC sample was provided on this SDG. Gasoline was within MS QC limits in A175-01M/A175-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogate was added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

Samples were analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

LAB CHRONICLE
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

Client : EUROPINS EATON ANALYTICAL
Project : 380-34727

SDG NO. : 23A194
Instrument ID : GCT039

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	WATER		Extraction Date/Time	Sample Data FN	Calibration Data FN	Prep. Batch	Notes
				Analysis Date/Time	Calibration Date/Time					
MBLK1W	VG39A08B	1	NA	01/19/2313:12	01/19/2313:12	EA19005A	EA19003A	23VG39A08	Method Blank	
LCS1W	VG39A08L	1	NA	01/19/2313:48	01/19/2313:48	EA19006A	EA19003A	23VG39A08	Lab Control Sample (LCS)	
LCD1W	VG39A08C	1	NA	01/19/2314:24	01/19/2314:24	EA19007A	EA19003A	23VG39A08	LCS Duplicate	
380-34727-1	A194-01	1	NA	01/20/2301:52	01/20/2301:52	EA19026A	EA19023A	23VG39A08	Field Sample	
380-34727-2	A194-02	1	NA	01/20/2302:29	01/20/2302:29	EA19027A	EA19023A	23VG39A08	Field Sample	

FN - Filename
% Moist - Percent Moisture

SAMPLE RESULTS

METHOD 5030B/8015B
TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

Client : EUROFINS EATON ANALYTICAL Date Collected: 01/17/23 09:20
Project : 380-34727 Date Received: 01/19/23
Batch No. : 23A194 Date Extracted: 01/20/23 01:52
Sample ID : 380-34727-1 Date Analyzed: 01/20/23 01:52
Lab Samp ID: A194-01 Dilution Factor: 1
Lab File ID: EA19026A Matrix: WATER
Ext Btch ID: 23VG39A08 % Moisture: NA
Calib. Ref.: EA19023A Instrument ID: 39

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
GASOLINE	ND	0.020	0.010
<hr/>			
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY
Bromofluorobenzene	0.0310	0.0400	78
<hr/>			

Notes:

Parameter H-C Range

Gasoline C6-C10

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 5ml Final Volume : 5ml

Prepared by : SCerva Analyzed by : SCerva

METHOD 5030B/8015B

TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

Client : EUROFINS EATON ANALYTICAL Date Collected: 01/17/23 09:20
 Project : 380-34727 Date Received: 01/19/23
 Batch No. : 23A194 Date Extracted: 01/20/23 02:29
 Sample ID : 380-34727-2 Date Analyzed: 01/20/23 02:29
 Lab Samp ID: A194-02 Dilution Factor: 1
 Lab File ID: EA19027A Matrix: WATER
 Ext Btch ID: 23VG39A08 % Moisture: NA
 Calib. Ref.: EA19023A Instrument ID: 39

PARAMETERS	RESULTS	RL	MDL
	(mg/L)	(mg/L)	(mg/L)
GASOLINE	ND	0.020	0.010
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY QC LIMIT
Bromofluorobenzene	0.0315	0.0400	79 60-140

Notes:

Parameter H-C Range

Gasoline C6-C10

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 5ml Final Volume : 5ml

Prepared by : SCerva Analyzed by : SCerva

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

QC SUMMARIES

METHOD 5030B/8015B

TOTAL PETROLEUM HYDROCARBONS BY PURGE AND TRAP

Client : EUROFINS EATON ANALYTICAL Date Collected: 01/19/23 13:12
 Project : 380-34727 Date Received: 01/19/23
 Batch No. : 23A194 Date Extracted: 01/19/23 13:12
 Sample ID : MBLK1W Date Analyzed: 01/19/23 13:12
 Lab Samp ID: VG39A08B Dilution Factor: 1
 Lab File ID: EA19005A Matrix: WATER
 Ext Btch ID: 23VG39A08 % Moisture: NA
 Calib. Ref.: EA19003A Instrument ID: 39

PARAMETERS	RESULTS	RL	MDL
	(mg/L)	(mg/L)	(mg/L)
GASOLINE	ND	0.020	0.010
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY QC LIMIT
Bromofluorobenzene	0.0281	0.0400	70 60-140

Notes:

Parameter H-C Range

Gasoline C6-C10

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 5ml Final Volume : 5ml

Prepared by : SCerva Analyzed by : SCerva

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 380-34727
BATCH NO. : 23A194
METHOD : 5030B/8015B

MATRIX : WATER % MOISTURE:NA
DILUTION FACTOR: 1 1
SAMPLE ID : MBLK1W LCS1W LCD1W
LAB SAMPLE ID : VG39A08L VG39A08C
LAB FILE ID : EA19005A EA19006A EA19007A
DATE PREPARED : 01/19/23 13:12 01/19/23 13:48 01/19/23 14:24
DATE ANALYZED : 01/19/23 13:12 01/19/23 13:48 01/19/23 14:24
PREP BATCH : 23VG39A08 23VG39A08
CALIBRATION REF: EA19003A EA19003A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Gasoline	ND	0.500	0.437	87	0.500	0.445	89	2	60-130	30

SURROGATE PARAMETER	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	SpikeAmt (mg/L)	LCDResult (mg/L)	LCDRec (%)	QCLimit (%)
Bromofluorobenzene	0.0400	0.0406	102	0.0400	0.0416	104	70-130

MB: Method Blank sample LCS: Lab Control Sample LCD: Lab Control Sample Duplicate

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
 PROJECT : 380-35053
 BATCH NO. : 23A175
 METHOD : 5030B/8015B

MATRIX	: WATER	% MOISTURE:NA
DILUTION FACTOR:	1	1
SAMPLE ID	: 380-35053-1	380-35053-1MS
LAB SAMPLE ID	: A175-01	A175-01M
LAB FILE ID	: EA19020A	EA19021A
DATE PREPARED	: 01/19/23 22:17	01/19/23 22:53
DATE ANALYZED	: 01/19/23 22:17	01/19/23 22:53
PREP BATCH	: 23VG39A08	23VG39A08
CALIBRATION REF:	EA19012A	EA19012A

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Gasoline	ND	0.500	0.453	91	0.500	0.458	92	1	50-130	30

SURROGATE PARAMETER	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromofluorobenzene	0.0400	0.0412	103	0.0400	0.0415	104	60-140

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

380-34727

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

SDG#: 23A194

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

Client : EUROFINS EATON ANALYTICAL

Project: 380-34727

SDG : 23A194

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

One(1) water sample was received on 01/19/23 to be analyzed for Total Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

The sample was analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSA029WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) LCS was analyzed. Percent recovery for Diesel was within LCS QC limits in DSA029WL. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. Diesel was within MS QC limits in 23A175-01M/23A175-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

The sample was analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

Client : EUROFINS EATON ANALYTICAL

Project: 380-34727

SDG : 23A194

METHOD 3520C/8015B
PETROLEUM HYDROCARBONS BY EXTRACTION

One(1) water sample was received on 01/19/23 to be analyzed for Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

The sample was analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSA029WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) LCS was analyzed. Percent recovery for JP5 was within LCS QC limits in J5A029WL. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. JP5 was within MS QC limits in 23A175-01M/23A175-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

The sample was analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

Client : EUROFINS EATON ANALYTICAL

Project: 380-34727

SDG : 23A194

METHOD 3520C/8015B
PETROLEUM HYDROCARBONS BY EXTRACTION

One(1) water sample was received on 01/19/23 to be analyzed for Petroleum Hydrocarbons by Extraction in accordance with Method 3520C/8015B and project specific requirements.

Holding Time

The sample was analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. DSA029WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) LCS was analyzed. Percent recovery for JP8 was within LCS QC limits in J8A029WL. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. JP8 was within MS QC limits in 23A175-01M/23A175-01S. Refer to Matrix QC summary form for details.

Surrogate

Surrogates were added on QC and field samples. All surrogate recoveries were within QC limits. Refer to sample result summary forms for details.

Sample Analysis

The sample was analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

LAB CHRONICLE
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

Client : EUROFINS EATON ANALYTICAL
Project : 380-34727

SDG NO. : 23A194

Instrument ID : D5

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	Analysis Date/Time	Extraction Date/Time	Sample Data FN	Calibration Prep. Data FN	Notes
.....
MBLK1W	DSA029WB	1	NA	01/24/2318:24	01/23/2314:30	LA24010A	LA24004A	23DSA029W Method Blank
LCS1W	DSA029WL	1	NA	01/24/2318:42	01/23/2314:30	LA24011A	LA24004A	23DSA029W Lab Control Sample (LCS)
380-34727-1	A194-01	1	NA	01/24/2322:04	01/23/2314:30	LA24022A	LA24004A	23DSA029W Field Sample

FN - Filename
% Moist - Percent Moisture

LAB CHRONICLE
PETROLEUM HYDROCARBONS BY EXTRACTION

Client : EUROFINS EATON ANALYTICAL
Project : 380-34727

SDG NO. : 23A194

Instrument ID : D5

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	Analysis Date/Time	WATER Extraction Date/Time	Sample Data FN	Calibration Prep. Data FN	Notes
MBLK1W	DSA029WB	1	NA	01/24/2318:24	01/23/2314:30	LA24010A	23DSA029W	Method Blank
LCS1W	JSA029WL	1	NA	01/24/2319:00	01/23/2314:30	LA24012A	23DSA029W	Lab Control Sample (LCS)
380-34727-1	A194-01	1	NA	01/24/2322:04	01/23/2314:30	LA24022A	23DSA029W	Field Sample

FN - Filename
% Moist - Percent Moisture

LAB CHRONICLE
PETROLEUM HYDROCARBONS BY EXTRACTION

Client : EUROTINS EATON ANALYTICAL
Project : 380-34727

SDG NO. : 23A194
Instrument ID : D5

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	Analysis DateTime	WATER	Extraction DateTime	Sample Data FN	Calibration Prep. Batch	Notes
MBLK1W	DSAO29NB	1	NA	01/24/2318:24		01/23/2314:30	LA24006A	23DSA029W	Method Blank
LCS1W	J8A029NL	1	NA	01/24/2319:18		01/23/2314:30	LA24006A	23DSA029W	Lab Control Sample (LCS)
380-34727-1	A194-01	1	NA	01/24/2322:04		01/23/2314:30	LA24022A	23DSA029W	Field Sample

FN : Filename
% Moist : Percent Moisture

SAMPLE RESULTS

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

Client : EUROFINS EATON ANALYTICAL Date Collected: 01/17/23 09:20
Project : 380-34727 Date Received: 01/19/23
Batch No. : 23A194 Date Extracted: 01/23/23 14:30
Sample ID : 380-34727-1 Date Analyzed: 01/24/23 22:04
Lab Samp ID: 23A194-01 Dilution Factor: 1
Lab File ID: LA24022A Matrix: WATER
Ext Btch ID: 23DSA029W % Moisture: NA
Calib. Ref.: LA24004A Instrument ID: D5

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
Diesel	ND	0.027	0.014
Motor Oil	ND	0.055	0.027
<hr/>			
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY
Bromobenzene	0.525	0.545	96
Hexacosane	0.165	0.136	121
<hr/>			

Notes:

Parameter H-C Range

Diesel C10-C24

Motor Oil C24-C36

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 920ml Final Volume : 5ml

Prepared by : POreto Analyzed by : SDeeso

METHOD 3520C/8015B
PETROLEUM HYDROCARBONS BY EXTRACTION

Client : EUROFINS EATON ANALYTICAL Date Collected: 01/17/23 09:20
Project : 380-34727 Date Received: 01/19/23
Batch No. : 23A194 Date Extracted: 01/23/23 14:30
Sample ID : 380-34727-1 Date Analyzed: 01/24/23 22:04
Lab Samp ID: 23A194-01 Dilution Factor: 1
Lab File ID: LA24022A Matrix: WATER
Ext Btch ID: 23DSA029W % Moisture: NA
Calib. Ref.: LA24005A Instrument ID: D5

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP5	ND	0.055	0.027
<hr/>			
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY
Bromobenzene	0.525	0.545	96
Hexacosane	0.165	0.136	121
<hr/>			

Notes:

RL : Reporting Limit

Parameter H-C Range

JP5 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 920ml

Final Volume : 5ml

Prepared by : POrero

Analyzed by : SDeeso

METHOD 3520C/8015B
PETROLEUM HYDROCARBONS BY EXTRACTION

Client : EUROFINS EATON ANALYTICAL Date Collected: 01/17/23 09:20
Project : 380-34727 Date Received: 01/19/23
Batch No. : 23A194 Date Extracted: 01/23/23 14:30
Sample ID : 380-34727-1 Date Analyzed: 01/24/23 22:04
Lab Samp ID: 23A194-01 Dilution Factor: 1
Lab File ID: LA24022A Matrix: WATER
Ext Btch ID: 23DSA029W % Moisture: NA
Calib. Ref.: LA24006A Instrument ID: D5

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP8	ND	0.055	0.027
<hr/>			
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY
Bromobenzene	0.525	0.545	96
Hexacosane	0.165	0.136	121
<hr/>			

Notes:

RL : Reporting Limit

Parameter H-C Range

JP8 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 920ml

Final Volume : 5ml

Prepared by : P0reto

Analyzed by : SDeeso

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

QC SUMMARIES

METHOD 3520C/8015B
TOTAL PETROLEUM HYDROCARBONS BY EXTRACTION

Client : EUROFINS EATON ANALYTICAL Date Collected: 01/23/23 14:30
Project : 380-34727 Date Received: 01/23/23
Batch No. : 23A194 Date Extracted: 01/23/23 14:30
Sample ID : MBLK1W Date Analyzed: 01/24/23 18:24
Lab Samp ID: DSA029WB Dilution Factor: 1
Lab File ID: LA24010A Matrix: WATER
Ext Btch ID: 23DSA029W % Moisture: NA
Calib. Ref.: LA24004A Instrument ID: D5

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
Diesel	ND	0.025	0.012
Motor Oil	ND	0.050	0.025
<hr/>			
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY
Bromobenzene	0.415	0.500	83
Hexacosane	0.129	0.125	103
<hr/>			

Notes:

Parameter H-C Range

Diesel C10-C24

Motor Oil C24-C36

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 1000ml

Final Volume : 5ml

Prepared by : POreto

Analyzed by : SDeeso

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 380-34727
BATCH NO. : 23A194
METHOD : 3520C/8015B

MATRIX : WATER % MOISTURE:NA
DILUTION FACTOR: 1 1
SAMPLE ID : MBLK1W LCS1W
LAB SAMPLE ID : DSA029WB DSA029WL
LAB FILE ID : LA24010A LA24011A
DATE PREPARED : 01/23/23 14:30 01/23/23 14:30
DATE ANALYZED : 01/24/23 18:24 01/24/23 18:42
PREP BATCH : 23DSA029W 23DSA029W
CALIBRATION REF: LA24004A LA24004A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Diesel	ND	2.50	2.43	97	50-130

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Bromobenzene	0.500	0.510	102	60-130
Hexacosane	0.125	0.143	114	60-130

MB: Method Blank sample LCS: Lab Control Sample

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
 PROJECT : 380-35053
 BATCH NO. : 23A175
 METHOD : 3520C/8015B

MATRIX	: WATER	% MOISTURE:NA
DILUTION FACTOR:	1	1
SAMPLE ID	: 380-35053-1	380-35053-1MSD
LAB SAMPLE ID	: 23A175-01	23A175-01S
LAB FILE ID	: LA24014A	LA24016A
DATE PREPARED	: 01/23/23 14:30	01/23/23 14:30
DATE ANALYZED	: 01/24/23 19:37	01/24/23 20:14
PREP BATCH	: 23DSA029W	23DSA029W
CALIBRATION REF:	LA24004A	LA24004A

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
Diesel	ND	2.75	1.93	70	2.75	2.07	75	7	50-130	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromobenzene	0.550	0.415	75	0.550	0.446	81	60-130
Hexacosane	0.138	0.147	107	0.138	0.147	107	60-130

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

METHOD 3520C/8015B
PETROLEUM HYDROCARBONS BY EXTRACTION

Client : EUROFINS EATON ANALYTICAL Date Collected: 01/23/23 14:30
Project : 380-34727 Date Received: 01/23/23
Batch No. : 23A194 Date Extracted: 01/23/23 14:30
Sample ID : MBLK1W Date Analyzed: 01/24/23 18:24
Lab Samp ID: DSA029WB Dilution Factor: 1
Lab File ID: LA24010A Matrix: WATER
Ext Btch ID: 23DSA029W % Moisture: NA
Calib. Ref.: LA24005A Instrument ID: D5

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP5	ND	0.050	0.025
<hr/>			
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY
Bromobenzene	0.415	0.500	83
Hexacosane	0.129	0.125	103
<hr/>			

Notes:

RL : Reporting Limit

Parameter H-C Range

JP5 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 1000ml

Final Volume : 5ml

Prepared by : POrero

Analyzed by : SDeeso

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 380-34727
BATCH NO. : 23A194
METHOD : 3520C/8015B

MATRIX : WATER % MOISTURE:NA
DILUTION FACTOR: 1 1
SAMPLE ID : MBLK1W LCS1W
LAB SAMPLE ID : DSA029WB J5A029WL
LAB FILE ID : LA24010A LA24012A
DATE PREPARED : 01/23/23 14:30 01/23/23 14:30
DATE ANALYZED : 01/24/23 18:24 01/24/23 19:00
PREP BATCH : 23DSA029W 23DSA029W
CALIBRATION REF: LA24005A LA24005A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
JP5	ND	2.50	2.51	100	30-160

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Bromobenzene	0.500	0.515	103	60-130
Hexacosane	0.125	0.144	115	60-130

MB: Method Blank sample LCS: Lab Control Sample

1
2
3
4
5

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
 PROJECT : 380-35053
 BATCH NO. : 23A175
 METHOD : 3520C/8015B

6
7
8
9
10
11
12
13
14
15
16
17

MATRIX	: WATER	% MOISTURE:NA
DILUTION FACTOR:	1	1
SAMPLE ID	: 380-35053-1	380-35053-1MSD
LAB SAMPLE ID	: 23A175-01	23A175-01S
LAB FILE ID	: LA24014A	LA24018A
DATE PREPARED	: 01/23/23 14:30	01/23/23 14:30
DATE ANALYZED	: 01/24/23 19:37	01/24/23 20:50
PREP BATCH	: 23DSA029W	23DSA029W
CALIBRATION REF:	LA24005A	LA24005A

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
JP5	ND	2.55	1.64	64	2.65	1.97	74	18	30-160	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromobenzene	0.510	0.410	80	0.530	0.462	87	60-130
Hexacosane	0.127	0.130	102	0.132	0.142	107	60-130

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

METHOD 3520C/8015B
PETROLEUM HYDROCARBONS BY EXTRACTION

Client : EUROFINS EATON ANALYTICAL Date Collected: 01/23/23 14:30
Project : 380-34727 Date Received: 01/23/23
Batch No. : 23A194 Date Extracted: 01/23/23 14:30
Sample ID : MBLK1W Date Analyzed: 01/24/23 18:24
Lab Samp ID: DSA029WB Dilution Factor: 1
Lab File ID: LA24010A Matrix: WATER
Ext Btch ID: 23DSA029W % Moisture: NA
Calib. Ref.: LA24006A Instrument ID: D5

PARAMETERS	RESULTS (mg/L)	RL (mg/L)	MDL (mg/L)
JP8	ND	0.050	0.025
<hr/>			
SURROGATE PARAMETERS	RESULT	SPK_AMT	%RECOVERY
Bromobenzene	0.415	0.500	83
Hexacosane	0.129	0.125	103
<hr/>			

Notes:

RL : Reporting Limit

Parameter H-C Range

JP8 C8-C18

Reported ND at RL quantitated per pattern recognition.

Detection limits are reported relative to sample result significant figures.

Sample Amount : 1000ml

Final Volume : 5ml

Prepared by : POrero

Analyzed by : SDeeso

EMAX QUALITY CONTROL DATA
LAB CONTROL SAMPLE ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
PROJECT : 380-34727
BATCH NO. : 23A194
METHOD : 3520C/8015B

MATRIX : WATER % MOISTURE:NA
DILUTION FACTOR: 1 1
SAMPLE ID : MBLK1W LCS1W
LAB SAMPLE ID : DSA029WB J8A029WL
LAB FILE ID : LA24010A LA24013A
DATE PREPARED : 01/23/23 14:30 01/23/23 14:30
DATE ANALYZED : 01/24/23 18:24 01/24/23 19:18
PREP BATCH : 23DSA029W 23DSA029W
CALIBRATION REF: LA24006A LA24006A

ACCESSION:

PARAMETERS	MBResult (mg/L)	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
JP8	ND	2.50	2.10	84	30-160

SURROGATE PARAMETERS	SpikeAmt (mg/L)	LCSResult (mg/L)	LCSRec (%)	QCLimit (%)
Bromobenzene	0.500	0.523	105	60-130
Hexacosane	0.125	0.150	120	60-130

MB: Method Blank sample LCS: Lab Control Sample

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT : EUROFINS EATON ANALYTICAL
 PROJECT : 380-35053
 BATCH NO. : 23A175
 METHOD : 3520C/8015B

MATRIX	: WATER	% MOISTURE:NA
DILUTION FACTOR:	1	1
SAMPLE ID	: 380-35053-1	380-35053-1MS
LAB SAMPLE ID	: 23A175-01	23A175-01M
LAB FILE ID	: LA24014A	LA24019A
DATE PREPARED	: 01/23/23 14:30	01/23/23 14:30
DATE ANALYZED	: 01/24/23 19:37	01/24/23 21:09
PREP BATCH	: 23DSA029W	23DSA029W
CALIBRATION REF:	LA24006A	LA24006A

ACCESSION:

PARAMETERS	PSResult (mg/L)	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	RPD (%)	QCLimit (%)	MaxRPD (%)
JP8	ND	2.65	1.98	75	2.58	2.17	84	9	30-160	30

SURROGATE PARAMETERS	SpikeAmt (mg/L)	MSResult (mg/L)	MSRec (%)	SpikeAmt (mg/L)	MSDResult (mg/L)	MSDRec (%)	QCLimit (%)
Bromobenzene	0.530	0.474	89	0.515	0.508	99	60-130
Hexacosane	0.132	0.139	105	0.129	0.154	120	60-130

PS: Parent Sample MS: Matrix Spike MSD: Matrix Spike Duplicate

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

LABORATORY REPORT FOR

EUROFINS EATON ANALYTICAL

380-34727

METHOD SW8015C
ALCOHOLS BY GC

SDG#: 23A194

CASE NARRATIVE

Client : EUROFINS EATON ANALYTICAL

Project: 380-34727

SDG : 23A194

METHOD SW8015C
ALCOHOLS BY GC

One(1) water sample was received on 01/19/23 to be analyzed for Alcohols by GC in accordance with Method SW8015C and project specific requirements.

Holding Time

The sample was analyzed within the prescribed holding time.

Calibration

Multi-calibration points were generated to establish initial calibration (ICAL). ICAL was verified using a secondary source (ICV). Continuing calibration (CCV) verifications were carried out on a frequency specified by the project. All calibration requirements were within acceptance criteria. Refer to calibration summary forms of ICAL, ICV and CCV for details. MRL was analyzed as required by the project. Refer to MRL summary form for details.

Method Blank

Method blank was prepared and analyzed at the frequency required by the project. For this SDG, one(1) method blank was analyzed. MEA003WB - result was compliant to project requirement. Refer to sample result summary form for details.

Lab Control Sample

Lab control sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of LCS/LCD was analyzed. MEA003WL/MEA003WC were within LCS limits. Refer to LCS summary form for details.

Matrix QC Sample

Matrix spike sample was prepared and analyzed at a frequency required by the project. For this SDG, one(1) set of MS/MSD was analyzed. Ethanol was within MS QC limits in A194-01M/A194-01S. Refer to Matrix QC summary form for details.

Sample Analysis

The sample was analyzed according to prescribed analytical procedures. Results were evaluated in accordance to project requirements. For this SDG, all quality control requirements were met.

LAB CHRONICLE
ALCOHOLS BY GC

Client : EUROFINS EATON ANALYTICAL
Project : 380-34727

Client Sample ID	Laboratory Sample ID	Dilution Factor	% Moist	Analysis DateTime	WATER	Extraction DateTime	Sample Data FN	Calibration Prep. Batch	Notes
MBLK1W	MEA03WB	1	NA	01/20/2312:21	NA	TA20004A	TA20002A	MEA03W	Method Blank
LCS1W	MEA03WL	1	NA	01/20/2312:35	NA	TA20005A	TA20002A	MEA03W	Lab Control Sample (LCS)
LCD1W	MEA03WC	1	NA	01/20/2312:49	NA	TA20006A	TA20002A	MEA03N	LCS Duplicate
380-34727-1	A194-01	1	NA	01/20/2313:35	NA	TA20007A	TA20002A	MEA03N	Field Sample
380-34727-1MSD	A194-01M	1	NA	01/20/2313:55	NA	TA20008A	TA20002A	MEA03W	Matrix Spike Sample (MS)
380-34727-1MSD	A194-01S	1	NA	01/20/2314:09	NA	TA20009A	TA20002A	MEA03W	MS Duplicate (MSD)

FN - Filename
% Moist - Percent Moisture

SAMPLE RESULTS

METHOD SW8015C
ALCOHOLS BY GC

Client : EUROFINS EATON ANALYTICAL Date Collected: 01/17/23
Project : 380-34727 Date Received: 01/19/23
Batch No. : 23A194 Date Extracted: NA
Sample ID: 380-34727-1 Date Analyzed: 01/20/23 13:35
Lab Samp ID: A194-01 Dilution Factor: 1
Lab File ID: TA20007A Matrix : WATER
Ext Btch ID: MEA003W % Moisture : NA
Calib. Ref.: TA20002A Instrument ID : GCT050

PARAMETERS	RESULTS (ug/L)	RL (ug/L)	MDL (ug/L)
ETHANOL	ND	2000	500

RL : Reporting Limit

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

QC SUMMARIES

METHOD SW8015C
ALCOHOLS BY GC

Client : EUROFINS EATON ANALYTICAL Date Collected: NA
Project : 380-34727 Date Received: NA
Batch No. : 23A194 Date Extracted: NA
Sample ID: MBLK1W Date Analyzed: 01/20/23 12:21
Lab Samp ID: MEA003WB Dilution Factor: 1
Lab File ID: TA20004A Matrix : WATER
Ext Btch ID: MEA003W % Moisture : NA
Calib. Ref.: TA20002A Instrument ID : GCT050

PARAMETERS	RESULTS (ug/L)	RL (ug/L)	MDL (ug/L)
ETHANOL	ND	2000	500

RL : Reporting Limit

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

EMAX QUALITY CONTROL DATA
LCS/LCD ANALYSIS

CLIENT: EUROFINS EATON ANALYTICAL
 PROJECT: 380-34727
 BATCH NO.: 23A194
 METHOD: METHOD SW8015C

MATRIX: WATER % MOISTURE: NA
 DILUTION FACTOR: 1 1
 SAMPLE ID: MBLK1W
 LAB SAMP ID: MEA003WB MEA003WL MEA003WC
 LAB FILE ID: TA20004A TA20005A TA20006A
 DATE EXTRACTED: NA NA NA DATE COLLECTED: NA
 DATE ANALYZED: 01/20/2312:21 01/20/2312:35 01/20/2312:49 DATE RECEIVED: NA
 PREP. BATCH: MEA003W MEA003W MEA003W
 CALIB. REF: TA20002A TA20002A TA20002A

ACCESSION:

PARAMETER	BLNK RSLT (ug/L)	SPIKE AMT (ug/L)	BS RSLT (ug/L)	BS % REC	SPIKE AMT (ug/L)	BSD RSLT (ug/L)	BSD % REC	RPD (%)	QC LIMIT (%)	MAX RPD (%)
Ethanol	ND	10000	9730	97	10000	9310	93	4	60-130	30

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

EMAX QUALITY CONTROL DATA
MS/MSD ANALYSIS

CLIENT: EUROFINS EATON ANALYTICAL
 PROJECT: 380-34727
 BATCH NO.: 23A194
 METHOD: METHOD SW8015C

MATRIX: WATER % MOISTURE: NA
 DILUTION FACTOR: 1 1
 SAMPLE ID: 380-34727-1
 LAB SAMP ID: A194-01 A194-01M A194-01S
 LAB FILE ID: TA20007A TA20008A TA20009A
 DATE EXTRACTED: NA NA NA DATE COLLECTED: 01/17/23
 DATE ANALYZED: 01/20/2313:35 01/20/2313:55 01/20/2314:09 DATE RECEIVED: 01/19/23
 PREP. BATCH: MEA003W MEA003W MEA003W
 CALIB. REF: TA20002A TA20002A TA20002A

ACCESSION:

PARAMETER	SMPL RSLT	SPIKE AMT	MS RSLT	MS	SPIKE AMT	MSD RSLT	MSD	RPD	QC LIMIT	MAX RPD
	(ug/L)	(ug/L)	(ug/L)	% REC	(ug/L)	(ug/L)	% REC	(%)	(%)	(%)
Ethanol	ND	10000	9420	94	10000	9260	93	2	60-130	30



February 27, 2023

Rachelle Arada
Eurofins Eaton Analytical
750 Royal Oaks Drive
Suite 100
Monrovia, CA 91016-

Project Name: RED-HILL Project # 38001111 Job # 380-34727-1
Physis Project ID: 1407003-365

Dear Rachelle,


Enclosed are the analytical results for the sample submitted to PHYSIS Environmental Laboratories, Inc. (PHYSIS) on 1/19/2023. A total of 1 sample was received for analysis in accordance with the attached chain of custody (COC). Per the COC, the sample was analyzed for:

Organics
Polynuclear Aromatic Hydrocarbons by EPA 625.1
Disalicylidene propanediamine by EPA 625.1
Dibenzo [a,l] Pyrene w/ PAHs by EPA 625.1
Base/Neutral Extractable Compounds by EPA 625.1
Acid Extractable Compounds w/ PAHs by EPA 625.1
6-tert-Butyl-2,4-dimethylphenol by EPA 625.1
2,6-Di-tert-butylphenol by EPA 625.1
2,6-Di-tert-butyl-4-methylphenol by EPA 625.1
p-tert-Butylphenol by EPA 625.1

Analytical results in this report apply only to samples submitted to PHYSIS in accordance with the COC and are intended to be considered in their entirety.

Please feel free to contact me at any time with any questions. PHYSIS appreciates the opportunity to provide you with our analytical and support services.

Regards,


Misty Mercier
714 602-5320
Extension 202
mistymercier@physislabs.com



PROJECT SAMPLE LIST

Eurofins Eaton Analytical

PHYSIS Project ID: 1407003-365

RED-HILL Project # 38001111 Job # 380-34727-1

Total Samples: 1

PHYSIS ID	Sample ID	Description	Date	Time	Matrix	Sample Type
103733	AIEA WELLS PUMPS 1&2 (26031-203-TP400 (380-34727-1)		1/17/2023	9:20	Samplewater	Not Specified

ABBREVIATIONS and ACRONYMS

QM	Quality Manual
QA	Quality Assurance
QC	Quality Control
MDL	method detection limit
RL	reporting limit
R1	project sample
R2	project sample replicate
MS1	matrix spike
MS2	matrix spike replicate
B1	procedural blank
B2	procedural blank replicate
BS1	blank spike
BS2	blank spike replicate
LCS1	laboratory control spike
LCS2	laboratory control spike replicate
LCM1	laboratory control material
LCM2	laboratory control material replicate
CRM1	certified reference material
CRM2	certified reference material replicate
RPD	relative percent difference
LMW	low molecular weight
HMW	high molecular weight

QUALITY ASSURANCE SUMMARY

LABORATORY BATCH: Physis' QM defines a laboratory batch as a group of 20 or fewer project samples of similar matrix, processed together under the same conditions and with the same reagents. QC samples are associated with each batch and were used to assess the validity of the sample analyses.

PROCEDURAL BLANK: Laboratory contamination introduced during method use is assessed through the preparation and analysis of procedural blanks is provided at a minimum frequency of one per batch.

ACCURACY: Accuracy of analytical measurements is the degree of closeness based on percent recovery calculations between measured values and the actual or true value and includes a combination of reproducibility error and systematic bias due to sampling and analytical operations. Accuracy of the project data was indicated by analysis of MS, BS, LCS, LCM, CRM, and/or surrogate spikes on a minimum frequency of one per batch. Physis' QM requires that 95% of the target compounds greater than 10 times the MDL be within the specified acceptance limits.

PRECISION: Precision is the agreement among a set of replicate measurements without assumption of knowledge of the true value and is based on RPD calculations between repeated values. Precision of the project data was determined by analysis of replicate MS₁/MS₂, BS₁/BS₂, LCS₁/LCS₂, LCM₁/LCM₂, CRM₁/CRM₂, surrogate spikes and/or replicate project sample analysis (R₁/R₂) on a minimum frequency of one per batch. Physis' QM requires that for 95% of the compounds greater than 10 times the MDL, the percent RPD should be within the specified acceptance range.

BLANK SPIKES: BS is the introduction of a known concentration of analyte into the procedural blank. BS demonstrates performance of the preparation and analytical methods on a clean matrix void of potential matrix related interferences. The BS is performed in laboratory deionized water, making these recoveries a better indicator of the efficiency of the laboratory method per se.

MATRIX SPIKES: MS is the introduction of a known concentration of analyte into a sample. MS samples demonstrate the effect a particular project sample matrix has on the accuracy of a measurement. Individually, MS samples also indicate the bias of analytical measurements due to chemical interferences inherent in the specific project sample spiked. Intrinsic target analyte concentration in the specific project sample can also significantly impact MS recovery.

CERTIFIED REFERENCE MATERIALS: CRMs are materials of various matrices for which analytical information has been determined and certified by a recognized authority. These are used to provide a quantitative assessment of the accuracy of an analytical method. CRMs provide evidence that the laboratory preparation and analysis produces results that are comparable to those obtained by an independent organization.

LABORATORY CONTROL MATERIAL: LCM is provided because a suitable natural seawater CRM is not available and can be used to indicate accuracy of the method. Physis' internal LCM is seawater collected at ~800 meters in the Southern California San Pedro Basin and can be used as a reference for background concentrations in clean, natural seawater for comparison to project samples.

LABORATORY CONTROL SPIKES: LCS is the introduction of a known concentration of analyte into Physis' LCM. LCS samples were employed to assess the effect the seawater matrix has on the accuracy of a measurement. LCS also indicate the bias of this method due to chemical interferences inherent in the seawater matrix. Intrinsic LCM concentration can also significantly impact LCS recovery.

SURROGATES: A surrogate is a pure analyte unlikely to be found in any project sample, behaves similarly to



the target analyte and most often used with organic analytical procedures. Surrogates are added in known concentration to all samples and are measured to indicate overall efficiency of the method including processing and analyses.

HOLDING TIME: Method recommended holding times are the length of time a project sample can be stored under specific conditions after collection and prior to analysis without significantly affecting the analyte's concentration. Holding times can be extended if preservation techniques are employed to reduce biodegradation, volatilization, oxidation, sorption, precipitation, and other physical and chemical processes.

SAMPLE STORAGE/RETENTION: In order to maintain chemical integrity prior to analysis, all samples submitted to Physis are refrigerated (liquids) or frozen (solids) upon receipt unless otherwise recommended by applicable methods. Solid samples are retained for 1 year from collection while liquid samples are retained until method recommended holding times elapse.

TOTAL/DISSOLVED FRACTION: In some instances, the results for the dissolved fraction may be higher than the total fraction for a particular analyte (e.g. trace metals). This is typically caused by the analytical variation for each result and indicates that the target analyte is primarily in the dissolved phase, within the sample.

PHYSIS QUALIFIER CODES

CODE	DEFINITION
#	see Case Narrative
ND	analyte not detected at or above the MDL
B	analyte was detected in the procedural blank greater than 10 times the MDL
E	analyte concentration exceeds the upper limit of the linear calibration range, reported value is estimated
H	sample received and/or analyzed past the recommended holding time
J	analyte was detected at a concentration below the RL and above the MDL, reported value is estimated
N	insufficient sample, analysis could not be performed
M	analyte was outside the specified accuracy and/or precision acceptance limits due to matrix interference. The associated B/BS were within limits, therefore the sample data was reported without further clarification
SH	analyte concentration in the project sample exceeded the spike concentration, therefore accuracy and/or precision acceptance limits do not apply
SL	analyte results were lower than 10 times the MDL, therefore accuracy and/or precision acceptance limits do not apply
NH	project sample was heterogeneous and sample homogeneity could not be readily achieved using routine laboratory practices, therefore accuracy and/or precision acceptance limits do not apply
Q	analyte was outside the specified QAPP acceptance limits for precision and/or accuracy but within Physis derived acceptance limits, therefore the sample data was reported without further clarification
R	Physis' QM allows for 5% of the target compounds greater than 10 times the MDL to be outside the specified acceptance limits for precision and/or accuracy. This is often due to random error and does not indicate any significant problems with the analysis of these project samples



CASE NARRATIVE

QUALIFIER NOTES

In addition to the use of analyte specific Physis Qualifier Codes where applicable, the following were also noted.

ND

MDL is listed due to report format restrictions; it is not used in reporting. Analytical results reported are ND at the RL.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17



PANALYTICALS

REPORT

AURA

TERRA ENVIRONMENTAL SERVICES, INC.

Innovative Solutions for Nature



Innovative Solutions for Nature

PHYSIS Project ID: 1407003-365

Client: Eurofins Eaton Analytical

Project: RED-HILL Project # 38001111 Job # 380-34727-1

Acid Extractable Compounds

ANALYTE	Method	Units	RESULT	DF	MDL	RL	Fraction	QA CODE	Batch ID	Date Processed	Date Analyzed
Sample ID: 103733-R1	AIEA WELLS PUMPS 1&2 (260) 331- Matrix: Samplewater						Sampled:	17-Jan-23 9:20		Received:	19-Jan-23
(2,4,6-Tribromophenol)	EPA 625.1	% Recovery	86	1			Total	O-40114	20-Jan-23		14-Feb-23
(d5-Phenol)	EPA 625.1	% Recovery	20	1			Total	O-40114	20-Jan-23		14-Feb-23
2,4,5-Trichlorophenol	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23		14-Feb-23
2,4,6-Trichlorophenol	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23		14-Feb-23
2,4-Dichlorophenol	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23		14-Feb-23
2,4-Dinitrophenol	EPA 625.1	µg/L	ND	1	0.1	0.2	Total	O-40114	20-Jan-23		14-Feb-23
2,6-Dichlorophenol	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23		14-Feb-23
2,6-Di-tert-butyl-4-methylphenol	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23		14-Feb-23
2,6-Di-tert-butylphenol	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23		14-Feb-23
2-Chlorophenol	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23		14-Feb-23
2-Methyl-4,6-dinitrophenol	EPA 625.1	µg/L	ND	1	0.1	0.2	Total	O-40114	20-Jan-23		14-Feb-23
2-Methylphenol	EPA 625.1	µg/L	ND	1	0.1	0.2	Total	O-40114	20-Jan-23		14-Feb-23
2-Nitrophenol	EPA 625.1	µg/L	ND	1	0.1	0.2	Total	O-40114	20-Jan-23		14-Feb-23
3+4-Methylphenol	EPA 625.1	µg/L	ND	1	0.1	0.2	Total	O-40114	20-Jan-23		14-Feb-23
4-Chloro-3-methylphenol	EPA 625.1	µg/L	ND	1	0.1	0.2	Total	O-40114	20-Jan-23		14-Feb-23
4-Nitrophenol	EPA 625.1	µg/L	ND	1	0.1	0.2	Total	O-40114	20-Jan-23		14-Feb-23
6-tert-butyl-2,4-dimethylphenol	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23		14-Feb-23
Benzoic Acid	EPA 625.1	µg/L	ND	1	0.1	0.2	Total	O-40114	20-Jan-23		14-Feb-23
Benzyl Alcohol	EPA 625.1	µg/L	ND	1	0.1	0.2	Total	O-40114	20-Jan-23		14-Feb-23
Pentachlorophenol	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23		14-Feb-23
Phenol	EPA 625.1	µg/L	ND	1	0.1	0.2	Total	O-40114	20-Jan-23		14-Feb-23
p-tert-Butylphenol	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23		14-Feb-23



Innovative Solutions for Nature

PHYSIS Project ID: 1407003-365

Client: Eurofins Eaton Analytical

Project: RED-HILL Project # 38001111 Job # 380-34727-1

Base/Neutral Extractable Compounds

ANALYTE	Method	Units	RESULT	DF	MDL	RL	Fraction	QA CODE	Batch ID	Date Processed	Date Analyzed
Sample ID: 103733-R1	AIEA WELLS PUMPS 1&2 (260) 331-	Matrix: Samplewater					Sampled:	17-Jan-23	9:20	Received:	19-Jan-23
2-Chloronaphthalene	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
2-Nitroaniline	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
3-Nitroaniline	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
4-Bromophenylphenyl ether	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
4-Chloroaniline	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
4-Chlorophenylphenyl ether	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
4-Nitroaniline	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
Aniline	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
Benzidine	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
Bis(2-Chloroethoxy) methane	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
Bis(2-Chloroethyl) ether	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
Bis(2-Chloroisopropyl) ether	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
D benzofuran	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
Disalicylidene propanediamine	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
Hexachloroethane	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
Nitrobenzene	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
N-Nitrosodi-n-propylamine	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	
N-Nitrosodiphenylamine	EPA 625.1	µg/L	ND	1	0.05	0.1	Total	O-40114	20-Jan-23	14-Feb-23	



Innovative Solutions for Nature

PHYSIS Project ID: 1407003-365

Client: Eurofins Eaton Analytical

Project: RED-HILL Project # 38001111 Job # 380-34727-1

Polynuclear Aromatic Hydrocarbons

ANALYTE	Method	Units	RESULT	DF	MDL	RL	Fraction	QA CODE	Batch ID	Date Processed	Date Analyzed
Sample ID: 103733-R1 AIEA WELLS PUMPS 1&2 (260) 331- Matrix: Samplewater							Sampled:	17-Jan-23	9:20	Received:	19-Jan-23
(d10-Acenaphthene)	EPA 625.1	% Recovery	91	1			Total	O-40114	20-Jan-23	14-Feb-23	
(d10-Phenanthrene)	EPA 625.1	% Recovery	96	1			Total	O-40114	20-Jan-23	14-Feb-23	
(d12-Chrysene)	EPA 625.1	% Recovery	95	1			Total	O-40114	20-Jan-23	14-Feb-23	
(d12-Perylene)	EPA 625.1	% Recovery	90	1			Total	O-40114	20-Jan-23	14-Feb-23	
(d8-Naphthalene)	EPA 625.1	% Recovery	81	1			Total	O-40114	20-Jan-23	14-Feb-23	
1-Methylnaphthalene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
1-Methylphenanthrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
2,3,5-Trimethylnaphthalene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
2,6-Dimethylnaphthalene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
2-Methylnaphthalene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Acenaphthene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Acenaphthylene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Anthracene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Benz[a]anthracene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Benzo[a]pyrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Benzo[b]fluoranthene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Benzo[e]pyrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Benzo[g,h,i]perylene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Benzo[k]fluoranthene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Biphenyl	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Chrysene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
D benz[a,h]anthracene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
D benzo[a,l]pyrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
D benzothiophene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	



Innovative Solutions for Nature

PHYSIS Project ID: 1407003-365

Client: Eurofins Eaton Analytical

Project: RED-HILL Project # 38001111 Job # 380-34727-1

Polynuclear Aromatic Hydrocarbons

ANALYTE	Method	Units	RESULT	DF	MDL	RL	Fraction	QA CODE	Batch ID	Date Processed	Date Analyzed
Fluoranthene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Fluorene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Indeno[1,2,3-cd]pyrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Naphthalene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Perylene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Phenanthrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	
Pyrene	EPA 625.1	µg/L	ND	1	0.001	0.005	Total	O-40114	20-Jan-23	14-Feb-23	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17



QUALITY CONTROL

REPORT

AURA AURA

ENVIRONMENTAL LABORATORIES, INC.

TERRA

Innovative Solutions for Nature



Innovative Solutions for Nature

PHYSIS Project ID: 1407003-365
Client: Eurofins Eaton Analytical
Project: RED-HILL Project # 38001111 Job # 380-34727-1

Acid Extractable Compounds

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE LEVEL	SOURCE	ACCURACY %	PRECISION %	QA CODEc						
								RESULT									
Sample ID: 103732-B1	QAQC Procedural Blank						Matrix: Blank/Matrix		Sampled:		Received:						
	Method: EPA 625.1						Batch ID: O-40114		Prepared: 20-Jan-23		Analyzed: 13-Feb-23						
(2,4,6-Tribromophenol)	Total	93	1			% Recovery	100		93	30 - 130%	PASS						
(d5-Phenol)	Total	76	1			% Recovery	100		76	0 - 130%	PASS						
2,4,5-Trichlorophenol	Total	ND	1	0.05	0.1	µg/L											
2,4,6-Trichlorophenol	Total	ND	1	0.05	0.1	µg/L											
2,4-Dichlorophenol	Total	ND	1	0.05	0.1	µg/L											
2,4-Dinitrophenol	Total	ND	1	0.1	0.2	µg/L											
2,6-Dichlorophenol	Total	ND	1	0.05	0.1	µg/L											
2,6-Di-tert-butyl-4-methylphe nol	Total	ND	1	0.05	0.1	µg/L											
2,6-Di-tert-butylphenol	Total	ND	1	0.05	0.1	µg/L											
2-Chlorophenol	Total	ND	1	0.05	0.1	µg/L											
2-Methyl-4,6-dinitrophenol	Total	ND	1	0.1	0.2	µg/L											
2-Methylphenol	Total	ND	1	0.1	0.2	µg/L											
2-Nitrophenol	Total	ND	1	0.1	0.2	µg/L											
3+4-Methylphenol	Total	ND	1	0.1	0.2	µg/L											
4-Chloro-3-methylphenol	Total	ND	1	0.1	0.2	µg/L											
4-Nitrophenol	Total	ND	1	0.1	0.2	µg/L											
6-tert-butyl-2,4-dimethylphen ol	Total	ND	1	0.05	0.1	µg/L											
Benzoic Acid	Total	ND	1	0.1	0.2	µg/L											
Benzyl Alcohol	Total	ND	1	0.1	0.2	µg/L											
Pentachlorophenol	Total	ND	1	0.05	0.1	µg/L											
Phenol	Total	ND	1	0.1	0.2	µg/L											
p-tert-Butylphenol	Total	ND	1	0.05	0.1	µg/L											



PHYSIS Project ID: 1407003-365
 Client: Eurofins Eaton Analytical
 Project: RED-HILL Project # 38001111 Job # 380-34727-1

Acid Extractable Compounds

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY %	PRECISION %	QA CODEc
							LEVEL	RESULT			
Sample ID: 103732-BS1		QAQC Procedural Blank		Matrix: Blank/Matrix		Sampled:		Received:			
(2,4,6-Tribromophenol)	Total	108	1			% Recovery	100	0	108	30 - 130%	PASS
(d5-Phenol)	Total	82	1			% Recovery	100	0	82	0 - 130%	PASS
2,4,5-Trichlorophenol	Total	0.923	1	0.05	0.1	µg/L	1	0	92	30 - 130%	PASS
2,4,6-Trichlorophenol	Total	0.791	1	0.05	0.1	µg/L	1	0	79	56 - 118%	PASS
2,4-Dichlorophenol	Total	0.74	1	0.05	0.1	µg/L	1	0	74	51 - 117%	PASS
2,4-Dinitrophenol	Total	1.13	1	0.1	0.2	µg/L	1	0	113	0 - 152%	PASS
2,6-Dichlorophenol	Total	0.355	1	0.05	0.1	µg/L	0.5	0	71	30 - 130%	PASS
2,6-Di-tert-butyl-4-methylphe nol	Total	0.724	1	0.05	0.1	µg/L	1	0	72	50 - 150%	PASS
2,6-Di-tert-butylphenol	Total	0.821	1	0.05	0.1	µg/L	1	0	82	50 - 150%	PASS
2-Chlorophenol	Total	0.661	1	0.05	0.1	µg/L	1	0	66	41 - 110%	PASS
2-Methyl-4,6-dinitrophenol	Total	1.08	1	0.1	0.2	µg/L	1	0	108	0 - 141%	PASS
2-Methylphenol	Total	0.761	1	0.1	0.2	µg/L	1	0	76	40 - 117%	PASS
2-Nitrophenol	Total	0.632	1	0.1	0.2	µg/L	1	0	63	40 - 117%	PASS
3+4-Methylphenol	Total	0.784	1	0.1	0.2	µg/L	1	0	78	0 - 130%	PASS
4-Chloro-3-methylphenol	Total	0.839	1	0.1	0.2	µg/L	1	0	84	51 - 128%	PASS
4-Nitrophenol	Total	0.824	1	0.1	0.2	µg/L	1	0	82	10 - 164%	PASS
6-tert-butyl-2,4-dimethylphen ol	Total	0.721	1	0.05	0.1	µg/L	1	0	72	50 - 150%	PASS
Benzoic Acid	Total	0.63	1	0.1	0.2	µg/L	1	0	63	2 - 145%	PASS
Benzyl Alcohol	Total	0.783	1	0.1	0.2	µg/L	1	0	78	43 - 148%	PASS
Pentachlorophenol	Total	1.1	1	0.05	0.1	µg/L	1	0	110	36 - 111%	PASS
Phenol	Total	0.693	1	0.1	0.2	µg/L	1	0	69	29 - 114%	PASS
p-tert-Butylphenol	Total	0.865	1	0.05	0.1	µg/L	1	0	87	50 - 150%	PASS



PHYSIS Project ID: 1407003-365
 Client: Eurofins Eaton Analytical
 Project: RED-HILL Project # 38001111 Job # 380-34727-1

Acid Extractable Compounds

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE LEVEL	SOURCE RESULT	ACCURACY %		PRECISION %		QA CODEc					
									LIMITS	LIMITS	%	LIMITS						
Sample ID: 103732-BS2		QAQC Procedural Blank				Matrix: Blank/Matrix		Sampled:				Received:						
Method: EPA 625.1							Batch ID: O-40114		Prepared: 20-Jan-23		Analyzed: 13-Feb-23							
(2,4,6-Tribromophenol)	Total	107	1			% Recovery	100	0	107	30 - 130%	PASS	1	30 PASS					
(d5-Phenol)	Total	95	1			% Recovery	100	0	95	0 - 130%	PASS	15	30 PASS					
2,4,5-Trichlorophenol	Total	0.827	1	0.05	0.1	µg/L	1	0	83	30 - 130%	PASS	10	30 PASS					
2,4,6-Trichlorophenol	Total	0.809	1	0.05	0.1	µg/L	1	0	81	56 - 118%	PASS	2	30 PASS					
2,4-Dichlorophenol	Total	0.832	1	0.05	0.1	µg/L	1	0	83	51 - 117%	PASS	11	30 PASS					
2,4-Dinitrophenol	Total	0.955	1	0.1	0.2	µg/L	1	0	95	0 - 152%	PASS	16	30 PASS					
2,6-Dichlorophenol	Total	0.404	1	0.05	0.1	µg/L	0.5	0	81	30 - 130%	PASS	13	30 PASS					
2,6-Di-tert-butyl-4-methylphe nol	Total	0.774	1	0.05	0.1	µg/L	1	0	77	50 - 150%	PASS	7	30 PASS					
2,6-Di-tert-butylphenol	Total	0.854	1	0.05	0.1	µg/L	1	0	85	50 - 150%	PASS	4	30 PASS					
2-Chlorophenol	Total	0.788	1	0.05	0.1	µg/L	1	0	79	41 - 110%	PASS	18	30 PASS					
2-Methyl-4,6-dinitrophenol	Total	0.869	1	0.1	0.2	µg/L	1	0	87	0 - 141%	PASS	22	30 PASS					
2-Methylphenol	Total	0.853	1	0.1	0.2	µg/L	1	0	85	40 - 117%	PASS	11	30 PASS					
2-Nitrophenol	Total	0.759	1	0.1	0.2	µg/L	1	0	76	40 - 117%	PASS	19	30 PASS					
3+4-Methylphenol	Total	0.841	1	0.1	0.2	µg/L	1	0	84	0 - 130%	PASS	7	30 PASS					
4-Chloro-3-methylphenol	Total	0.903	1	0.1	0.2	µg/L	1	0	90	51 - 128%	PASS	7	30 PASS					
4-Nitrophenol	Total	0.871	1	0.1	0.2	µg/L	1	0	87	10 - 164%	PASS	6	30 PASS					
6-tert-butyl-2,4-dimethylphen ol	Total	0.778	1	0.05	0.1	µg/L	1	0	78	50 - 150%	PASS	8	30 PASS					
Benzoic Acid	Total	0.619	1	0.1	0.2	µg/L	1	0	62	2 - 145%	PASS	2	30 PASS					
Benzyl Alcohol	Total	0.862	1	0.1	0.2	µg/L	1	0	86	43 - 148%	PASS	10	30 PASS					
Pentachlorophenol	Total	0.949	1	0.05	0.1	µg/L	1	0	95	36 - 111%	PASS	15	30 PASS					
Phenol	Total	0.808	1	0.1	0.2	µg/L	1	0	81	29 - 114%	PASS	16	30 PASS					
p-tert-Butylphenol	Total	0.937	1	0.05	0.1	µg/L	1	0	94	50 - 150%	PASS	9	30 PASS					



PHYSIS Project ID: 1407003-365
Client: Eurofins Eaton Analytical
Project: RED-HILL Project # 38001111 Job # 380-34727-1

Base/Neutral Extractable Compounds

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE LEVEL	SOURCE RESULT	ACCURACY %	PRECISION %	QA CODEc
Sample ID: 103732-B1		QAQC Procedural Blank				Matrix: Blank/Matrix		Sampled:		Received:	
Method: EPA 625.1						Batch ID: O-40114		Prepared: 20-Jan-23		Analyzed: 13-Feb-23	
2-Chloronaphthalene	Total	ND	1	0.05	0.1	µg/L					
2-Nitroaniline	Total	ND	1	0.05	0.1	µg/L					
3-Nitroaniline	Total	ND	1	0.05	0.1	µg/L					
4-Bromophenylphenyl ether	Total	ND	1	0.05	0.1	µg/L					
4-Chloroaniline	Total	ND	1	0.05	0.1	µg/L					
4-Chlorophenylphenyl ether	Total	ND	1	0.05	0.1	µg/L					
4-Nitroaniline	Total	ND	1	0.05	0.1	µg/L					
Aniline	Total	ND	1	0.05	0.1	µg/L					
Benzidine	Total	ND	1	0.05	0.1	µg/L					
Bis(2-Chloroethoxy) methane	Total	ND	1	0.05	0.1	µg/L					
Bis(2-Chloroethyl) ether	Total	ND	1	0.05	0.1	µg/L					
Bis(2-Chloroisopropyl) ether	Total	ND	1	0.05	0.1	µg/L					
Dibenzofuran	Total	ND	1	0.05	0.1	µg/L					
Disalicylidene propanediamin	Total	ND	1	0.05	0.1	µg/L					
Hexachloroethane	Total	ND	1	0.05	0.1	µg/L					
Nitrobenzene	Total	ND	1	0.05	0.1	µg/L					
N-Nitrosodi-n-propylamine	Total	ND	1	0.05	0.1	µg/L					
N-Nitrosodiphenylamine	Total	ND	1	0.05	0.1	µg/L					



Innovative Solutions for Nature

PHYSIS Project ID: 1407003-365

Client: Eurofins Eaton Analytical

Project: RED-HILL Project # 38001111 Job # 380-34727-1

Base/Neutral Extractable Compounds

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE LEVEL	SOURCE RESULT	ACCURACY		PRECISION %	QA CODEc LIMITS
									%	LIMITS		
Sample ID: 103732-BS1 QAQC Procedural Blank												
		Method: EPA 625.1				Batch ID: O-40114			Prepared: 20-Jan-23			Analyzed: 13-Feb-23
2-Chloronaphthalene	Total	0.849	1	0.05	0.1	µg/L	1	0	85	53 - 130%	PASS	
2-Nitroaniline	Total	0.771	1	0.05	0.1	µg/L	1	0	77	69 - 114%	PASS	
3-Nitroaniline	Total	0.794	1	0.05	0.1	µg/L	1	0	79	23 - 137%	PASS	
4-Bromophenylphenyl ether	Total	0.824	1	0.05	0.1	µg/L	1	0	82	61 - 132%	PASS	
4-Chloroaniline	Total	0.639	1	0.05	0.1	µg/L	1	0	64	50 - 150%	PASS	
4-Chlorophenylphenyl ether	Total	0.862	1	0.05	0.1	µg/L	1	0	86	63 - 130%	PASS	
4-Nitroaniline	Total	0.851	1	0.05	0.1	µg/L	1	0	85	10 - 159%	PASS	
Aniline	Total	0.571	1	0.05	0.1	µg/L	1	0	57	50 - 150%	PASS	
Benzidine	Total	0.0145	1	0.05	0.1	µg/L	1	0	1	0 - 125%	PASS	
Bis(2-Chloroethoxy) methane	Total	0.835	1	0.05	0.1	µg/L	1	0	83	66 - 122%	PASS	
Bis(2-Chloroethyl) ether	Total	0.78	1	0.05	0.1	µg/L	1	0	78	43 - 127%	PASS	
Bis(2-Chloroisopropyl) ether	Total	0.765	1	0.05	0.1	µg/L	1	0	76	49 - 128%	PASS	
Dibenzofuran	Total	0.824	1	0.05	0.1	µg/L	1	0	82	50 - 150%	PASS	
Disalicylidene propanediamin	Total	51.7	1	0.05	0.1	µg/L	50	0	103	50 - 150%	PASS	
Hexachloroethane	Total	0.621	1	0.05	0.1	µg/L	1	0	62	27 - 130%	PASS	
Nitrobenzene	Total	0.708	1	0.05	0.1	µg/L	1	0	71	54 - 111%	PASS	
N-Nitrosodi-n-propylamine	Total	0.771	1	0.05	0.1	µg/L	1	0	77	61 - 152%	PASS	
N-Nitrosodiphenylamine	Total	0.864	1	0.05	0.1	µg/L	1	0	86	49 - 142%	PASS	

Base/Neutral Extractable Compounds

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE LEVEL	SOURCE RESULT	ACCURACY %		PRECISION %		QA CODEc					
									LIMITS	LIMITS	%	LIMITS						
Sample ID: 103732-BS2		QAQC Procedural Blank			Matrix: Blank/Matrix			Sampled:			Received:							
		Method: EPA 625.1			Batch ID: O-40114			Prepared: 20-Jan-23			Analyzed: 13-Feb-23							
2-Chloronaphthalene	Total	0.889	1	0.05	0.1	µg/L	1	0	89	53 - 130%	PASS	5	30	PASS				
2-Nitroaniline	Total	0.859	1	0.05	0.1	µg/L	1	0	86	69 - 114%	PASS	11	30	PASS				
3-Nitroaniline	Total	0.852	1	0.05	0.1	µg/L	1	0	85	23 - 137%	PASS	7	30	PASS				
4-Bromophenylphenyl ether	Total	0.871	1	0.05	0.1	µg/L	1	0	87	61 - 132%	PASS	6	30	PASS				
4-Chloroaniline	Total	0.666	1	0.05	0.1	µg/L	1	0	67	50 - 150%	PASS	5	30	PASS				
4-Chlorophenylphenyl ether	Total	0.883	1	0.05	0.1	µg/L	1	0	88	63 - 130%	PASS	2	30	PASS				
4-Nitroaniline	Total	0.919	1	0.05	0.1	µg/L	1	0	92	10 - 159%	PASS	8	30	PASS				
Aniline	Total	0.635	1	0.05	0.1	µg/L	1	0	63	50 - 150%	PASS	12	30	PASS				
Benzidine	Total	0.00615	1	0.05	0.1	µg/L	1	0	1	0 - 125%	PASS	0	30	PASS				
Bis(2-Chloroethoxy) methane	Total	0.951	1	0.05	0.1	µg/L	1	0	95	66 - 122%	PASS	12	30	PASS				
Bis(2-Chloroethyl) ether	Total	0.943	1	0.05	0.1	µg/L	1	0	94	43 - 127%	PASS	19	30	PASS				
Bis(2-Chloroisopropyl) ether	Total	0.899	1	0.05	0.1	µg/L	1	0	90	49 - 128%	PASS	17	30	PASS				
Dibenzofuran	Total	0.881	1	0.05	0.1	µg/L	1	0	88	50 - 150%	PASS	7	30	PASS				
Disalicylidene propanediamin	Total	59.8	1	0.05	0.1	µg/L	50	0	120	50 - 150%	PASS	15	30	PASS				
Hexachloroethane	Total	0.704	1	0.05	0.1	µg/L	1	0	70	27 - 130%	PASS	12	30	PASS				
Nitrobenzene	Total	0.819	1	0.05	0.1	µg/L	1	0	82	54 - 111%	PASS	14	30	PASS				
N-Nitrosodi-n-propylamine	Total	0.84	1	0.05	0.1	µg/L	1	0	84	61 - 152%	PASS	9	30	PASS				
N-Nitrosodiphenylamine	Total	0.887	1	0.05	0.1	µg/L	1	0	89	49 - 142%	PASS	3	30	PASS				



Innovative Solutions for Nature

PHYSIS Project ID: 1407003-365
Client: Eurofins Eaton Analytical
Project: RED-HILL Project # 38001111 Job # 380-34727-1

Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE LEVEL	SOURCE RESULT	ACCURACY %	PRECISION %	QA CODEc LIMITS
Sample ID: 103732-B1		QAQC Procedural Blank						Matrix: Blank/Matrix		Sampled:	
Method: EPA 625.1						Batch ID: O-40114		Prepared: 20-Jan-23		Analyzed: 13-Feb-23	
(d10-Acenaphthene)	Total	98	1			% Recovery	100		98	27 - 133%	PASS
(d10-Phenanthrene)	Total	97	1			% Recovery	100		97	43 - 129%	PASS
(d12-Chrysene)	Total	104	1			% Recovery	100		104	52 - 144%	PASS
(d12-Perylene)	Total	96	1			% Recovery	100		96	36 - 161%	PASS
(d8-Naphthalene)	Total	86	1			% Recovery	100		86	25 - 125%	PASS
1-Methylnaphthalene	Total	ND	1	0.001	0.005	µg/L					
1-Methylphenanthrene	Total	ND	1	0.001	0.005	µg/L					
2,3,5-Trimethylnaphthalene	Total	ND	1	0.001	0.005	µg/L					
2,6-Dimethylnaphthalene	Total	ND	1	0.001	0.005	µg/L					
2-Methylnaphthalene	Total	ND	1	0.001	0.005	µg/L					
Acenaphthene	Total	ND	1	0.001	0.005	µg/L					
Acenaphthylene	Total	ND	1	0.001	0.005	µg/L					
Anthracene	Total	ND	1	0.001	0.005	µg/L					
Benz[a]anthracene	Total	ND	1	0.001	0.005	µg/L					
Benzo[a]pyrene	Total	ND	1	0.001	0.005	µg/L					
Benzo[b]fluoranthene	Total	ND	1	0.001	0.005	µg/L					
Benzo[e]pyrene	Total	ND	1	0.001	0.005	µg/L					
Benzo[g,h,i]perylene	Total	ND	1	0.001	0.005	µg/L					
Benzo[k]fluoranthene	Total	ND	1	0.001	0.005	µg/L					
Biphenyl	Total	ND	1	0.001	0.005	µg/L					
Chrysene	Total	ND	1	0.001	0.005	µg/L					
Dibenz[a,h]anthracene	Total	ND	1	0.001	0.005	µg/L					
Dibenzo[a,i]pyrene	Total	ND	1	0.001	0.005	µg/L					
Dibenzothiophene	Total	ND	1	0.001	0.005	µg/L					



Innovative Solutions for Nature

PHYSIS Project ID: 1407003-365

Client: Eurofins Eaton Analytical

Project: RED-HILL Project # 38001111 Job # 380-34727-1

Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY	PRECISION	QA CODEc
							LEVEL	RESULT			
Fluoranthene	Total	ND	1	0.001	0.005	µg/L					
Fluorene	Total	ND	1	0.001	0.005	µg/L					
Indeno[1,2,3-cd]pyrene	Total	ND	1	0.001	0.005	µg/L					
Naphthalene	Total	ND	1	0.001	0.005	µg/L					
Perylene	Total	ND	1	0.001	0.005	µg/L					
Phenanthrene	Total	ND	1	0.001	0.005	µg/L					
Pyrene	Total	ND	1	0.001	0.005	µg/L					



PHYSIS Project ID: 1407003-365
 Client: Eurofins Eaton Analytical
 Project: RED-HILL Project # 38001111 Job # 380-34727-1

Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY %	PRECISION %	QA CODEc	
							LEVEL	RESULT				
Sample ID: 103732-BS1		QAQC Procedural Blank						Matrix: Blank/Matrix		Sampled:		Received:
(d10-Acenaphthene)	Total	93	1				Method: EPA 625.1	Batch ID: O-40114	Prepared: 20-Jan-23		Analyzed: 13-Feb-23	
(d10-Phenanthrene)	Total	93	1				% Recovery	100	0	93	27 - 133% PASS	
(d12-Chrysene)	Total	102	1				% Recovery	100	0	102	52 - 144% PASS	
(d12-Perylene)	Total	95	1				% Recovery	100	0	95	36 - 161% PASS	
(d8-Naphthalene)	Total	80	1				% Recovery	100	0	80	25 - 125% PASS	
1-Methylnaphthalene	Total	0.454	1	0.001	0.005	µg/L	0.5	0	91	31 - 128% PASS		
1-Methylphenanthrene	Total	0.454	1	0.001	0.005	µg/L	0.5	0	91	66 - 127% PASS		
2,3,5-Trimethylnaphthalene	Total	0.482	1	0.001	0.005	µg/L	0.5	0	96	55 - 122% PASS		
2,6-Dimethylnaphthalene	Total	0.459	1	0.001	0.005	µg/L	0.5	0	92	48 - 120% PASS		
2-Methylnaphthalene	Total	1.4	1	0.001	0.005	µg/L	1.5	0	93	47 - 130% PASS		
Acenaphthene	Total	1.49	1	0.001	0.005	µg/L	1.5	0	99	53 - 131% PASS		
Acenaphthylene	Total	1.47	1	0.001	0.005	µg/L	1.5	0	98	43 - 140% PASS		
Anthracene	Total	1.49	1	0.001	0.005	µg/L	1.5	0	99	58 - 135% PASS		
Benz[a]anthracene	Total	1.6	1	0.001	0.005	µg/L	1.5	0	107	55 - 145% PASS		
Benzo[a]pyrene	Total	1.57	1	0.001	0.005	µg/L	1.5	0	105	51 - 143% PASS		
Benzo[b]fluoranthene	Total	1.65	1	0.001	0.005	µg/L	1.5	0	110	46 - 165% PASS		
Benzo[e]pyrene	Total	0.49	1	0.001	0.005	µg/L	0.5	0	98	42 - 152% PASS		
Benzo[g,h,i]perylene	Total	1.54	1	0.001	0.005	µg/L	1.5	0	103	63 - 133% PASS		
Benzo[k]fluoranthene	Total	1.59	1	0.001	0.005	µg/L	1.5	0	106	56 - 145% PASS		
Biphenyl	Total	0.478	1	0.001	0.005	µg/L	0.5	0	96	56 - 119% PASS		
Chrysene	Total	1.65	1	0.001	0.005	µg/L	1.5	0	110	56 - 141% PASS		
Dibenz[a,h]anthracene	Total	1.76	1	0.001	0.005	µg/L	1.5	0	117	55 - 150% PASS		
Dibenzo[a,i]pyrene	Total	0.456	1	0.001	0.005	µg/L	0.5	0	91	50 - 150% PASS		
Dibenzothiophene	Total	0.475	1	0.001	0.005	µg/L	0.5	0	95	46 - 126% PASS		



Innovative Solutions for Nature

PHYSIS Project ID: 1407003-365

Client: Eurofins Eaton Analytical

Project: RED-HILL Project # 38001111 Job # 380-34727-1

Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE LEVEL	SOURCE RESULT	ACCURACY		PRECISION %	QA CODEc LIMITS
									%	LIMITS		
Fluoranthene	Total	1.53	1	0.001	0.005	µg/L	1.5	0	102	60 - 146%	PASS	
Fluorene	Total	1.55	1	0.001	0.005	µg/L	1.5	0	103	58 - 131%	PASS	
Indeno[1,2,3-cd]pyrene	Total	1.77	1	0.001	0.005	µg/L	1.5	0	118	50 - 151%	PASS	
Naphthalene	Total	1.3	1	0.001	0.005	µg/L	1.5	0	87	41 - 126%	PASS	
Perylene	Total	0.463	1	0.001	0.005	µg/L	0.5	0	93	48 - 141%	PASS	
Phenanthrene	Total	1.5	1	0.001	0.005	µg/L	1.5	0	100	67 - 127%	PASS	
Pyrene	Total	1.53	1	0.001	0.005	µg/L	1.5	0	102	54 - 156%	PASS	



PHYSIS Project ID: 1407003-365
 Client: Eurofins Eaton Analytical
 Project: RED-HILL Project # 38001111 Job # 380-34727-1

Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE	SOURCE	ACCURACY		PRECISION		QA CODEc
							LEVEL	RESULT	%	LIMITS	%	LIMITS	
Sample ID: 103732-BS2		QAQC Procedural Blank		Matrix: Blank/Matrix			Sampled:			Received:			
(d10-Acenaphthene)	Total	96	1			% Recovery	100	0	96	27 - 133%	PASS	3	30 PASS
(d10-Phenanthrene)	Total	96	1			% Recovery	100	0	96	43 - 129%	PASS	3	30 PASS
(d12-Chrysene)	Total	105	1			% Recovery	100	0	105	52 - 144%	PASS	3	30 PASS
(d12-Perylene)	Total	92	1			% Recovery	100	0	92	36 - 161%	PASS	3	30 PASS
(d8-Naphthalene)	Total	93	1			% Recovery	100	0	93	25 - 125%	PASS	15	30 PASS
1-Methylnaphthalene	Total	0.49	1	0.001	0.005	µg/L	0.5	0	98	31 - 128%	PASS	7	30 PASS
1-Methylphenanthrene	Total	0.484	1	0.001	0.005	µg/L	0.5	0	97	66 - 127%	PASS	6	30 PASS
2,3,5-Trimethylnaphthalene	Total	0.499	1	0.001	0.005	µg/L	0.5	0	100	55 - 122%	PASS	4	30 PASS
2,6-Dimethylnaphthalene	Total	0.475	1	0.001	0.005	µg/L	0.5	0	95	48 - 120%	PASS	3	30 PASS
2-Methylnaphthalene	Total	1.52	1	0.001	0.005	µg/L	1.5	0	101	47 - 130%	PASS	8	30 PASS
Acenaphthene	Total	1.57	1	0.001	0.005	µg/L	1.5	0	105	53 - 131%	PASS	6	30 PASS
Acenaphthylene	Total	1.52	1	0.001	0.005	µg/L	1.5	0	101	43 - 140%	PASS	3	30 PASS
Anthracene	Total	1.51	1	0.001	0.005	µg/L	1.5	0	101	58 - 135%	PASS	2	30 PASS
Benz[a]anthracene	Total	1.62	1	0.001	0.005	µg/L	1.5	0	108	55 - 145%	PASS	1	30 PASS
Benzo[a]pyrene	Total	1.57	1	0.001	0.005	µg/L	1.5	0	105	51 - 143%	PASS	0	30 PASS
Benzo[b]fluoranthene	Total	1.7	1	0.001	0.005	µg/L	1.5	0	113	46 - 165%	PASS	3	30 PASS
Benzo[e]pyrene	Total	0.455	1	0.001	0.005	µg/L	0.5	0	91	42 - 152%	PASS	7	30 PASS
Benzo[g,h,i]perylene	Total	1.55	1	0.001	0.005	µg/L	1.5	0	103	63 - 133%	PASS	0	30 PASS
Benzo[k]fluoranthene	Total	1.6	1	0.001	0.005	µg/L	1.5	0	107	56 - 145%	PASS	1	30 PASS
Biphenyl	Total	0.497	1	0.001	0.005	µg/L	0.5	0	99	56 - 119%	PASS	3	30 PASS
Chrysene	Total	1.65	1	0.001	0.005	µg/L	1.5	0	110	56 - 141%	PASS	0	30 PASS
Dibenz[a,h]anthracene	Total	1.76	1	0.001	0.005	µg/L	1.5	0	117	55 - 150%	PASS	0	30 PASS
Dibenzo[a,i]pyrene	Total	0.462	1	0.001	0.005	µg/L	0.5	0	92	50 - 150%	PASS	1	30 PASS
Dibenzothiophene	Total	0.5	1	0.001	0.005	µg/L	0.5	0	100	46 - 126%	PASS	5	30 PASS



PHYSIS Project ID: 1407003-365

Client: Eurofins Eaton Analytical

Project: RED-HILL Project # 38001111 Job # 380-34727-1

Polynuclear Aromatic Hydrocarbons

QUALITY CONTROL REPORT

ANALYTE	FRACTION	RESULT	DF	MDL	RL	UNITS	SPIKE LEVEL	SOURCE RESULT	ACCURACY		PRECISION		QA CODEc
									%	LIMITS	%	LIMITS	
Fluoranthene	Total	1.58	1	0.001	0.005	µg/L	1.5	0	105	60 - 146%	PASS	3	30 PASS
Fluorene	Total	1.58	1	0.001	0.005	µg/L	1.5	0	105	58 - 131%	PASS	2	30 PASS
Indeno[1,2,3-cd]pyrene	Total	1.85	1	0.001	0.005	µg/L	1.5	0	123	50 - 151%	PASS	4	30 PASS
Naphthalene	Total	1.49	1	0.001	0.005	µg/L	1.5	0	99	41 - 126%	PASS	13	30 PASS
Perylene	Total	0.487	1	0.001	0.005	µg/L	0.5	0	97	48 - 141%	PASS	4	30 PASS
Phenanthrene	Total	1.54	1	0.001	0.005	µg/L	1.5	0	103	67 - 127%	PASS	3	30 PASS
Pyrene	Total	1.58	1	0.001	0.005	µg/L	1.5	0	105	54 - 156%	PASS	3	30 PASS

TENTATIVELY IDENTIFIED COMPOUNDS

ENVIRONMENTAL LABORATORIES, INC.

Innovative Solutions for Nature

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

Sample ID: 103733

Retention Time	Area (% of total)	Concentration (ng/L)	Library/ID	Cas Number	Match Quality (%)
35.8680	6.5142	1111	Anthracene-D10-	1719-06-8	96
10.7983	1.1869	202	1,5-Heptadien-4-one, 3,3,6-trimethyl-	546-49-6	88
10.1627	0.7917	135	Cyclopentane, 1,2,3,4,5-pentamethyl-	1000152-79-7	90
32.5851	0.7575	129	Benzoic acid, 2-ethylhexyl ester	5444-75-7	96

Concentration estimated using the response for Anthracene-d10

Sample ID: Lab Blank B1_40114

Retention Time	Area (% of total)	Concentration (ng/L)	Library/ID	Cas Number	Match Quality (%)
35.8727	5.3631	1111	Anthracene-D10-	1719-06-8	94
10.8002	1.2601	261	1,5-Heptadien-4-one, 3,3,6-trimethyl-	546-49-6	87
10.1649	0.4883	101	Cyclopentane, 1,2,3,4,5-pentamethyl-	1000152-79-7	89

Concentration estimated using the response for Anthracene-d10

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

Monrovia, CA (Suite 100)
750 Royal Oaks Drive Suite 100
Monrovia, CA 91016
Phone: 626-386-1100

Chain of Custody Record



eurofins

Environment Testing

Client Information (Sub Contract Lab)		Sampler:	Carrier Tracking No(s):
Client Contact: Shipping/Receiving		Lab P#: Arada, Rachelle	DOC No: 380-35173.1
Company: Physis Environmental Laboratories		E-Mail: Rachelle.Arada@jet.eurofinsus.com	Page: Page 1 of 1
Address: 1904 Wright Circle, City: Anaheim State, ZIP: CA, 92806 Phone:		State of Origin: Hawaii	Job #: 380-34727-1
Email:		Accreditations Required (See note):	Preservation Codes:
Project Name: RED-HILL.		TAT Requested (days):	A - HCl B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Ammonium H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other:
Site: Honolulu BWS Sites		PO#:	M - Hexane N - None O - AsNaQs P - Na2OHS Q - Na2SO3 R - Na2S2O3 S - H2SO4 T - TSP Difosechydrates U - Acetone V - MCA W - pH 4.5 Y - Trizma Z - other (specify)
Sample Identification - Client ID (Lab ID)		Sample Date:	Total Number of containers
		Sample Time:	
		Sample Type: (C=Comp., G=Grab)	Field Filtered Sample (Yes or No)
		Matrix: (W=water, S=solid, O=oil, A=aqueous, A/aqueous)	Perform MS/MSD (Yes or No)
		Preservation Code:	SUB (625 Acid/Base/PAH + TICs) / 625 Acid/Base/PAH + TICs
AIEA WELLS PUMPS 1&2 (260) (331-203-TP400) (380-34727-1)		1/17/23 09:20 Hawaiian Water X	6 See Attached Instructions
Empty Kit Relinquished by:		Date:	Special Instructions>Note:
Relinquished by: <i>HJ GRETNER</i>		Time:	
Deliverable Requested: I, II, III, IV, Other (specify)		Primary Deliverable Rank: 2	Method of Shipment:
Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)		<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For Months	
Special Instructions/QC Requirements:			
Custody Seals Intact:		Custody Seal No.:	
Δ Yes Δ No		Cooler Temperature(s) °C and Other Remarks:	

Note: Since laboratory accreditations are subject to change, Eurofins Eaton Analytical, LLC places the ownership of method, analysis & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analytes/substrates being analyzed, the samples must be shipped back to the Eurofins Eaton Analytical, LLC laboratory or other institutions will be provided. Any changes to accreditation status should be brought to Eurofins Eaton Analytical, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Eaton Analytical, LLC.

Possible Hazard Identification

Unconfirmed

Deliverable Requested: I, II, III, IV, Other (specify)

Primary Deliverable Rank: 2

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
 Return To Client Disposal By Lab Archive For Months

Special Instructions/QC Requirements:

</



Project Iteration ID: 1407003-365
Client Name: Eurofins Eaton Analytical
Project Name: RED-HILL Project # 38001111 Job # 380-34727-1
COC Page Number: 2 of 2
Bottle Label Color: NA

Sample Receipt Summary

Receiving Info

1. Initials Received By: 
2. Date Received: 11/19/23
3. Time Received: 1530
4. Client Name: Eurofins
5. Courier Information: (Please circle)

- Client UPS Area Fast DRS
- FedEx GSO/GLS Ontrac PAMS
- PHYSIS Driver:

- i. Start Time: _____
- ii. End Time: _____
- iii. Total Mileage: _____
- iv. Number of Pickups: _____

6. Container Information: (Please put the # of containers or circle none)

- Cooler Styrofoam Cooler Boxes None
- Carboy(s) Carboy Trash Can(s) Carboy Cap(s) Other _____

7. What type of ice was used: (Please circle any that apply)

- Wet Ice Blue Ice Dry Ice Water None

8. Randomly Selected Samples Temperature (°C): 1.0

Used I/R Thermometer # 1-2

Inspection Info

1. Initials Inspected By: 

Sample Integrity Upon Receipt:

1. COC(s) included and completely filled out.....  /  /  /  /  /  /  /  / 

Notes:

Chain of Custody Record

Client Information		Sampler: <i>Clay Hayne</i> Phone: <i>808 748 5840</i>		Lab PM: Arada, Rachelle		Carrier Tracking No(s): COC No: 380-21926-1845.1	
Client Contact: Dr. Ron Fenstemacher		Phone: E-Mail: Rachelle.Arada@et.eurofinsus.com		State of Origin:		Page: Page 1 of 4	
Company: City & County of Honolulu		PWSID:				Job #:	
Address: 630 South Beretania Street Chemistry Lab		Due Date Requested:				Analysis Requested	
City: Honolulu		TAT Requested (days):				Preservation Codes:	
State, Zip: HI, 96843		Compliance Project: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				A - HCL M - Hexane B - NaOH N - None C - Zn Acetate O - AsNaO2 D - Nitric Acid P - Na2O4S E - NaHSO4 Q - Na2S03 F - MeOH R - Na2S2O3 G - Amchlor S - H2SO4 H - Ascorbic Acid T - TSP Dodecahydrate I - Ice U - Acetone J - DI Water V - MCAA K - EDTA W - pH 4-5 L - EDA Y - Trizma Other: Z - other (specify)	
Phone: 808-748-5091(Tel)		PO #: C20525101 exp 05312023					
Email: RFENSTEMACHER@hbws.org		WO #:					
Project Name: RED-HILL		Project #: 38001111					
Site: Hawaii		SSOW#:					
Sample Identification		Sample Date	Sample Time	Sample Type (C=comp, G=grab) BT=tissue, A=air	Matrix (W=water, S=solid, O=wastefill, BT=tissue, A=air)	Field Filtered Sample (Y/N or No)	Total Number of Containers
						<input checked="" type="checkbox"/>	
AIEA GULCH WELLS PUMP 1				Water	R	N D N CB HA	
AIEA GULCH WELLS PUMP 2				Water	R	N D N CB HA	
AIEA WELLS P (260)				Water	R	N D N CB HA	
HALAWA WELLS UNITS 1 & 2				Water	R	N D N CB HA	
MOANALUA WELLS				Water	R	N D N CB HA	
HALAWA SHAFT VIEW POOL				Water	R	N D N CB HA	
KAAMIO WELLS				Water	R	N D N CB HA	
TB: AIEA GULCH WELLS PUMP 1				Water	R	N D N CB HA	
TB: AIEA GULCH WELLS PUMP 2				Water	R	N D N CB HA	
TB: AIEA WELLS PUMPS1&2(260)		<i>1-7-23</i>	<i>0920</i>	<i>C</i>	Water	<input checked="" type="checkbox"/>	<i>Pump 2 in service</i>
TB: HALAWA WELLS UNITS 1 & 2				Water	R	N D N CB HA	
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)	
<input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological						<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months	
Deliverable Requested: I, II, III, IV, Other (specify)						Special Instructions/QC Requirements:	
Empty Kit Relinquished by:		Date:	Time:	Method of Shipment:			
Relinquished by:		<i>1-7-23 1100</i>	<i>10:00</i>	Company	Received by: <i>A. J. G. RETTNER</i>	Date/Time: <i>01/18/2023 10:00</i>	Company <i>EFA</i>
Relinquished by:		Date/Time:	Company	Received by:	Date/Time:	Company	
Relinquished by:		Date/Time:	Company	Received by:	Date/Time:	Company	
Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks: <i>(752A) GEL-FROZEN { 2.1-2.0 1.5-1.4</i>			



380-34727 COC

FEDEX 7710 5196 { 7512
7442 7659

Ver. 06/08/2021

1.3-1.2

Chain of Custody Record

Client Information		Sampler: <i>Olof Keppe</i>		Lab PM: Arada, Rachelle		Carrier Tracking No(s):		COC No: 380-21926-1845.2
Client Contact: Dr. Ron Fenstemacher		Phone: 808 748 5840		E-Mail: Rachelle.Arada@et.eurofinsus.com		State of Origin:		Page: Page 2 of 4
Company: City & County of Honolulu		PWSID:		Analysis Requested				Job #:
Address: 630 South Beretania Street Chemistry Lab		Due Date Requested:						Preservation Codes:
City: Honolulu		TAT Requested (days):						A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA M - Hexane N - None O - AsNaO2 P - Na2O4S Q - Na2SO3 R - Na2S2O3 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 Y - Trizma Z - other (specify)
State, Zip: HI, 96843		Compliance Project: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						
Phone: 808-748-5091(Tel)		PO #: C20525101 exp 05312023						
Email: RFENSTEMACHER@hbws.org		WO #:						
Project Name: RED-HILL		Project #: 38001111						
Site: Hawaii		SSOW#:						
Sample Identification		Sample Date	Sample Time	Sample Type (C=Comp, G=grab) BT=Tissue, A=Air	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No)	Total Number of containers	Special Instructions/Note:
AIEA GULCH WELLS PUMP 1					Water	R R R R RA R		
AIEA GULCH WELLS PUMP 2					Water			
AIEA WELLS P (260)					Water			
HALAWA WELLS UNITS 1 & 2					Water			
MOANALUA WELLS					Water			
HALAWA SHAFT VIEW POOL					Water			
KAAMIMO WELLS					Water			
TB: AIEA GULCH WELLS PUMP 1					Water			
TB: AIEA GULCH WELLS PUMP 2					Water			
TB: AIEA WELLS PUMPS1&2(260)		1-17-23	0820	C	Water	X X X X	Keppe 2 in service	
TB: HALAWA WELLS UNITS 1 & 2					Water			
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)		
<input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological						<input type="checkbox"/> Return To Client	<input type="checkbox"/> Disposal By Lab	<input type="checkbox"/> Archive For _____ Months
Deliverable Requested: I, II, III, IV, Other (specify)						Special Instructions/QC Requirements:		
Empty Kit Relinquished by:		Date:	Time:			Method of Shipment:		
Relinquished by: <i>Olof Keppe</i>		Date/Time: 1-17-23 1100	Company:	Received by: <i>M. J. G. PEITNER</i>	Date/Time: 01/18/2023 10:00	Company: <i>EPA</i>		
Relinquished by:		Date/Time:	Company:	Received by:	Date/Time:	Company:		
Relinquished by:		Date/Time:	Company:	Received by:	Date/Time:	Company:		
Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks: (752A) GEL-FROZEN { 21-2.0 1.5-1.4 1.3-1.2 Ver: 06/08/2021				

Shipping Summary



Environment Testing

Bottle Order Information

Bottle Order: RED-HILL - Quarterly
 Bottle Order #: 1845
 Request From Client: 6/23/2022
 Date Order Posted: 6/23/2022 7:29:27AM
 Order Status: Shipped
 Prepared By: Davis Haley
 Deliver By Date: 6/27/2022 11:59:00PM

When To Ship:



S 3 8 0 - 6 9 8 8

Monrovia, CA (Suite 100)
 750 Royal Oaks Drive Suite 100
 Monrovia, CA 91016
 Phone (626) 386-1100

Project/Event Information

Project Manager: Rachelle Arada
 Tel: (626) 386-1106 Em: Rachelle.Arada@et.eurofinsus.com
 Lab Project Number: 38001111
 Project Ref: RED-HILL
 Event Desc:

RECEIVED
-GR 01/18/2023

Client Samples: AIEA GULCH WELLS PUMP 1, AIEA GULCH WELLS PUMP 2, AIEA WELLS P___ (260), HALAWA SHAFT VIEW POOL, HALAWA WELLS UNITS 1 & 2, KAAMILO WELLS, MOANALUA WELLS

Sets	Bottles/Set	Bottle Type Description	Field Filtered	Preservative	Method	Matrix	Comments
7	6	Voa Vial 40ml Amber - Sodium thiosulfate		Sodium Thiosulfate	504.1_PREC - Local Method 505_LL_PREC - (MOD) ML505 +505-EAL Aldrin Dieldrin Tox	Water Water	<i>1 OUT OF 6 HAS ICE FORMATION - GR</i>
7	1	Plastic 250ml - unpreserved		None	2320B - (MOD) Total Alkalinity SM4500_H+ - Local Method 2510B - Conductivity	Water Water Water	
7	1	Plastic 500ml - with Nitric Acid		Nitric Acid	200.8 - Metals, Priority Pollutant by 200.8 200.7 - (MOD) Custom	Water Water	<i>ICE FORMATION - GR</i>

Please notify your PM immediately if an error is found in shipment. When returning samples, please return all provided QC samples.

Shipping Summary

Client Samples: AIEA GULCH WELLS PUMP 1, AIEA GULCH WELLS PUMP 2, AIEA WELLS P___ (260), HALAWA SHAFT VIEW POOL, HALAWA WELLS UNITS 1 & 2, KAAMIMO WELLS, MOANALUA WELLS

Sets	Bottles/Set	Bottle Type Description	Field Filtered	Preservative	Method	Matrix	Comments
7	1	Plastic 500ml - unpreserved		None	2540C_Calcd - Total Dissolved Solids (TDS)	Water	ICE FORMATION -GR
7	1	Plastic 250ml - with Zinc Acetate & NaOH		Zinc Acetate and Sodium Hydroxide	SM4500_S2_D - Sulfide, Total	Water	
7	6	Voa Vial 40ml Amber - Ascor. Acid & HCL		Ascorbic Acid and Hydrochloric Acid	524.2_Pres_PREC - VOASDWA plus TICs + Acetone 524.2_SIM_PREC - TBA by 524.2 SIM	Water	
7	3	Amber Glass 1 Liter- Sodium Sulfite/HCl		Sodium Sulfite w/HCl	525.2_PREC - 525plus Plus TICs	Water	-1 OUT OF 3 ICE FORMATION -GR -1 OUT OF 3 ARCHIVED BROKEN -GR
7	2	Plastic 125mL - unpreserved		None	300_OF_28D_B - Bromide 4500_F_C - Fluoride 300_OF_28D_PREC - Chloride and Sulfate 300_OF_48H_PREC - Nitrite, Nitrate, and Nitrite+Nitrate	Water Water Water Water	1 OUT OF 2 HAS ICE FORMATION -GR
7	1	Plastic 250ml - with Nitric Acid		Nitric Acid	245.1 - Local Method	Water	
7	2	Amber Glass 1 L - NaThiosulfate 8mL HCL		Sodium Thiosulfate/Hydrochloric Acid	SUBCONTRACT - 8015 Jet Fuel 8 (JP8)	Water	1 OUT OF 2 HAS ICE FORMATION -GR
7	2	Amber Glass 1 L - NaThiosulfate 8mL HCL		Sodium Thiosulfate/Hydrochloric Acid	SUBCONTRACT - 8015 Jet Fuel 5 (JP5)	Water	
7	2	Amber Glass 1 L - NaThiosulfate 8mL HCL		Sodium Thiosulfate/Hydrochloric Acid	SUBCONTRACT - 8015 Diesel LL (EAL) and Motor Oil	Water	
7	3	Voa Vial 40ml - SodiumThio w/HCl-dropper		Sodium Thiosulfate	SUBCONTRACT - 8015 Gas (Purgeable) LL (EAL)	Water	

Please notify your PM immediately if an error is found in shipment. When returning samples, please return all provided QC samples.

Shipping Summary

Client Samples: TB: AIEA GULCH WELLS PUMP 1, TB: AIEA GULCH WELLS PUMP 2, TB: AIEA WELLS PUMPS1&2(260), TB: HALAWA SHAFT VIEW POOL,
TB: HALAWA WELLS UNITS 1 & 2, TB: KAAMIMO WELLS, TB: MOANALUA WELLS

Sets	Bottles/Set	Bottle Type Description	Field Filtered	Preservative	Method	Matrix	Comments
7	2	VOA Vial 40mL - NaThiosulfate/HCL		Sodium Thiosulfate/Hydrochloric Acid	SUBCONTRACT - 8015 Gas (Purgeable) LL (EAL)	Water	
7	6	Voa Vial 40ml Amber - Ascor. Acid & HCL		Ascorbic Acid and Hydrochloric Acid	524.2_Pres_PREC - VOASDWA plus TICs + Acetone 524.2_SIM_PREC - TBA by 524.2 SIM	Water	RECEIVED 2 OUT OF 6 - GR
7	3	Voa Vial 40ml Amber - Sodium thiosulfate		Sodium Thiosulfate	504.1_PREC - Local Method	Water	RECEIVED 2 OUT OF 3 - GR
7	2	Voa Vial 40ml Amber - Ascorbic & Maleic		Ascorbic Acid/Maleic	524.3_SIM_PREC - Low Level TCP/EDB/DBCP	Water	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

Please notify your PM immediately if an error is found in shipment. When returning samples, please return all provided QC samples.

Shipping Summary

Client Samples: AIEA GULCH WELLS PUMP 1, AIEA GULCH WELLS PUMP 2, AIEA WELLS P___ (260), HALAWA SHAFT VIEW POOL, HALAWA WELLS UNITS 1 & 2, KAAMILO WELLS, MOANALUA WELLS

Sets	Bottles/Set	Bottle Type Description	Field Filtered	Preservative	Method	Matrix	Comments
7	3	Voa Vial 40ml Amber - Sodium thiosulfate		Sodium Thiosulfate	SUBCONTRACT - 8015 Ethanol	Water	
7	2	Amber Glass 1 liter - Sodium Thiosulfate		Sodium Thiosulfate	SUBCONTRACT - 625 PAH Physis LL (EAL) + TICs	Water	<i>1 OUT OF 2 HAS ICE FORMATION - GR</i>
7	2	Amber Glass 1 liter - Sodium Thiosulfate		Sodium Thiosulfate	SUBCONTRACT - 625 Base Neutral LL (EAL) Physis	Water	
7	2	Amber Glass 1 liter - Sodium Thiosulfate		Sodium Thiosulfate	SUBCONTRACT - 625 Acid LL (EAL) Physis	Water	<i>1 OUT OF 2 HAS ICE FORMATION - GR</i>
7	3	Voa Vial 40ml Amber - Ascorbic & Maleic		Ascorbic Acid/Maleic	524.3_SIM_PREC - Low Level TCP/EDB/DBCP	Water	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

Please notify your PM immediately if an error is found in shipment. When returning samples, please return all provided QC samples.



卷之三

Note: Since laboratory accreditations are subject to change, Eurofins Eaton Analytical, LLC places the ownership of method, analysis & accreditation compliance until our subcontracted laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not complete the analysis/assessment in the State of Origin listed above for analytes/parameters being analyzed, the samples must be shipped back to the Eurofins Eaton Analytical, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to the attention of the signed Chain of Custody at Eurofins Eaton Analytical, LLC.

Possible Hazard Identification

Unconfirmed
Deliverable Requested: I, II, III, IV, Other (specify)

Primary Deliverable Bank: 2

Return To Client *Disp.*

110

For Mont

1

100

104

104

10

10

1

104

/2021

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-34727-1

Login Number: 34727

List Source: Eurofins Drinking Water Testing Pomona

List Number: 1

Creator: Segura, Ryan

Question

Answer

Comment

The cooler's custody seal, if present, is intact.

True

Sample custody seals, if present, are intact.

True

Samples were received on ice.

True

Cooler Temperature is acceptable.

True

Cooler Temperature is recorded.

True

COC is present.

True

COC is filled out in ink and legible.

True

COC is filled out with all pertinent information.

True

There are no discrepancies between the containers received and the COC.

True

Samples are received within Holding Time (excluding tests with immediate HTs)

True

Sample containers have legible labels.

True

Containers are not broken or leaking.

True

Sample collection date/times are provided.

True

There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs

True

Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").

True

Samples do not require splitting or compositing.

True

Container provided by EEA

True

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-34727-1

Login Number: 34727

List Source: Eurofins Eaton South Bend

List Number: 2

List Creation: 01/20/23 12:09 PM

Creator: Blackburn, Kelly

Question

Answer

Comment

The cooler's custody seal, if present, is intact.

True

Sample custody seals, if present, are intact.

True

Samples were received on ice.

True

Cooler Temperature is acceptable.

True

Cooler Temperature is recorded.

True

COC is present.

True

COC is filled out in ink and legible.

True

COC is filled out with all pertinent information.

True

There are no discrepancies between the containers received and the COC.

True

Samples are received within Holding Time (excluding tests with immediate HTs)

True

Sample containers have legible labels.

True

Containers are not broken or leaking.

True

Sample collection date/times are provided.

True

There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs

True

Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").

True

Samples do not require splitting or compositing.

True

Container provided by EEA

False

Client provided containers